

Appendix D1 – Management Programs (Stormwater Management)

**ROBERT G. CASSILLY**  
Harford County Executive

**ROBERT S. McCORD**  
Director of Administration



**JOSEPH J. SIEMEK, P.E.**  
Director of Public Works

## DEPARTMENT OF PUBLIC WORKS

**DATE:** June 1, 2023

**FROM:** Division of Environment and Sustainability  
Bureau of Stormwater Management

**TO:** Harford County Engineering, Developer and Consultant Community

**RE:** Stormwater Review Directive **Effective June 1, 2023** (Bond Values)

This affects only Final Review Submittals made after this date.

Stormwater Management Bond amounts will be determined using the following unit prices.

NO.	ITEM	UNIT	UNIT COST
101	Clearing and Grubbing	AC.	\$6,000.00
201	Earthwork	C.Y.	\$41.00
201A	Earthwork – Mass Grading *	C.Y.	\$20.00
202	Cutoff Trench/Impervious Core Clay Material on Site	C.Y.	\$20.00
203	Clay Material Off Site	C.Y.	\$45.00
204	Test Pit Excavation	C.Y.	\$90.00
301	Concrete Sand ASTM C-33	C.Y.	\$82.00
302	Mix No. 3 Concrete for miscellaneous structures	C.Y.	\$430.00
303	Concrete Pipe Bedding	C.Y.	\$300.00
304	15" RCP C-361	L.F.	\$75.00
305	18" RCP C-361	L.F.	\$85.00

*Harford County Celebrates 250 Years ~ 1773-2023*

306	24" RCP C-361	L.F.	\$105.00
307	30" RCP C-361	L.F.	\$130.00
308	36" RCP C-361	L.F.	\$155.00
309	42" RCP C-361	L.F.	\$195.00
310	48" RCP C-361	L.F.	\$235.00
311	54" RCP C-361	L.F.	\$295.00
312	60" RCP C-361	L.F.	\$340.00
313	72" RCP C-361	L.F.	\$455.00
314	15" Concrete End Section	EA.	\$750.00
315	18" Concrete End Section	EA.	\$800.00
316	24" Concrete End Section	EA.	\$850.00
317	30" Concrete End Section	EA.	\$1,200.00
318	36" Concrete End Section	EA.	\$1,750.00
319	42" Concrete End Section	EA.	\$2,500.00
320	48" Concrete End Section	EA.	\$3,000.00
321	15" BCCMP 14 Ga	L.F.	\$65.00
322	18" BCCMP 14 Ga	L.F.	\$75.00
323	24" BCCMP 14 Ga	L.F.	\$95.00
324	30" BCCMP 14 Ga	L.F.	\$105.00
325	36" BCCMP 14 Ga	L.F.	\$120.00
326	42" BCCMP 14 Ga	L.F.	\$135.00
327	48" BCCMP 12 Ga	L.F.	\$160.00
328	54" BCCMP 14 Ga	L.F.	\$170.00
329	60" BCCMP 14 Ga	L.F.	\$195.00
330	72" BCCMP 14 Ga	L.F.	\$225.00

331	15" Metal End Section	EA.	\$305.00
332	18" Metal End Section	EA.	\$365.00
333	24" Metal End Section	EA.	\$480.00
334	30" Metal End Section	EA.	\$820.00
335	36" Metal End Section	EA.	\$1,050.00
336	42" Metal End Section	EA.	\$2,100.00
337	48" Metal End Section	EA.	\$2,490.00
338	Std. Y-1 Inlet (Minimum Depth)	EA.	\$3,375.00
339	Std Y-1 Inlet (Vertical Depth)	L.F.	\$330.00
340	Class I Rip-Rap (per 1' depth)	S.Y.	\$61.00
341	Class II Rip-Rap (per 1' depth)	S.Y.	\$70.00
342	Gabions	C.Y.	\$200.00
343	Filter Cloth	S.Y.	\$4.00
344	Hardware Cloth	S.Y.	\$5.00
345	PVC Pipe 6"/8"	L.F.	\$40.00
346	PVC Pipe 12"	L.F.	\$60.00
347	No. 2 Stone	C.Y.	\$85.00
501	CR-6 (access road 8" thick)	S.Y.	\$15.00
601	42" Chain Link Fence	L.F.	\$25.00
602	18' Gate	EA.	\$1,285.00
603	Split Rail Fence (3 rail w/wire)	L.F.	\$25.00
701	Solid Sodding	S.Y.	\$12.50
702	Seed and Mulch	S.Y.	\$2.00
703	Landscaping (S.F. of stormwater management easement)	S.F.	\$2.00
704	Permeable Soil	C.Y.	\$80.00



---

**ROBERT G. CASSILLY**  
Harford County Executive

**ROBERT S. McCORD**  
Director of Administration



**JOSEPH J. SIEMEK, P.E.**  
Director of Public Works

---

## DEPARTMENT OF PUBLIC WORKS

**DATE:** March 12, 2024

**FROM:** Division of Environment and Sustainability  
Bureau of Stormwater Management

**TO:** Harford County Engineering, Developer and Consultant Community

**RE:** Stormwater Review Directive: Pond Repair Spillway (Barrel and Riser) Replacements

***This directive will apply to Final Pond Repair Review submissions received by Harford County after April 23, 2024.***

The Maryland Department of the Environment Dam Safety Division has instructed the Harford Soil Conservation District to have design engineers provide the following updated analyses for in-kind replacement of barrels and riser structures (pond repairs):

**Breach Analysis:** A new breach analysis is necessary unless the design engineer can review the old breach analysis to determine its adequacy. A new analysis or review of the old analysis needs to evaluate the downstream conditions to see if they have changed (i.e., more housing, development, etc.) and if the quality of the original study is still acceptable by current standards. [2018-05-15-Breach-Analysis-Guidance.pdf \(maryland.gov\)](#)

**Hydrology & Hydraulic Analysis:** A new analysis or an update of the old study is necessary to evaluate the changes in the upstream watershed. In addition, design rainfall values have now changed by adopting the NOAA Atlas 14 precipitation values with the Type C rainfall distribution. [Policy Memorandum No. 17 - In-Kind Replacement of Spillways.pdf \(maryland.gov\)](#)

Please provide the two analyses; depending on the results, the county reviewer may require modification of the riser structure, storage area, pipe size, and/or emergency spillway.

*Harford County Celebrates 250 Years ~ 1773-2023*

**Reminder:** The TP 40 and NRCS Type II rainfall distribution no longer apply. Please use the Type C rainfall distribution and use the following (Harford NOAA-C) 24-hour rainfall duration values:

1-year 2.69 in  
2-year 3.26 in  
5-year 4.19 in  
10-year 5.00 in  
25-year 6.25 in  
50-year 7.34 in  
100-year 8.58 in

**Note:** Filter Diaphragms are preferred over anti-seep collars but not required for Small Ponds.

**EFFECTIVE DATE: April 24, 2024**

---

**ROBERT G. CASSILLY**  
Harford County Executive

**ROBERT S. McCORD**  
Director of Administration



**JOSEPH J. SIEMEK, P.E.**  
Director of Public Works

---

**DEPARTMENT OF PUBLIC WORKS  
BUREAU OF STORMWATER MANAGEMENT**

**DATE:** September 6, 2024  
**FROM:** Division of Environment and Sustainability ~ Bureau of Stormwater Management  
**TO:** Harford County Engineering, Developer and Consultant Community  
**SUBJECT:** Stormwater Management Compliance Guidance - **Frequently Asked Questions**

The MDE is currently working on proposed changes to §4-201 and §4-203, annotated Code of Maryland Title 26 Department of the Environment Subtitle 17 Water Management and Chapter 02 Stormwater Management. Until these changes are enacted, the following Harford County guidance items are to be implemented:

**1. Can Enhanced filters provide ESDv?**

Enhanced Filters may be utilized in combination with properly designed Environmental Site Design (ESD) facilities to provide water quality volume (WQv) and recharge volume (Rev). Enhanced Filters cannot be utilized to provide channel protection volume (CPv). The Environmental Site Design volume (ESDv) is comprised of both WQv and CPv. Enhanced Filters do not meet the full intent of the CPv component of ESDv. Enhanced Filter practices have high flowrates and the drain down time is significantly shorter than the 24–36-hour requirement for CPv. To achieve CPv a facility must meet the intent of the slow-release rate. Enhanced Filters cannot be used as a standalone practice to meet the full ESDv requirement.

- a. MDE approved technology enhanced filters, such as Filtera's, do not provide CPv because of the high flow rate and are for WQv only.
- b. Enhanced filters designed directly below Micro-Bioretenion or Bioswale, etc (as shown in the MDE Stormwater Design Manual) are purely for Recharge Volume (Rev) ONLY. Harford County does not credit additional WQv or CPv associated with this enhanced filter configuration. The runoff enters the enhanced filter only after slowly passing through the properly designed Micro-Bioretenion media where the ESDv credit is obtained. Only additional Rev credit is obtained in the enhanced filter below the treatment facility.

**2. Is 4-foot Groundwater Separation required for all ESD infiltration facilities?**

Yes. Facilities designed as Infiltration Practices require a 4-foot separation from the bottom of the facility to the seasonally high ground water table. Infiltration practices include the natural ground as part of the filtering mechanism (media). Infiltration practices introduce a large amount of water into the ground. When a large amount of water is introduced this way, inadequate separation may allow the ground water to mound up and encroach into the facility eliminating the filtering mechanism and the facility will stop working. All *Infiltration* practices must have the 4-foot minimum separation from the seasonally high groundwater.

*Harford County Celebrates 250 Years ~ 1773-2023*

The determination of the seasonally high groundwater needs to be clearly documented by a qualified professional. To avoid re-design issues at the Final design, the determination of seasonally high groundwater must be submitted as part of the Site design phase.

For facilities designed as Filtering Practices where the filtering mechanism (media) is placed at the surface; includes an aggregate reservoir provided below the media; and also includes an underdrain piping system, the groundwater mounding is most likely to be drained off through the underdrain system. In this case the filtering mechanism is not impacted, and the facility will continue to function as designed. Therefore, the inclusion of the underdrain could be a case where the ground water separation is *not completely necessary for the operation of the facility and ground water may approach closer to the bottom of the facility while still meeting the treatment design intent of the facility*. Therefore, on a case-by-case basis Harford County may allow a Waiver of the reduction of the 4-foot groundwater separation. The County will require a formal written Waiver request. Groundwater shall never be allowed to be above the invert of the underdrain thereby continuously draining the water table. The designer must select the most appropriate facility type when groundwater is present. County approval of the Waiver request is not guaranteed and depends on the actual separation of groundwater and the bottom of the facility. Impermeable liners for filtering practices are not preferred by the County to keep ground water separate.

### **3. How do I determine Recharge volume compliance?**

If a project meets the Target ESDv volume requirement, then it is allowable to state that the Rev requirements have also been achieved for the project. Designers may calculate the Rev provided by individual facilities utilizing the contributing drainage area and the corresponding Composite Soil Specific Recharge Factor. The Rev provided by each facility may be summed for a total project Rev. However, if a facility has an impermeable liner such as a concrete box or Clay/PVC liner, then the facility will not provide Rev and cannot be credited toward a projects Rev.

- a. Regardless of the presence of an underdrain, an individual facility can be considered to meet Rev only if it meets the Target ESDv and does not have an impermeable liner.
- b. Designers may calculate Rev below underdrains to determine Rev for each facility, however this is not necessary.
- c. Submerged Gravel Wetlands are ESD facilities with media; Rev can be credited for these facilities only if they meet the Target ESDv for the drainage area to the facility. No enhanced filter can be used with SGWs.

### **4. How do I determine the remaining ESDv, and can I capture it in water quality practices?**

The Target ESDv for the project (Limit of Disturbance) must be provided by Chapter 5 practices unless all Chapter 5 practice options have been exhausted. The County retains the authority to determine if all Chapter 5 practices for a project have been exhausted. The project must treat a minimum of 1-inch of runoff volume ( $P_e = 1$  inch) in ESD practices before standard Chapter 3 facilities may be utilized to provide/store the remaining ESDv requirement. Computations must be provided to show how the selected Chapter 3 practices will store/treat the remaining ESDv.

### **5. What is Harford County's understanding of the requirement that certain ESD facilities shall store 75% of the ESDv?**

Chapter 3 of the MDE Manual states that for Stormwater Filtering Systems the entire treatment system shall temporarily hold at least 75% of the WQv prior to filtration (above the surface). This concept should therefore be applied to Chapter 5 ESD Micro-Scale facilities where the MDE Stormwater Design Manual references that a facility shall store 75% of the ESDv, which will also include Micro-Bioretenion's, Bioswales and Submerged

Gravel Wetlands. The media section of ESD facilities is considered the filtering mechanism and therefore 75% of the Target volume must be stored **above the media**. Harford County does not allow for storage calculations to include the porosity of the media and aggregate layers. The 75% surface storage requirement provides a 25% credit for storage within the filtering media. The ESDv credit of any facility is limited to the runoff generated by the 1-yr 24-hr storm NOAA Type C distribution ( $P_e = 2.69''$ ) from the facilities contributing area. Refer to the NRCS Maryland National Engineering Field Handbook Part 650 Change Notice No. 6 (July 11, 2016).

Therefore:

- a. Only the actual Surface Storage Volume Provided at the design ponding depth may be divided by 75% to obtain the total Facility ESDv provided. (Total ESDv = Surface Storage Volume / 75%).
- b. The total ESDv provided can only be up to a maximum of the 1-yr ESD target volume for the facility's contributing area ( $P_e = 2.69''$ ).

#### **6. How is “ESDv provided” determined for a Submerged Gravel Wetland?**

Submerged Gravel Wetland facilities must provide a minimum of 75% storage of the Target ESDv above the surface (ponding storage to the ponding depth, which does not include the dry 4” below the surface). See item #5 regarding the 75% Surface Storage volume. The volume within the submerged gravel wetland layers is considered “Dead Storage” and cannot be counted toward the storage provided. ESDv storage requirement is based on the surface storage provided as stated in item #5 above (maximum ponding depth = 2’).

- a.  $ESDv \text{ provided} = \text{Surface Storage Volume} / 75\%$  (up to the maximum Target ESDv of the contributing area to the SGW facility for 1-yr 24hr storm ( $P_e = 2.69''$ ))
- b. Submerged Gravel Wetlands should not be designed in A/B soils. Generally, Submerged gravel wetlands should not be designed with liners for use in A/B soils. A different facility that is more appropriate to the site's soil should be considered to promote localized groundwater recharge.

#### **7. How is “ESDv provided” determined for a Landscape Infiltration?**

Do not confuse “Filtering Practices” and “Infiltration Practices.” Filtering practices vs. Infiltration practices are basically the same except for the location of the storage reservoir and filtering mechanism. Landscape Infiltration facilities (M-3) are “Infiltration Practices” that utilize the natural/native soil as the filtering mechanism. The storage reservoir is considered temporary ponding and includes the sand and aggregate media layers above the natural/native soils. The ESDv provided is the temporary ponding volume plus the porosity ( $n=0.40$ ) volume of the sand and aggregate media layers that are above the natural/native soils.

- a.  $ESDv \text{ provided} = \text{Surface Storage Volume} + 0.40 \times (\text{volume in the sand and aggregate media layers})$

#### **8. How is “ESDv provided” determined for a Bio-Swale?**

Bio-Swale facilities must provide 75% storage above the filtering media (surface storage). See item #5 regarding 75% Surface Storage volume. Increasing the media depth from 2’ to 4’ will not generate additional ESDv provided since the ESDv storage requirement is based only on the surface storage provided as stated in item #5 above. Harford County does not accept the use of MDE Equation 5.2 to determine the ESDv provided for Grass Swales. Use Equation 5.3 for grass swales.

- a. Check dams may be used to provide increased surface storage volume up to 1-foot. However, check dams' main function is for velocity control. If a Bio-swale includes check dams, then the geometric volume behind each check dam is calculated to determine the surface storage volume in each segment.

- b. Bioswale with Check Dams → ESDv = Total Surface Storage Volume provided behind the check dams (above the surface/media) / 75% (up to the maximum Target ESDv of the contributing area for 1-yr 24hr storm {Pe = 2.69'}).
- c. If a Bio-swale does not have check dams, then the surface storage would be based on the **calculated** flow depth (1-year storm event) multiplied by the average swale width and multiplied by the swale length. The flow criteria restrictions provided in MDE Chapter 5 (M-8 Swales) must be achieved to be able to obtain the ESDv credit (i.e., 4" max ESDv flow depth, 1 ft./sec ESDv flow velocity). Note: Manning's n = 0.15 is achieved when the grass depth is equal to the flow depth. Reminder: having a 4" depth of grass does not create a 4" flow depth.
- d. Bioswale without Check Dams → ESDv = (calculated flow depth x average swale width x swale length) / 75% (up to a maximum Target ESDv of the contributing area for 1-yr 24hr storm) {Pe = 2.69'}.
- e. Note: a control structure at the end of the swale with an elevated weir can be utilized to create ponding depth for a bioswale, since the ponding is temporary with the flow passing through the media and the underdrain connected to the control structure.

### 9. How is "ESDv provided" determined for a Grass Swale?

ESDv provided by Grass Swales is calculated based on the length of the swale times the average cross-sectional width times the depth of the flow produced by the 1-yr 24-hr (ESDv {Pe = 2.69'}) storm. The flow depth is based on Manning's equation for the peak 1-yr storm event (SCS Method: WinTR55) flow produced by the contributing area, limited to a maximum flow depth of 4-inches. Harford County does not accept the use of MDE Equation 5.3 to determine the ESDv provided for Grass Swales.

- a. Provided ESDv = Average cross-section width x calculated flow depth x swale length (up to the maximum Target ESDv of the contributing area for 1-yr 24hr storm {Pe = 2.69'}).
- b. ESDv flow depth and velocity calculations must be provided using Manning's equation with n=0.15
- c. The flow criteria in MDE Chapter 5 must be achieved to obtain the ESDv credit (i.e., 4" max ESDv flow depth, 1 ft./sec. ESDv flow velocity). Note: Manning's n = 0.15 is achieved when the grass depth is equal to the flow depth. Reminder: having a 4" depth of grass does not create a 4" flow depth.

### 10. Can hydraulic routing be used for ESD facilities?

Yes, current hydraulic modeling software can be used to determine WSE and flow rates out of ESD facilities. Runoff based on SCS Method, NOAA Atlas 14 precipitation values with Type C rainfall distribution (Refer to the NRCS Maryland National Engineering Field Handbook Part 650 Change Notice No. 6 July 11, 2016).

If hydrograph routing is to be conducted for ESD facilities, then the following techniques must be utilized for Harford County acceptance:

- a. For a filtering facility, it is acceptable to only use surface storage and surface outlet control devices in the routing model. Even if an ESD facility includes an underdrain beneath filter media, the underdrain cannot be used as a direct and/or indirect discharge stage in the routing model.
- b. For infiltration facilities (no underdrains), it is acceptable to use surface storage, surface outlet control devices and apply an infiltration flow using an infiltration rate (Rawls) across the surface area (or area of the bottom of the media, when applicable), in the routing model. Note: if the surface area is not flat, then the determination of the infiltration flow value needs to be presented in a detailed calculation. Reminder: for flat facilities, the infiltration component does not start until the entire surface area is ponding. The model needs to be set with a starting ponding depth for the infiltration.

### **11. Can the Reduced Runoff Curve Number Method be used?**

The Runoff reduction methodology was intended to incentivize developers to utilize ESD facilities. The use of the runoff reduction method should be considered on a case-by-case basis to determine if it is applicable to the site's configuration. Use of the method is intended for smaller storm events such as the 1-yr and 2-year events for the drainage areas to the ESD facilities. This method could also be used for the 10-year event based on the MDE guidelines but is not recommended by Harford County; the County will require a formal written Waiver request.

The reduction method should not be used for 100-year storm event. The 100-year design is to ensure safe passage of extreme events. Utilizing the runoff reduction method to reduce the CN value for 100-year event assumes each ESD facility is functioning at 100% design. This may not be realistic as ESD facilities will most likely be inundated during extreme storm events allowing runoff to short circuit the peak flow. Additionally, long term maintenance inadequacies may reduce the effectiveness of each ESD facility. As a result, utilizing runoff reduction method for 100-year events may allow for the under sizing of ponds resulting in freeboard requirements not being achieved for safe passage of extreme events.

Hydraulic routing is a preferable method and is an acceptable method to determine peak discharge flows. Hydraulic routing allows for specific hydrograph analysis that accounts for each facility's storage vs. control stages.

### **12. What is the maximum credit and size ESD facility designed for?**

The state mandates that WQv, Rev, and CPv are to be provided for projects that require SWM. As a result, Harford County allows ESDv credit for the entire 1-year 24-hour storm event up to a  $P_e = 2.69''$  of runoff. In addition to the state mandate, Harford County requires Flood Protection of the 10-year 24-hour storm event.

Harford County only allows ESDv provided credit up to the 1-year 24-hour storm event ( $P_e = 2.69''$ ), however ESD facilities may be oversized to account for the County's 10-year flood protection requirement. Oversizing ESD facilities (that do not have to be off-line) for 10-year management is not recommended and is not a normal course of practice. The preferred design will use ESD practices for the 1-year storm event with excess volume bypassing or spilling into a traditional Chapter 3 facility for 10-year quantity management. The County understands that this traditional method may not be appropriate for specific lots and therefore will allow the use of ESD facilities to be oversized for 10-year quantity. However, there is a practical limit to enlarging ESD facilities where the ESD begins to become a Chapter 3 facility and therefore the County will evaluate the appropriateness of oversized ESD facilities on a case-by-case basis. If ESD facilities are used for 10-year quantity management, the designer should evaluate the following:

- a. Perform hydraulic routing of the ESD facility to determine 10-yr WSE and peak discharge rates.
- b. Evaluate embankment classification. Based on the embankment classification the engineer must meet all required criteria.
- c. Maximum WSE must not be more than 2-feet above the facility surface. Planting plans must be provided that demonstrate the plantings will survive the designed water depths.
- d. Sizing for 10-year management should be based on hydraulic routing.

### **13. What is the minimum freeboard for ESD and Quantity Management Facilities?**

ESD facilities that are designed offline, have a drainage area of less than 0.50 acres, and are not intended to provide quantity management ( $Q_p$ ) shall provide a minimum freeboard of 6-inches above the 10-yr WSE. For all MDE Chapter 5 facilities with drainage areas greater than 0.50 acres and Chapter 3 facilities that are not classified as MDE Code 378 facilities must be designed in accordance with the requirements of the sub-code

378 criteria in the front end of MDE Manual Chapter 3 Section 3.1.1 Pond Feasibility Criteria. The table below shows the minimum requirements for different example embankments, it is the Engineer's responsibility to evaluate all embankments, meet all regulated requirements, and provide all necessary design measures to ensure the safety and stability of the design. All MDE Code 378 embankments must be approved by Harford Soil Conservation District. The designer must submit the MDE Embankment Flow Chart for each facility to demonstrate the design requirement category.

Table 14.1 - Common Embankment Requirements					
	ESD (<0.50 acres)*	Chapter 3 Pond	Excavated Ponds	Special Embankment	Code 378 (Class a)
Concrete Cradle / ASTM C-361	No	Yes	Yes	Yes	Yes
Cutoff Trench / Impervious Core	No	Engineer's Judgement	Engineer's Judgement	Engineer's Judgement	Yes
Seepage Control	No gravel under spillway pipe	No gravel under spillway pipe	No gravel under spillway pipe	Yes	Yes
Design Conveyance	10-yr	10-yr	100-yr	100-yr	100-yr
Freeboard above 10-yr WSE	6-inches minimum	12-inches minimum	See 100-yr	See 100-yr	See 100-yr
Freeboard above 100-yr WSE	No	No	2' without ES or 1' with ES	2' without ES or 1' with ES	2' without ES or 1' with ES
Dam Breach Analysis	No**	No**	No**	Yes	Yes

\*ESD facilities with drainage areas greater than 0.50 acres shall follow the Chp. 3 Pond criteria.

\*\*The designer must consider the downstream reach conditions and provide a basis for not providing a dam breach analysis (i.e., no structures downstream, downgrade conveyance, small storage volume, etc.) Should Harford County not agree with the screening level assessment, a dam breach analysis will be required.

**14. Use of “Site Area” or “Limit of Disturbance” to determine ESDv requirements.**

The area used for calculating existing percent impervious (%) corresponds to either the project's property boundary for a residential lot less than 1 acre or the Limit of Disturbance (LOD) for all other projects. For Redevelopment classifications, only the impervious area within the LOD is used to determine the Target ESDv. Refer to the Harford County ESDv Requirement guideline for detailed discussion on how to determine a projects ESDv requirements.

**15. Does Harford County allow Forest Conservation Area ESDv Credit?**

No, Harford County does not allow Forest Conservation Area ESDv Credit. Appendix E.1 – Formerly Chapter 5 prior to 2009 was not required and was intended to incentivize developers to use better site design methods. The credits in this chapter no longer apply. The only applicable technique related to Forest conservation is in the 2009 Chapter 5 N-3 Sheet flow to Conservation Areas. Using the entire property as the Site area and then subtracting out the conservation area for the ESDv requirement calculation is not acceptable.

**16. What rainfall data does Harford County use for design?**

The 24-hour design rainfall amounts for various frequencies for Harford County has been developed by NOAA Atlas 14. These values are based upon rainfall data developed by the National Oceanic and Atmospheric Administration Atlas 14 (NOAA 14). Revised rainfall distribution tables have been developed for three different regions of Maryland. These rainfall data and rainfall distributions have replaced data from Weather Bureau Technical Paper 40 (TP-40) and the standard NRCS rainfall distributions Type II, listed in the EFH on page 2-13. The old values shall no longer be used for design purposes.

The 24-hour design rainfall in the table below shall be used with the NOAA C distribution table.

<b>Harford County 24-hour rainfall duration values</b>							
<b>Storm</b>	<b>1-year</b>	<b>2-year</b>	<b>5-year</b>	<b>10-year</b>	<b>25-year</b>	<b>50-year</b>	<b>100-year</b>
<b>Unit</b>	<b>in.</b>	<b>in.</b>	<b>in.</b>	<b>in.</b>	<b>in.</b>	<b>in.</b>	<b>in.</b>
<b>Rainfall</b>	<b>2.69</b>	<b>3.26</b>	<b>4.19</b>	<b>5.00</b>	<b>6.25</b>	<b>7.34</b>	<b>8.58</b>

**17. Does Harford County have Guidelines and/or Requirements for Large Building Projects?**

The state mandates that WQv, Rev, and CPv are to be provided for projects that require SWM. The preparation of the Concept Stormwater Management will establish the Target treatment requirements based on the Limit of Disturbance and proposed impervious area. Chapter 5 facilities, appropriately spread out within the site, must be considered, and utilized for all the proposed development beyond the footprint of the large building (< 250,000 sf or about 5.75 ac).

Since the entire roof area will create a series of drainage areas that will exceed design limits of most Chapter 5 facilities, it is understood that the use of small-scale practices may be difficult or physically impossible to fully implement treatment for the roof areas. For Large Building Projects, the architectural plans for the roof area drainage and discharge piping locations are critical to the design and must be provided as part of the Concept Stormwater Management Plan submission.

The initial evaluation process for the treatment of the roof area needs to consider the use of Chapter 5 Submerged Gravel Wetlands (SGW) for treatment (HSG C and HSG D soils), since these facilities are allowed to have larger contributing drainage areas. The use of the SGW facilities will be in addition to the other Chapter 5 facilities that will be throughout the site. The SGW facilities are not “regional” facilities, nor are they intended to be used to meet Qp or Qf requirements.

Only after the evaluation and implementation of Chapter 5 practices has been exhausted and documented, Harford County will consider allowing a Stormwater Management Qualitative Control Waiver per § 214-28 C and D and submitted per § 214-28 G.

If Harford County determines that a Waiver can be approved, the Waiver will require the use of Chapter 3 F-6 Bioretention facilities to provide the treatment of the roof areas. As a condition for approving a qualitative control waiver, the following design items must be provided:

- a) The F-6 facilities are to treat roof drainage areas only.
- b) The maximum drainage area, including the F-6 facility, shall be less than five (5) acres.
- c) The F-6 facilities are not to be designed to meet Cpv, Qp, or Qf.
- d) The F-6 facility is to be off-line. A flow splitter device will be provided to divert the roof runoff for the water quality storm event to the facility, with the by-passing flow piped to the project's quantity control facility.
- e) The F-6 facility will be provided with an overflow designed for a 10-year storm and underdrain pipe system to an outfall location. The overflow must also be able to safely pass a 100-year storm.
- f) Since the facility is only treating roof drainage, a sediment forebay pretreatment basin will not be required, except that flow entering the facility will have suitable erosion protection to spread the flow into the facility.
- g) The Target ESDv shall be based on the drainage area to the facility.
- h) Surface ponding limited to a 12" maximum.
- i) A drop of at least 6" above the ponding elevation shall be provided at all inlets of the facility.
- j) The minimum "surface storage" below the overflow device shall be 75% of the Target ESDv.
- k) The ESDv provided (surface storage) shall not exceed the Maximum ESDv based on a  $Pe = 2.69$ .
- l) The typical bioretention filter bed will include the following:
  - i. Surface treatment: The 3" mulch layer should be 1-1/2" mulch layer with 1-1/2" light color stone layer on top to prevent mulch migration, per latest MDE landscape guidance.
  - ii. Filter bed: Media 2.5' to 4.0' deep (per Appendix B.3. Table B.3.2 Materials Specifications for Bioretention)
  - iii. Perforated underdrain (6" dia. min.) located in a gravel layer with 4" bedding and 2" pipe cover.
  - iv. Permeable filter fabric shall be placed between the gravel layer and the filter bed.
  - v.
- m) The F-6 facilities shall meet the same set-back requirements as micro-bioretention facilities.
- n) A landscaping plan shall be provided per the Maryland Stormwater Design Manual, except, no trees are allowed within the facility.
- o) The facility shall not be used for sediment control. The practice should not be constructed until the contributing drainage area is permanently stabilized. If this is not possible, the runoff from disturbed areas shall be diverted away and no sediment control practices shall be used near the proposed location. If site work requires that these facilities be constructed earlier in the sequence, then the E&S plans should consider other protections (e.g., covering the facilities with an impermeable liner.) Permanent stabilization shall be established over the contributing drainage area before runoff can be accepted into the facility.
- p) Construction and material specifications shall be in accordance with Appendix B-4 of the 2000 Maryland Stormwater Design Manual Volumes I & II, as amended unless specified above.

**Maintenance Schedules for all Ponds and BMPs must be provided on the Final Plans. See the following example:**

Note:  
Highlighted are  
additions/revisions  
made to the  
Maintenance  
Schedule

**POND MAINTENANCE SCHEDULE**

1. The facilities shall be inspected twice annually by the Owner (March & September) for the following:
  - A. Visual inspection of all components
  - B. Physical inspection of any movable parts, drain, valves, etc.
2. Vegetated cover shall be maintained by mowing, liming, and fertilizing. As a minimum requirement, lime and fertilization shall be applied one (1) time every two (2) years. No trees or woody vegetation shall be planted on nor allowed to grow within 15 feet of the toe of the embankment.
3. Grass on the dam and non-wetland portions of the pond shall be mowed anytime the grass is over twelve (12) inches tall.
4. All storm drain inflow points to be kept free of sediment, vegetation or debris that can form obstructions; from inflow point to control release structure.
5. As shown on the SWM Landscape Plan, plantings shall be inspected and maintained or replaced as necessary during facility maintenance.
6. Fences and gates shall be kept in good repair; remove vegetation collection/growth.
7. All required maintenance shall be performed by the Owner, the Owner's Representative, or Beneficial Users at the Owner's or Beneficial User's expense.
8. Rills on the slopes of the dam and washes in the earth spillway shall be filled with suitable material and thoroughly compacted. These areas shall be reseeded or resodded, limes, and fertilized as needed.
9. All appurtenances shall be kept free of trash.
10. Contact DPW-Stormwater Management (410) 638-3509, Ext. 2440 as soon as discovered, before any repair of the structure, pipe, or embankment.

---

**ROBERT G. CASSILLY**  
Harford County Executive

**ROBERT S. McCORD**  
Director of Administration



**JOSEPH J. SIEMEK, P.E.**  
Director of Public Works

---

**DEPARTMENT OF PUBLIC WORKS  
BUREAU OF STORMWATER MANAGEMENT**

**DATE:** April 30, 2025  
**FROM:** Division of Environment and Sustainability ~ Bureau of Stormwater Management  
**TO:** Harford County Engineering, Developer and Consultant Community  
**SUBJECT:** Stormwater Management Compliance Guidance – SWM Performance Bonds

Harford County Code Section 214-37.G specifies the conditions under which the performance bond for a stormwater management pond may be reduced to an amount not less than 50% of the approved estimated cost of construction. There has been recent discussion concerning how performance bonds may be reduced for other stormwater management systems, including natural areas, ESD practices, and other stormwater quality measures.

This memo clarifies the current process and provides guidance on how the process could be more efficient.

**Stormwater Management Ponds (Quantity)**

As stated in 214-37.G., SWM quantity ponds, once they are constructed and functioning as a sediment control device and there is an active grading permit is in force for the site, a partial as-built may be submitted. The partial as-built will be reviewed and if approved, the bond for the pond may be reduced up to 50% of the original cost of construction. Once the pond is converted to function as a final stormwater quantity management facility, the final as-built may be submitted and reviewed. Once the final as-built is approved in accordance with Code Section 214-39, the bond is reduced to 10% and the facility is put into the one-year maintenance phase.

**Stormwater ESD Practices (Quality)**

These devices are smaller in scope and have no interim sediment control condition or function, and there is not any 50% bond reduction component included in the Code. Once the ESD practices are completed and function as final stormwater quality management facilities, and there is an active grading permit is in force for the site, the final as-built may be submitted and reviewed. Once the final as-built is approved in accordance with Code Section 214-39, the bond is reduced to 10% and the facilities are put into the one-year maintenance phase.

*Harford County Celebrates 250 Years ~ 1773-2023*

## **Guidance on Stormwater Management Permit Application and Processing**

The stormwater quantity and quality devices included within a single stormwater management permit, as determined by the Engineer, can be as large, small, or numerous as the site conditions allow and the owner desires. Usually, drainage areas are considered and the design plans and the SWM Permit applications can include a SWM pond alone, a cluster of ESD devices, or a combination of both .

If the large ponds are tied to a permit with smaller ESDs, the pond and all ESDs tied to that permit must be completed and the as-built submitted and approved before any bonds may be reduced. Bonds are reduced only on individual permits and cannot be based on individual facility completion within a permit if it contains multiple facilities.

Defining SWM permit and bonding requirements strategically with the project phasing will allow the facilities included in each permit to be as-built and have the bond reduced to 10% as quickly as possible without the need to wait for the entire project to be completed.



## Plan Review Fiscal Counts For Fiscal Year 2025

TYPENAME	Count
Concept Plan Review	20
DPW - SWM Eng - Final Plan Review - Revisions	9
DPW - SWM Engineering - Final Plan Review	39
Site Development Plan Review	13

PLANNUMBER	DESCRIPTION	TYPENAME
SWMENG-000037-2024	508 Pulaski Highway in Aberdeen- Outdoor Storage	Concept Plan Review
SWMENG-000063-2025	Susquehanna Meadows Lot 11	Concept Plan Review
SWMENG-000084-2024	Emmorton Business Park SWM Pond Repair	Concept Plan Review
SWMENG-000095-2024	Boy Scouts of America Broad Creek Comfort Stations	Concept Plan Review
<del>SWMENG-000098-2025</del>	<del>Harford Mall Redevelopment Phase 3 (was Macy's)</del>	<del>Concept Plan Review</del>
SWMENG-000107-2024	Leeswood Garth SWM Pond Repair	Concept Plan Review
SWMENG-000173-2024	1438 Pulaski Highway; Site Address is 1438 South Philadelphia Boulevard	Concept Plan Review
SWMENG-000181-2024	Peverley Estates Additional Two Lots-Lot 2 and Lot 3	Concept Plan Review
SWMENG-000206-2024	Watts Meadow	Concept Plan Review
SWMENG-000210-2025	Harford County Highways Salt Barn Abingdon- H254508	Concept Plan Review
SWMENG-000225-2024	Oak Avenue Rubble Landfill Pond 2 Repair	Concept Plan Review
SWMENG-000244-2024	Bridge 013 Hookers Mill Road over Bynum Run Replacement- H204521	Concept Plan Review
SWMENG-000251-2024	Robert F. Kahoe Revise Lot 1 to Create Lots 7 & 8	Concept Plan Review
SWMENG-000287-2024	Rooted Bible Fellowship Church Barrell Replacement- SWM Repair- ARPA/G216579	Concept Plan Review
SWMENG-000394-2024	Greenbrier Hills Section 7 Barrel Replacement- pond repair	Concept Plan Review
SWMENG-000415-2024	Jones Junction Kia Service Center 2001 Bel Air Road Building Addition	Concept Plan Review
SWMENG-000460-2022	Trimble Hills- FKA Lands of Great Lands Lots 1-4 and Silver Coasts Lots 2 &	Concept Plan Review
SWMENG-000481-2024	Susquehanna Meadows Track One Lot 8 Only	Concept Plan Review

PLANNUMBER	DESCRIPTION	TYPENAME
SWMENG-000482-2024	Susquehanna Meadows Track One Lot 12 Only	Concept Plan Review
SWMENG-000485-2024	7 Brew Coffee at 2 Forest Valley Drive Road	Concept Plan Review
SWMENG-000501-2024	Zone 3 Elevated Water Tank- City of Aberdeen	Concept Plan Review
<del>SWMENG-000508-2024</del>	<del>102 N Bond Street</del>	<del>Concept Plan Review</del>
<del>SWMENG-000522-2022</del>	<del>Bel Air Town Center Taco Bell Replacement</del>	<del>Concept Plan Review</del>
SWMENG-000045-2021	Pevery Estates- residential Ownership Change	DPW - SWM Eng - Final Plan Review - Revisions
SWMENG-000268-2022	Ridgelys Reserve AKA Oak Grove Stancills- new owner	DPW - SWM Eng - Final Plan Review - Revisions
SWMENG-000280-2020	Old Trails- townhomes- microbioretention dry wells submerged gravel	DPW - SWM Eng - Final Plan Review - Revisions
SWMENG-000282-2024	Willow Oak FKA Steinbach Property Phase 1 Lots 1-5 and Phase 2 is the	DPW - SWM Eng - Final Plan Review - Revisions
SWMENG-000480-2020	Hackleys Reserve Ph 3, 4, 5 AKA Magnolia Landing- residential- ponds	DPW - SWM Eng - Final Plan Review - Revisions
SWMENG-000515-2020	LEMS Contracting Company Maintenance Building- commercial	DPW - SWM Eng - Final Plan Review - Revisions
SWMENG-000533-2018	Caine Ridge Resubdivision of Lot 6 to Create Lots 8-11 - single family- dry	DPW - SWM Eng - Final Plan Review - Revisions
SWMENG-000747-2016	Church Creek Elementary School SWM Improvements- convert existing pond	DPW - SWM Eng - Final Plan Review - Revisions
SWMENG-000760-2016	Hess Farm Lots 1-7 - single family - ponds rooftop disconnect non rooftop disconnect microbioretention bioswales and drywells	DPW - SWM Eng - Final Plan Review - Revisions
SWMENG-000045-2023	Otter Creek Landing Section 2 Phase 1- Pond Repair	DPW - SWM Engineering - Final Plan Review
SWMENG-000047-2024	Campus Hills Commercial SWM Pond Repair- behind Arena Club	DPW - SWM Engineering - Final Plan Review
SWMENG-000101-2023	Tall Oaks Manor Lots 9-12; single family	DPW - SWM Engineering - Final Plan Review
SWMENG-000102-2024	Forest Hill Business Center Lot 7- KO Storage; 11 Newport Drive	DPW - SWM Engineering - Final Plan Review
SWMENG-000106-2023	Mariner Point Park Stormwater Management Improvements	DPW - SWM Engineering - Final Plan Review
SWMENG-000115-2024	James Run Lot 3	DPW - SWM Engineering - Final Plan Review
SWMENG-000116-2024	James Run Lot 4A	DPW - SWM Engineering - Final Plan Review
SWMENG-000141-2023	Aberdeen Solar	DPW - SWM Engineering - Final Plan Review
SWMENG-000148-2021	Eng Property- 1210 Bush Road- 3 lot residential	DPW - SWM Engineering - Final Plan Review
SWMENG-000154-2022	Van Bibber Road Lots 1-3 AKA 1209 Van Bibber Road- single family	DPW - SWM Engineering - Final Plan Review
SWMENG-000158-2025	17 Rockdale Avenue; Deere Haven Lot 9	DPW - SWM Engineering - Final Plan Review
SWMENG-000161-2023	Harkins, W. Herbert and Patricia A Lots 18 & 19- single family	DPW - SWM Engineering - Final Plan Review
SWMENG-000168-2020	Highfields Section 2- lots 6-18 single family	DPW - SWM Engineering - Final Plan Review
SWMENG-000181-2024	Pevery Estates Additional Two Lots-Lot 2 and Lot 3	DPW - SWM Engineering - Final Plan Review
SWMENG-000185-2024	818 Pulaski Highway	DPW - SWM Engineering - Final Plan Review
SWMENG-000216-2021	Patterson Mill Professional Building	DPW - SWM Engineering - Final Plan Review
SWMENG-000228-2024	Hollywoods Area 4 Section 2 Lot 2 Pond 3	DPW - SWM Engineering - Final Plan Review
<del>SWMENG-000231-2023</del>	<del>Standard on Bond, The - mixed use development</del>	<del>DPW - SWM Engineering - Final Plan Review</del>
SWMENG-000251-2024	Robert F. Kahoe Revise Lot 1 to Create Lots 7 & 8	DPW - SWM Engineering - Final Plan Review
SWMENG-000254-2023	Carsins Reserve FKA 921 S Stepney Rd- residential	DPW - SWM Engineering - Final Plan Review
SWMENG-000265-2024	Ponderosa Estates SWM Pond Repeir	DPW - SWM Engineering - Final Plan Review
SWMENG-000287-2024	Rooted Bible Fellowship Church Barrell Replacement- SWM Repair-	DPW - SWM Engineering - Final Plan Review
SWMENG-000288-2025	North Bay Investments MD LLC FKA Joppa Marina	DPW - SWM Engineering - Final Plan Review

PLANNUMBER	DESCRIPTION	TYPENAME
SWMENG-000309-2021	Ivanhoe Street FKA Washington Court Access Road- H214506	DPW - SWM Engineering - Final Plan Review
SWMENG-000338-2024	Lauras Landing Stormwater Pond Repair	DPW - SWM Engineering - Final Plan Review
SWMENG-000342-2024	St. Clair Drive Stormwater Barrel Replacement	DPW - SWM Engineering - Final Plan Review
SWMENG-000363-2024	Thomas Run Station Stormwater Pond Outfall Barrel Replacement	DPW - SWM Engineering - Final Plan Review
SWMENG-000369-2023	Bridge 0140 Scarboro Road Bridge Replacement over Tributary & Deer	DPW - SWM Engineering - Final Plan Review
SWMENG-000394-2024	Greenbrier Hills Section 7 Barrel Replacement- pond repair	DPW - SWM Engineering - Final Plan Review
SWMENG-000413-2023	Hickory Park Athletic Fields Improvements-P084117	DPW - SWM Engineering - Final Plan Review
SWMENG-000432-2023	Repurpose Innovation Park FKA Harford Minerals - Fast Track	DPW - SWM Engineering - Final Plan Review
SWMENG-000460-2022	Trimble Hills- FKA Lands of Great Lands Lots 1-4 and Silver Coasts Lots 2 &	DPW - SWM Engineering - Final Plan Review
<del>SWMENG-000475-2022</del>	<del>Raising Canes - Bel Air</del>	<del>DPW - SWM Engineering - Final Plan Review</del>
SWMENG-000476-2022	Woodbridge Center Way SWM Pond Repair- G216579	DPW - SWM Engineering - Final Plan Review
SWMENG-000480-2024	Magnolia Road CSEGS Solar Panel Field - ownership change	DPW - SWM Engineering - Final Plan Review
SWMENG-000482-2022	Abingdon Fire Company- Riverside Station- E214106	DPW - SWM Engineering - Final Plan Review
SWMENG-000491-2016	Bridge 169 Abingdon Rd over CSX Replacement -microbioretention facility	DPW - SWM Engineering - Final Plan Review
SWMENG-000500-2024	Clayton Station Business Center Lot 5- 1300 Business Center Way;	DPW - SWM Engineering - Final Plan Review
SWMENG-000501-2024	Zone 3 Elevated Water Tank- City of Aberdeen	DPW - SWM Engineering - Final Plan Review
SWMENG-000506-2023	Churchville Solar	DPW - SWM Engineering - Final Plan Review
SWMENG-000593-2021	Woodley Road Extension- H204523	DPW - SWM Engineering - Final Plan Review
SWMENG-000043-2024	Enterprise Rent A Car; 1204 Pulaski Highway	Site Development Plan Review
SWMENG-000101-2024	Magnolia Road CSEGS Solar Panel Field aka Magnolia Road Parcels 11 &	Site Development Plan Review
SWMENG-000102-2024	Forest Hill Business Center Lot 7- KO Storage; 11 Newport Drive	Site Development Plan Review
SWMENG-000122-2024	Bel Air South Commercial P/O Lot 1 Chick fil A- was Bertucci's	Site Development Plan Review
SWMENG-000150-2024	Mt Zion Church Pipe Replacement	Site Development Plan Review
SWMENG-000173-2024	1438 Pulaski Highway; Site Address is 1438 South Philadelphia Boulevard	Site Development Plan Review
SWMENG-000189-2025	Creekside- FKA Pacas Meadows- residential Ownership Change	Site Development Plan Review
SWMENG-000219-2023	Frankie's Landing Lots 1-3	Site Development Plan Review
<del>SWMENG-000231-2023</del>	<del>Standard on Bond, The - mixed use development</del>	<del>Site Development Plan Review</del>
SWMENG-000254-2023	Carsins Reserve FKA 921 S Stepney Rd- residential	Site Development Plan Review
SWMENG-000341-2024	J. B. Hunt Transport Services Parking Lot Expansion	Site Development Plan Review
SWMENG-000401-2024	Loflin Marshalling Park- Commercial Vehicle and Towing Business	Site Development Plan Review
SWMENG-000430-2023	Magnolia 622 LLC Property	Site Development Plan Review
SWMENG-000535-2022	Clayton Station Business Center Lot 5- 1300 Business Center Way	Site Development Plan Review

**\*\*Note: Cells struckout are projects in the Town of Bel Air; Not included in our counts**



# Exemptions and Waivers Technical Memorandum

*Prepared for*

Harford County Department of Public Works  
Division of Construction Management, Watershed Protection, and Restoration Office  
212 S. Bond Street  
Bel Air, Maryland 21014

*Prepared by*

EA Engineering, Science, and Technology, Inc., PBC  
225 Schilling Circle, Suite 400  
Hunt Valley, Maryland 21031  
410-584-7000

October 2025  
Version: Final  
EA Project No. 16199-20



This page intentionally left blank



# Table of Contents

1.	Introduction and Background.....	5
1.1.	Purpose.....	6
2.	Recommended Exemptions and Waivers Process .....	7
2.1.	Storage.....	8
3.1.	Quality Assurance/Quality Control .....	9
3.	ArcGIS Pro Project .....	10
4.	Exemptions and Waivers Progress.....	10
	Appendix A: Exemptions.....	11
	Appendix B: Waivers .....	13



## List of Tables

Table 1. Exemptions_Points Feature Class Schema.....	8
Table 2. Waivers_Points Feature Class Schema .....	8
Table 3. Exemptions Waivers Types Domain Types .....	9

## List of Figures

Figure 1. Workflow diagram depicting how the waiver/exemption is added into the Watersheds.sde .....	7
---	---



## 1. Introduction and Background

Harford County (County) may receive requests for exemptions and/or waivers on sediment control and stormwater management plans for new development and redevelopment within the County. Exemptions and waivers are processed on a case-by-case basis by the Bureau of Stormwater Management based on their corresponding categories and are regulated under Chapter 214 of the Harford County Code. The Bureau of Stormwater Management will review the request and determine if it meets the guidelines for an exemption or waiver. An exemption allows for a land development activity to not be subjected to stormwater management, while a waiver is a reduction of stormwater management on an individual review basis. The following list of exemption and waiver categories includes those currently being tracked for compliance with the Municipal Separate Storm Sewer System (MS4) permit requirements.

### Exemption Categories (§ 214-27 B):

- (1) Agricultural land-management activities
- (2) Additions or modifications to existing single-family detached residential structures, provided Condition Number 3 below is met
- (3) Developments that do not disturb over 5,000 square feet of land area
- (4) Land-development activities which the Water Management Administration determines will be regulated under specific state laws, which provide for managing stormwater runoff
- Single residences on lots greater than 2 acres (under 1984 regulations and no longer available)

### Waiver Categories (§ 214-28 B and C):

- Less than 10 percent increase in runoff from the two-year storm event (1984 regulations and no longer available)
- Completely surrounded by existing storm drain (1984 regulations and no longer available)
- Have direct discharges to tidally influenced receiving waters
- No increase in runoff or impervious area (2000 regulations)
- Underground utilities are to be installed and the existing drainage patterns will not be changed and there is no increase in impervious area (2000 regulations)



Harford County Code §214-28 also includes other specific waivers for quantity and quality, not listed above, that are determined on a case-by-case basis.

## 1.1. Purpose

The County contracted EA Engineering, Science, and Technology, Inc., PBC (EA) to create geospatial data for waivers and exemptions in the “Waivers\_Points” and “Exemptions\_Points” feature classes.


The purpose of this Memorandum is to:

1. Document the current exemptions and waivers process
2. Document the exemptions and waivers recommended process
3. Detail the Feature Class Schema
4. Document Data Storage
5. Present Quality Assurance and Quality Control Process on Data
6. Detail the ArcGIS Pro Project Working Space
7. Document EA’s progress through 30 June 2025



## 2. Recommended Exemptions and Waivers Process

Exemptions and waivers requests are currently generated from a public request through email or postal mail. As part of the MS4 Annual Report, the Office of Watershed Protection and Restoration maps the approved waiver and exemption. The Bureau of Stormwater Management notifies the Office of Watershed Protection and Restoration via email of any waivers and exemptions. As illustrated in Figure 1, the workflow diagram, requests are sent to the Bureau of Stormwater Management for approval; exemptions and waivers can either be approved or not approved, which will determine if they will be entered into the geodatabase. If approved, a letter from the County will be sent to the requester notifying them of the approval. This letter must be included in the MS4 Annual Report. If the exemption or waiver is denied, a letter will be sent notifying the requester, but does not need to be included in the MS4 Annual Report and will not be added to the geodatabase or Laserfiche. The Bureau of Stormwater Management will scan the approval letter and any other documentation into Laserfiche and be organized in alphabetical order based on the site description.



**Figure 1. Workflow diagram depicting how the waiver/exemption is added into the Watersheds.sde**



EA creates a point for the approved exemption/waiver in the respective “Exemptions\_Points” or “Waivers\_Points” feature classes stored in the Watersheds.sde. The data stored in these feature classes are then submitted in the MS4 Annual Report.

## 2.1. Storage

The “Exemptions\_Points” and “Waivers\_Points” feature classes are stored in the Watersheds.sde, which is accessible on the County’s network. The feature classes will be edited in an ArcGIS Pro project. Table 1 defines the Exemptions\_Points feature class attributes for the exemptions. Table 2 defines the Waivers\_Points feature class attributes for the waivers.

**Table 1. Exemptions\_Points Feature Class Schema**

Attribute	Description	Data Type	Domains
ObjectID	Unique attribute auto populated	Object ID	
Feature	Feature Number manually created and populated	Text	
SWM_Number	Stormwater permit number if applicable	Text	
Site	Owner/Description of property	Text	
Location	Address of property	Text	
Submit_Date	Date of exemption submission	Date	
Approval_Date	Date of approval for exemption	Date	
Watershed_Number	DNR 12-digit watershed number	Text	
Type	Type of exemption that was approved	Text	dExemptions
Report	Reporting year of exemption	Text	
North	Central northing coordinate of the feature	Double	
East	Central easting coordinate of the feature	Double	
Shape	Required GIS attribute	Geometry	
Created_User	GIS tracking attribute	Text	
Created_Date	GIS tracking attribute	Date	
Last_Edited_User	GIS tracking attribute	Text	
Last_Edited_Date	GIS tracking attribute	Date	
GlobalID	Unique ID in geodatabase	Global ID	

**Table 2. Waivers\_Points Feature Class Schema**

Attribute	Description	Data Type	Domains
ObjectID	Unique attribute auto populated	Object ID	
Feature	Feature Number manually created and populated	Text	
SWM_Number	Stormwater permit number if applicable	Text	
Site	Owner/Description of property	Text	
Location	Address of property	Text	
Submit_Date	Date of waiver submission	Date	
Approval_Date	Date of approval for waiver	Date	
Watershed_Number	12-digit watershed number	Text	
Quantity	Quantitative waiver codes approved	Text	
Quality	Qualitative waiver codes approved	Text	
Report	Reporting year of waiver	Text	



Attribute	Description	Data Type	Domains
East	Central easting coordinate of the feature	Double	
North	Central northing coordinate of the feature	Double	
BldPermit	Building Permit Number	Text	
TaxID	Tax identification number for property that the exemption or waiver is on	Text	
Shape	Required GIS attribute	Geometry	
Created_User	GIS tracking attribute	Text	
Created_Date	GIS tracking attribute	Date	
Last_Edited_User	GIS tracking attribute	Text	
Last_Edited_Date	GIS tracking attribute	Date	
GlobalID	Unique ID in geodatabase	Global ID	

**Table 3. Exemptions Waivers Types Domain Types**

Code	Code Description	Notes
E1	Agricultural land management	Approved by Soil Conservation District
E2	Additions or modifications to existing single-family residences	
E3	Developments that disturb less than 5,000 square feet	Does not disturb over 5,000 square feet
E4	Land development activities regulated under specific state laws which provide management of stormwater runoff	For example, Maryland Department of the Environment issued permit for mining.
E5	Single residences on lots greater than 2 acres	Not applicable since 2005
W1	Less than 10 percent increase	No longer available
W2	Completely surrounded by existing storm drains	No longer available
W3	Provisions to control direct discharge to tidal waters	Only for quantity control
W4	No increase in impervious cover	
W5	Underground utilities are to be installed and the existing drainage patterns will not be changed and there is no increase in impervious area.	Linear utility project.

### 3.1. Quality Assurance/Quality Control

The quality assurance/quality control is conducted through manual review quality control checks. EA contacted the Bureau of Stormwater Management to confirm the correct number of exemptions/waivers approved in Fiscal Year (FY) 25. Ms. Edith Santiago confirmed that there was a total of 26 exemptions/waivers, 15 exemptions, and 11 waivers.

EA had the feature classes data reviewed by a Stormwater Engineer. Reviews of each exemption/waiver were completed to ensure that attributes entered in the feature classes were accurate. The Stormwater Engineer confirmed the exemption/waiver codes, SWM\_Number, site, location, submit date, and approval date were correct.



### 3. ArcGIS Pro Project

EA and the County have access to the editing ArcGIS Pro project “ExemptionsWaivers,” stored on the County’s watershed (J) drive <\\FS02\share02\DPW\dpwshare\WRE\19 Data\Exemptions and Waivers\ExemptionsWaivers.aprx>.

The ArcGIS Pro project has the layers below:

- Feature Classes:
  - Cadastral
  - ExemptionWaiver
  - 12 Digit Watersheds
  - Waivers\_Points
  - Exemptions\_Points
- Tables:
  - ExemptionsWaiversReviewed
- Imagery:
  - WM2023 (Basemap)

### 4. Exemptions and Waivers Progress

EA has created a total of 26 points for FY24:

- **Fifteen (15) exemption points** were created in the “Exemptions\_Points” feature class.
- **Eleven (11) waiver points** were created in the Waivers\_Points” feature class.

EA has updated the working geodatabase to the servers here:

<\\fs02\Share02\Share02\DPW\dpwshare\19 Data\Exemptions and Waivers\ExemptionsWaivers.gdb>



## Appendix A: Exemptions

FY25 Exemptions  
Harford County Stormwater Management Exemptions between 07/01/2024 and 06/30/2025

site	location	submit date	approval date	watershed	easting	northing	type	ID
Forest Hill Elementary School-Retriever Terrace	2407 Rocks Rd, Forest Hill, MD 21050	2024-10-08	2024-10-09	021202020325	1485309.998	699607.8317	Section 214-3.B(1)b Section 214-27B.(3)	EX438
Church Creek Elementary School Portable Classroom	4299 Church Creek Rd, Belcamp, MD 21017	2024-10-17	2025-01-03	021307011129	1524624.555	659896.8799	Section 214-3.B(1)b	EX440
Prospect Mill Elementary School Portable Classroom	101 Prospect Mill Rd, Bel Air, MD 21015	2024-10-17	2025-01-03	021202020323	1511516.525	689085.6729	Section 214-3.B(1)b	EX439
3911 Eaton Drive (Pole Barn)	3911 Eaton Drive	2024-10-08	2025-01-13	021202020327	1465485.264	719751.6378	Section 214-3.B(1)b Section 214-27B.(3)	EX441
7 Brew Coffee Shop at 2912 Emmorton Road	2912 Emmorton Road, Abingdon, MD 21009	2025-01-21	2025-02-11	021307041131	1506887.599	660748.5351	Section 214-27B.(3)	EX442
Millbrook Creek Sod Farm	Level Rd, Churchville MD 21028	2025-01-14	2025-04-07	021202020322	1535432.476	692961.8883	Section 214-27B.(1)	EX443
1813 Harford Road	1813 Harford Rd, Fallston, MD 21047	2025-03-19	2025-04-30	021307031132	1485227.546	669746.501	Section 214-27B.(3)	EX444
1254 Collier Lane	1254 Collier Ln, Belcamp, MD 21017	2025-03-21	2025-05-02	021307011129	1526399.354	658849.7387	Section 214-27B.(3)	EX447
Fallston High School-Outdoor Court Resurfacing Project	2301 Carrs Mill Rd, Fallston, MD 21047	2025-04-02	2025-05-02	021307031132	1478062.733	676599.3938	Section 214-3.B(1)b Section 214-27B.(3)	EX446
Magnolia Middle School-Outdoor Court Resurfacing Project	299 Fort Hoyle Rd, Joppatowne, MD 21085	2025-03-20	2025-05-02	021308010293	1501368.023	634543.1616	Section 214-3.B(1)b Section 214-27B.(3)	EX445
Harford Christian Modular Classroom	1736 WHITEFORD RD	2025-05-06	2025-06-10	021202050339	1515237.267	727200.5422	Section 214-27B.(3)	EX448
2713 Fallsmont Drive- Garage Construction	2713 Fallsmont Drive		2025-06-10	021308040298	1468181.617	674711.9838	Section 214-3.B(1)b Section 214-27B.(3)	EX449
617 Loring Ave.- House Construction	617 Loring Ave		2025-06-12	021307041131	1494822.839	688717.1159	Section 214-3.B(1)b Section 214-27B.(3)	EX450
Riverside Elementary School Portable Classroom	211 STILLMEADOW DRIVE JOPPA, MD 21085	5/30/2025	6/27/2025	021308010293	632315.6602	1499553.92	Section 214-27B.(3)	EX451
Walmart Online Pickup Delivery (Abingdon)	401 CONSTANT FRIENDSHIP BLVD JOPPA, MD 21009	5/20/2025	6/27/2025	021307021130	654903.8768	1505843.58	Section 214-27B.(3)	EX452

**Exemptions:**  
Section 214-3.B(1)b: (Last Amended April 19, 2010)  
Section 214-27B.(1): (Last Amended April 19, 2010)  
Section 214-27B.(3): (Last Amended April 19, 2010)



## Appendix B: Waivers

FY25 Waivers  
 Harford County Stormwater Management Waivers between 07/01/2024 and  
 06/30/2025

site	location	submit date	approval date	watershed	easting	northing	quantity	quality	ID
MLD (MLV 190D20 to Station 195) Dig 4750 Project	3006 WHITEFORD RD	2024-05-31	2024-07-03	021202050343	1482293.62	744408.7463	Section 214-28.B.(3)	Section 214-28.C.(3)	WA0846
Broad Creek Memorial Scout Reservation - Camp Saffron Comfort Stations	1929 SUSQUEHANNA HALL RD	2024-02-07	2024-07-11	021202050339	1517868.796	739975.0915	Section 214-28.B.(3)		WA0847
Lower Wheel Creek Stream Restoration Repairs	NORTH AND SOUTH SIDES OF WEST WHEEL ROAD	2024-06-04	2025-07-11	021307031132	1500118.694	663399.557	Section 214-28.B.(2) Section 214-28.H.(4)	Section 214-28.C.(1) Section 214-28.H.(4)	WA0852
Taylor Creek Stream Restoration	OFF FALCONER ROAD AND OFF SOURGHUM COURT	2024-06-04	2024-07-11	021308010293	1495199.563	638687.278	Section 214-28.B.(2) Section 214-28.H.(4)	Section 214-28.C.(1) Section 214-28.H.(4)	WA0848
Anita C. Leight Estuary Center Stream Restoration	700 Otter Point Rd, Abingdon, MD 21009	2024-12-30	2025-03-26	021307011127	1518134.827	651345.8744	Section 214-28.B.(2)	Section 214-28.C.(1)	WA0850
Glenwood Sewer Petition	Donegal Rd and Duncannon Rd	2024-06-28	2025-02-07	021307041131	1504229.658	674266.1612	Section 214-28.B.(3)		WA0849
North Reardon Stream Restoration	1702 TRIMBLE ROAD		2025-06-12	021308010293	1503508.197	637663.0212	Section 214-28.B.(2)	Section 214-28.C.(1)	WA0851
Melrose Lane Sewer Replacement	MELROSE LANE	2025-06-28	2025-06-30	021307041131	1491191.869	693101.672	Section 214-28.B.(3)	Section 214-28.C.(3)	WA0855
Edgewood Village Stream Restoration	EDGEWATER DR	2025-04-29	2025-06-30	021307021130	1504949.191	642193.576	Section 214-28.B.(2)(c)	Section 214-28.C.(1)(c)	WA0854
Simons Run Stream Restoration and Wetland Mitigation Project	PYLE RD	2025-05-23	2025-06-30	021202020325	1491680.367	711486.654	Section 214-28.B.(2)(c)	Section 214-28.C.(1)(c)	WA0853
Culvert Replacement at Tollgate over Tributary of Winters Run	TOLLGATE RD	2025-04-18	2025-06-13	021307031132	1486439.255	679109.976	Section 214-28.B.(2)(a)	Section 214-28.C.(2)(a)	WA0856

**Waivers:**  
 Section 214-28 B.(1-4): (Last Amended April 19, 2010)  
 Section 214-28 B. (2)(a): (Last Amended April 19, 2010)  
 Section 214-28 B. (2)(c): (Last Amended April 19, 2010)  
 Section 214-28 C.(1,3): (Last Amended April 19, 2010)  
 Section 214-28 C. (2)(a): (Last Amended April 19, 2010)  
 Section 214-28 C. (2)(c): (Last Amended April 19, 2010)  
 Section 214-28 H.(4): (Last Amended April 19, 2010)

**NOTE:**  
Highlighted Text -  
stormwater inspections

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
7/1/2024	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
7/1/2024	2611 CHESTNUT HILL RD	Residential	Pre-Con	SW
7/1/2024	1609 HEIMS LN	Residential	Complaint	SC
7/1/2024	1934 PLEASANTVILLE RD	Residential	Pre-Inspection	SC
7/1/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
7/1/2024	2205 JACK LN	Residential	Maintenance	SC
7/1/2024	1812 WALTON RD	Commercial	Maintenance	SC
7/1/2024	0 NUTTAL AVE	Capital Project	Maintenance	SC
7/1/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
7/1/2024	2509 MOUNTAIN RD	Residential	Reinspection	SC
7/1/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
7/1/2024	728 BALTIMORE PIK	Commercial	As-Built	SW
7/1/2024	0 NUTTAL AVE		Maintenance	SW
7/2/2024	1915 EDEN MILL RD	Residential	Final	SC
7/2/2024	611 MAHAN RD	Residential	Maintenance	SC
7/2/2024	0 DONNAWOOD RD	Residential	Complaint	SC
7/2/2024	319 COOLEY MILL RD	Residential	Maintenance	SC
7/2/2024	854 STANSBURY RD	Residential	Maintenance	SC
7/2/2024	615 SCHUCKS RD	Subdivision	Maintenance	SC
7/2/2024	3839 ALDINO RD	Commercial	Maintenance	SC
7/2/2024	3064 WHITEFORD RD	Residential	Maintenance	SC
7/2/2024	0 Van Bibber	Commercial	Maintenance	SC
7/2/2024	301 FOUNTAIN GREEN RD	Subdivision	Maintenance	SC
7/2/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
7/2/2024	617 MAHAN RD	Residential	Maintenance	SC
7/2/2024	2559 SHURES LANDING RD	Commercial	As-Built	SW
7/3/2024	2013 PACKARD DR	Residential	Maintenance	SC
7/3/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
7/3/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
7/3/2024	509 CHERRY HILL RD	Residential	Maintenance	SC
7/3/2024	2589 MEDICAL HALL RD	Residential - Single	Construction	SW
7/3/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
7/3/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
7/3/2024	2014 PACKARD DR	Residential	Maintenance	SC
7/3/2024	1406 Mandeville RD	Residential	Maintenance	SC
7/3/2024	3026 SNAKE LN	Residential	Maintenance	SC
7/3/2024	208 KENNARD AVE	Residential	Complaint	SC
7/3/2024	101 CHERRY HILL RD	Commercial	Maintenance	SC
7/3/2024	0 HANSON RD	Subdivision	Maintenance	SC
7/5/2024	2000 CALVARY RD	Commercial		SC
7/5/2024	2817 FALLSTON RD	Residential	Maintenance	SC
7/5/2024	4998 JOLLY ACRES RD	Residential	Maintenance	SC
7/5/2024	2239 ENGLE RD	Residential	Maintenance	SC
7/5/2024	2822 CHARLES ST	Residential	Maintenance	SC
7/5/2024	517 STRATFORD RD			SC
7/5/2024	3219 WHITE HALL RD	Residential	Maintenance	SC
7/5/2024	2830 HARFORD RD	Residential		SC
7/5/2024	3118 CHARLES ST	Residential	Maintenance	SC
7/8/2024	2551 UREY RD	Residential	Complaint	SC
7/8/2024	1225 BUSH RD	Residential	Maintenance	SC
7/8/2024	2014 EMMORTON RD	Subdivision	Reinspection	SC
7/8/2024	2309 SNOW RD	Residential	Maintenance	SC
7/8/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
7/8/2024	928 Fenario RD	Residential	Maintenance	SC
7/8/2024	2551 UREY RD	Residential	Complaint	SC
7/8/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
7/8/2024	338 EARLTON RD	Residential	Maintenance	SC
7/8/2024	3538 ALDINO RD	Commercial	Maintenance	SC
7/8/2024	2215 CRESWELL RD	Institutional	Reinspection	SC
7/8/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
7/8/2024	2110 BEL AIR RD	Commercial	Construction	SW
7/8/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
7/8/2024	5129 FAWN GROVE RD	Residential	Pre-Con	SW
7/8/2024	0 PURPLE PL	Subdivision	Maintenance	SC
7/8/2024	0 YEARLING DR	Subdivision	Maintenance	SC
7/8/2024	2315 BEL AIR RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<b>Start Date</b>	<b>Address</b>	<b>Property Type</b>	<b>Purpose</b>	<b>Type</b>
7/8/2024	3839 ALDINO RD	Commercial	As-Built	SW
7/9/2024	1623 SHADY TREE CT	Subdivision	Reinspection	SC
7/9/2024	1934 PLEASANTVILLE RD	Residential	Installation	SC
7/9/2024	417-A Calvary RD	Residential	Pre-Inspection	SC
7/9/2024	2013 PACKARD DR	Residential	Reinspection	SC
7/9/2024	417-A Calvary RD	Residential - Single	Pre-Con	SW
7/9/2024	2300 EDWARDS LN	Residential	Maintenance	SC
7/9/2024	303 SEAR CT	Subdivision	Maintenance	SC
7/9/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
7/9/2024	3505 Berkley RD	Forested	Complaint	SC
7/9/2024	2551 UREY RD			SC
7/10/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
7/10/2024	1203 TECHNOLOGY DR	Commercial		SC
7/10/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
7/10/2024	1203 TECHNOLOGY DR	Commercial	Pre-Con	SW
7/10/2024	1924 PLEASANTVILLE RD	Residential	Construction	SW
7/10/2024	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
7/10/2024	1405 BERWICK CT	Residential	Maintenance	SW
7/10/2024	1430 QUAKER CHURCH RD			SC
7/10/2024	0 TECHNOLOGY DR	Commercial	Pre-Con	SW
7/10/2024	3064 WHITEFORD RD	Residential	Maintenance	SC
7/10/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
7/10/2024	10 MC GREGOR WAY	Residential	Reinspection	SC
7/11/2024	401 THOMAS RUN RD	Institutional	Maintenance	SC
7/11/2024	1702 MOONRIVER CT	Subdivision	Maintenance	SC
7/11/2024	0 ARDEN DR	Subdivision	Maintenance	SC
7/11/2024	3144 OLD YORK RD			SC
7/11/2024	608 PHILADELPHIA RD	Commercial	Pre-Con	SW
7/11/2024	504 RECKORD RD	Residential - Single	Maintenance	SW
7/11/2024	1702 MOONRIVER CT	Subdivision	Maintenance	SC
7/11/2024	0 Van Bibber	Commercial	Maintenance	SC
7/11/2024	1657 Robin CIR	Commercial	Maintenance	SC
7/11/2024	504 RECKORD RD	Residential	Final	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
7/11/2024	0 HANSON RD	Subdivision	Maintenance	SC
7/11/2024	608 PHILADELPHIA RD	Commercial	Pre-Inspection	SC
7/12/2024	301 PROSPECT MILL RD	Residential		SC
7/12/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
7/12/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
7/12/2024	2246 GIBSON RD	Residential	Maintenance	SC
7/12/2024	215 KENNARD AVE	Residential	Maintenance	SC
7/12/2024	928 Fenario CIR		As-Built	SW
7/12/2024	320 RECKORD RD	Residential		SW
7/12/2024	604 SUGAR HILL RD	Residential	Pre-Inspection	SC
7/12/2024	0 Surf Scoter LA	Subdivision	Maintenance	SC
7/12/2024	300 PULASKI HWY	Commercial	Maintenance	SC
7/12/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
7/12/2024	2509 MOUNTAIN RD	Residential	Reinspection	SC
7/12/2024	209 KENNARD AVE	Residential		SC
7/12/2024	509 CHERRY HILL RD	Residential	Maintenance	SC
7/12/2024	320 RECKORD RD	Residential	Maintenance	SC
7/12/2024	0 NUTTAL AVE		As-Built	SW
7/15/2024	3416 NOVA SCOTIA RD	Residential	Final	SC
7/15/2024	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
7/15/2024	Inspection Number: 040097-2024	Capital Project	Pre-Inspection	SC
7/15/2024	2013 PACKARD DR	Residential	Reinspection	SC
7/15/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
7/15/2024	601 CARSINS RUN RD	Forested	Maintenance	SC
7/15/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SW
7/15/2024	3505 Berkley RD	Forested		SC
7/15/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
7/15/2024	2205 JACK LN	Residential	Maintenance	SC
7/15/2024	611 MAHAN RD	Residential - Single		SW
7/15/2024	2420 WHITEFORD RD		Request As-Built	SW
7/15/2024	608 HENDERSON RD	Residential	Maintenance	SW
7/16/2024	119 HOPEWELL RD	Residential - Single	Pre-Con	SW
7/16/2024	781 PRIESTFORD RD	Residential	Pre-Con	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
7/16/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
7/16/2024	604 SUGAR HILL RD	Residential	Maintenance	SC
7/16/2024	331 MARINA AVE	Residential	Maintenance	SC
7/16/2024	617 MAHAN RD	Residential	Maintenance	SC
7/16/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
7/16/2024	0 Van Bibber	Commercial	Reinspection	SC
7/16/2024	1903 MITCHELL DR	Residential		SC
7/16/2024	2315 BEL AIR RD	Commercial	Maintenance	SC
7/16/2024	905 HENDERSON RD	Residential	Installation	SC
7/16/2024	119 HOPEWELL RD	Residential	Pre-Inspection	SC
7/16/2024	2208 CONNOLLY RD	Commercial	Maintenance	SC
7/16/2024	208 KENNARD AVE	Residential	Complaint	SC
7/16/2024	3839 ALDINO RD	Commercial	Maintenance	SC
7/16/2024	611 MAHAN RD	Residential	Maintenance	SC
7/16/2024	604 SUGAR HILL RD	Residential - Single	Pre-Con	SW
7/16/2024	781 PRIESTFORD RD	Residential	Pre-Inspection	SC
7/16/2024	1111 VALE RD	Residential	Pre-Inspection	SC
7/16/2024	408 Constant Friendship BLVD	Commercial	As-Built	SW
7/16/2024	1809 FALLSTON RD		Maintenance	SW
7/17/2024	854 STANSBURY RD	Residential	Maintenance	SC
7/17/2024	509 CHERRY HILL RD	Residential	Maintenance	SC
7/17/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
7/17/2024	1111 VALE RD	Residential	Pre-Con	SW
7/17/2024	741 HOOKERS MILL RD	Residential	Complaint	SC
7/17/2024	1406 MANDEVILLE RD	Residential - Single	Maintenance	SW
7/17/2024	1406 Mandeville RD	Residential	Maintenance	SC
7/17/2024	101 CHERRY HILL RD	Commercial	Maintenance	SC
7/17/2024	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
7/17/2024	904 EDGEWOOD RD	Commercial	Maintenance	SW
7/17/2024	711 PHILADELPHIA RD	Commercial	Complaint	SC
7/17/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
7/17/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
7/17/2024	2300 EDWARDS LN	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
7/18/2024	0 MANTLEWOOD WAY	Subdivision	Maintenance	SC
7/18/2024	1915 FOUNTAIN GREEN RD	Commercial	Pre-Inspection	SC
7/18/2024	1915 FOUNTAIN GREEN RD	Commercial	Pre-Con	SW
7/18/2024	354 OLD BAY LN	Commercial		SC
7/18/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC
7/18/2024	3205 SUDATH LN	Residential	Maintenance	SC
7/18/2024	4624 MERCEDES DR	Commercial	Maintenance	SC
7/18/2024	115 Magnolia Rd	Forested	Complaint	SC
7/18/2024	1812 WALTON RD	Commercial	Maintenance	SC
7/18/2024	1525 PHILADELPHIA BLVD	Commercial	Maintenance	SC
7/18/2024	1035 JOPPA RD	Commercial	Complaint	SC
7/18/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
7/18/2024	2014 PACKARD DR	Residential	Maintenance	SC
7/18/2024	2248 GIBSON RD	Residential	Maintenance	SC
7/19/2024	1702 MOONRIVER CT	Subdivision	Maintenance	SC
7/19/2024	2509 MOUNTAIN RD	Residential	Reinspection	SC
7/19/2024	0 CEDAR DR	Commercial	Maintenance	SC
7/19/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
7/19/2024	604 SUGAR HILL RD	Residential	Reinspection	SC
7/19/2024	208 KENNARD AVE	Residential	Complaint	SC
7/19/2024	0 WHEEL RD			SW
7/19/2024	3219 WHITE HALL RD	Residential	Final	SC
7/19/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC
7/19/2024	1526 QUARRY RD		Maintenance	SW
7/22/2024	905 HENDERSON RD	Residential	Maintenance	SC
7/22/2024	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
7/22/2024	615 SCHUCKS RD	Subdivision	Maintenance	SC
7/22/2024	0 YEARLING DR	Subdivision	Maintenance	SC
7/22/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
7/22/2024	0 NUTTAL AVE	Capital Project	Maintenance	SC
7/22/2024	2019 FAIRLANE RD	Residential	Complaint	SC
7/22/2024	615 SCHUCKS RD	Residential	Construction	SW
7/22/2024	1623 SHADY TREE CT	Subdivision	Reinspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<b>Start Date</b>	<b>Address</b>	<b>Property Type</b>	<b>Purpose</b>	<b>Type</b>
7/22/2024	0 VAN BIBBER RD		Pre-Con	SW
7/22/2024	119 HOPEWELL RD	Residential	Installation	SC
7/22/2024	2205 JACK LN			SW
7/22/2024	100 THOMAS RUN RD	Institutional	Maintenance	SC
7/22/2024	0 VAN BIBBER RD	Commercial	Pre-Inspection	SC
7/22/2024	3026 SNAKE LN	Residential		SC
7/22/2024	338 EARLTON RD	Residential		SC
7/22/2024	4625 JOLLY ACRES RD	Residential	Request As-Built	SW
7/22/2024	0 PURPLE PL	Subdivision	Maintenance	SC
7/22/2024	3538 ALDINO RD	Commercial	Maintenance	SC
7/22/2024	1691 LAUREL BROOK RD	Residential	Request As-Built	SW
7/23/2024	Inspection Number: ESCCI-032160-2024	Commercial		SC
7/23/2024	0 VAN BIBBER RD		Conversion	SW
7/23/2024	1111 VALE RD	Residential	Maintenance	SC
7/23/2024	2209 APOLLO TER		Reinspection	SC
7/23/2024	2315 BEL AIR RD	Commercial	Maintenance	SC
7/23/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC
7/23/2024	0 Van Bibber	Commercial	Final	SC
7/23/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
7/23/2024	2651 PEERY DR	Residential	Conversion	SW
7/23/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SW
7/23/2024	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
7/23/2024	301 FOUNTAIN GREEN RD	Subdivision	Maintenance	SC
7/23/2024	1307 GOVERNOR CT	Commercial	Maintenance	SW
7/23/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
7/23/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
7/23/2024	2029 CONNOLLY RD	Residential	Maintenance	SW
7/23/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
7/23/2024	3010 RECKORD RD	Residential	Maintenance	SC
7/23/2024	2014 PACKARD DR	Residential	Maintenance	SC
7/23/2024	0 Van Bibber	Commercial		SC
7/23/2024	1603 EVA AVE		Complaint	SC
7/23/2024	2208 CONNOLLY RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
7/23/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
7/23/2024	319 COOLEY MILL RD	Residential		SC
7/23/2024	2113 NUTTAL AVE	Subdivision	Pre-Inspection	SC
7/23/2024	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
7/23/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
7/23/2024	320 RECKORD RD	Residential	Maintenance	SC
7/23/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
7/23/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
7/23/2024	0 ARDEN DR	Subdivision	Maintenance	SC
7/23/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC
7/23/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
7/23/2024	2013 PACKARD DR	Residential	Maintenance	SC
7/23/2024	0 HANSON RD	Subdivision	Maintenance	SC
7/23/2024	607-E DEMBYTOWN RD	Residential	Pre-Inspection	SC
7/23/2024	607-E DEMBYTOWN RD	Residential - Single	Pre-Con	SW
7/23/2024	2113 NUTTAL AVE	Residential	Pre-Con	SW
7/24/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
7/24/2024	3118 CHARLES ST	Residential	Request As-Built	SW
7/24/2024	2301 Carrs Mill RD	Commercial	Maintenance	SC
7/24/2024	4805 PHILADELPHIA RD	Commercial	Maintenance	SC
7/24/2024	417-A Calvary RD	Residential	Installation	SC
7/24/2024	2019 FAIRLANE RD	Residential	Final	SC
7/24/2024	2600 TOBIN CROSSING	Commercial	Construction	SW
7/25/2024	928 Fenario RD	Residential	Maintenance	SC
7/25/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
7/25/2024	1623 SHADY TREE CT	Subdivision	Reinspection	SC
7/25/2024	2000 CALVARY RD	Commercial	Maintenance	SC
7/25/2024	0 CHELSEA RD	Commercial	Maintenance	SC
7/25/2024	2300 EDWARDS LN	Residential	Maintenance	SC
7/25/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
7/25/2024	2013 SCHUSTER RD	Residential	Maintenance	SC
7/25/2024	2014 EMMORTON RD	Subdivision	Reinspection	SC
7/25/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
7/25/2024	2600 TOBIN CROSSING	Commercial		SC
7/25/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
7/25/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
7/25/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
7/25/2024	2205 JACK LN	Residential	Maintenance	SC
7/25/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
7/25/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
7/25/2024	303 SEAR CT	Subdivision	Maintenance	SC
7/26/2024	300 PULASKI HWY	Commercial	Maintenance	SC
7/26/2024	2013 SCHUSTER RD	Residential	Maintenance	SC
7/26/2024	509 CHERRY HILL RD	Residential		SC
7/26/2024	208 KENNARD AVE	Residential		SC
7/26/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
7/26/2024	0 Surf Scoter LA	Subdivision	Maintenance	SC
7/26/2024	604 SUGAR HILL RD	Residential	Reinspection	SC
7/28/2024	3064 WHITEFORD RD	Residential	Maintenance	SC
7/29/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
7/29/2024	2309 SNOW RD	Residential	Maintenance	SC
7/29/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
7/29/2024	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
7/29/2024	215 KENNARD AVE		Maintenance	SW
7/29/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
7/29/2024	1408 THOMAS RUN RD	Residential	Pre-Inspection	SC
7/29/2024	215 KENNARD AVE	Residential	Maintenance	SC
7/29/2024	2025 CASTLETON RD	Residential	Maintenance	SC
7/29/2024	3144 OLD YORK RD	Residential	Pre-Inspection	SC
7/29/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
7/29/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SW
7/29/2024	555 Joppa Farm RD		Maintenance	SW
7/29/2024	3541 PROSPECT RD		Maintenance	SW
7/30/2024	1225 BUSH RD	Residential	Maintenance	SC
7/30/2024	3416 NOVA SCOTIA RD	Residential - Single	Final	SW
7/30/2024	0 GRAVEL HILL RD		Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
7/30/2024	2239 ENGLE RD	Residential	Approval	SC
7/30/2024	1205 MAIN ST	Residential	Maintenance	SC
7/30/2024	2818 OLD JOPPA RD	Residential	Maintenance	SC
7/30/2024	1526 OLD TOWER RD	Residential - Single	Final	SW
7/30/2024	2822 CHARLES ST	Residential	Maintenance	SC
7/30/2024	0 WHEEL RD	Residential	Maintenance	SW
7/31/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
7/31/2024	401 THOMAS RUN RD	Institutional	Maintenance	SC
7/31/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
7/31/2024	1525 PHILADELPHIA BLVD	Commercial	Maintenance	SC
7/31/2024	2301 Carrs Mill RD	Commercial	Maintenance	SC
7/31/2024	1903 MITCHELL DR	Residential		SC
7/31/2024	5129 FAWN GROVE RD	Residential	Maintenance	SW
7/31/2024	7 LOCUST RD	Residential	Maintenance	SC
7/31/2024	3205 SUDATH LN	Residential	Maintenance	SC
7/31/2024	331 MARINA AVE	Residential	Maintenance	SC
7/31/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC
7/31/2024	1501 PERRYMAN RD	Commercial	Maintenance	SC
7/31/2024	100 THOMAS RUN RD	Institutional	Maintenance	SC
7/31/2024	408 Constant Friendship BLVD	Commercial	As-Built	SW
7/31/2024	3022 CHURCHVILLE RD		Maintenance	SW
7/31/2024	2600 TOBIN CROSSING		Maintenance	SW
8/1/2024	611 MAHAN RD	Residential	Maintenance	SC
8/1/2024	3314 ABINGDON RD	Commercial	Pre-Inspection	SC
8/1/2024	0 MANTLEWOOD WAY	Subdivision	Maintenance	SC
8/1/2024	3314 ABINGDON RD	Commercial	Pre-Con	SW
8/1/2024	4624 MERCEDES DR	Commercial	Maintenance	SC
8/1/2024	617 MAHAN RD	Residential	Maintenance	SC
8/1/2024	3839 ALDINO RD	Commercial	Maintenance	SC
8/1/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/1/2024	0 HANSON RD	Subdivision	Maintenance	SC
8/2/2024	354 OLD BAY LN	Commercial	Maintenance	SC
8/2/2024	3116 TUCKER RD	Residential	Approval	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
8/2/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
8/2/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
8/2/2024	1603 EVA AVE			SC
8/2/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
8/2/2024	2000 CALVARY RD	Commercial	Reinspection	SC
8/2/2024	1406 MANDEVILLE RD	Residential - Single	Request As-Built	SW
8/2/2024	1406 Mandeville RD	Residential	Maintenance	SC
8/2/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
8/2/2024	100 THOMAS RUN RD	Institutional	Maintenance	SC
8/2/2024	607-E DEMBYTOWN RD	Residential	Maintenance	SC
8/2/2024	781 PRIESTFORD RD	Residential	Installation	SC
8/2/2024	3010 RECKORD RD	Residential		SC
8/2/2024	904 EDGEWOOD RD	Commercial	Maintenance	SW
8/2/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/2/2024	0 GRAVEL HILL RD	Commercial	Maintenance	SC
8/2/2024	303 SEAR CT	Subdivision	Reinspection	SC
8/2/2024	1609 HEIMS LN	Residential	Reinspection	SC
8/2/2024	2651 PEERY DR	Residential	As-Built	SW
8/3/2024	1408 THOMAS RUN RD	Residential	Maintenance	SC
8/5/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/5/2024	119 HOPEWELL RD	Residential	Maintenance	SC
8/5/2024	301 FOUNTAIN GREEN RD	Subdivision	Maintenance	SC
8/5/2024	2205 JACK LN	Residential	Maintenance	SC
8/5/2024	3026 SNAKE LN	Residential	Maintenance	SC
8/5/2024	0 YEARLING DR	Subdivision	Maintenance	SC
8/5/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
8/5/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
8/5/2024	0 PURPLE PL	Subdivision	Maintenance	SC
8/5/2024	2301 Carrs Mill RD	Commercial	Final	SC
8/5/2024	2911 VERBENA DR	Capital Project	Reinspection	SC
8/5/2024	3538 ALDINO RD	Commercial	Maintenance	SC
8/5/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
8/5/2024	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
8/5/2024	1121 DEER CREEK CHURCH RD	Residential	Approval	SC
8/5/2024	664 Trimble RD	Subdivision	Complaint	SC
8/5/2024	0 HANSON RD	Subdivision	Maintenance	SC
8/6/2024	2110 BEL AIR RD	Commercial		SW
8/6/2024	1111 VALE RD	Residential	Maintenance	SC
8/6/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
8/6/2024	781 PRIESTFORD RD	Residential	Maintenance	SC
8/6/2024	320 RECKORD RD	Residential	Maintenance	SC
8/6/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/6/2024	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
8/6/2024	905 HENDERSON RD	Residential	Maintenance	SC
8/6/2024	2246 GIBSON RD	Residential	Maintenance	SC
8/6/2024	104 MOONLIGHT DR	Subdivision	Maintenance	SC
8/6/2024	4998 JOLLY ACRES RD	Residential	Maintenance	SC
8/6/2024	319 COOLEY MILL RD	Residential	Maintenance	SC
8/6/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
8/6/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
8/7/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
8/7/2024	1225 BUSH RD	Residential	Maintenance	SC
8/7/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/7/2024	2014 EMMORTON RD	Subdivision	Reinspection	SC
8/7/2024	4805 PHILADELPHIA RD	Commercial	Maintenance	SC
8/7/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
8/7/2024	2300 EDWARDS LN	Residential	Maintenance	SC
8/7/2024	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
8/7/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
8/7/2024	417-A Calvary RD	Residential	Maintenance	SC
8/8/2024	1812 WALTON RD	Commercial	Maintenance	SC
8/8/2024	1405 BERWICK CT	Residential		SW
8/8/2024	300 PULASKI HWY	Commercial	Maintenance	SC
8/8/2024	0 CEDAR DR	Commercial	Maintenance	SC
8/8/2024	100 THOMAS RUN RD	Institutional	Maintenance	SC
8/8/2024	0 CHELSEA RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
8/8/2024	2025 CASTLETON RD	Residential	Maintenance	SC
8/8/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/8/2024	2551 UREY RD	Residential	Complaint	SC
8/8/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
8/8/2024	2600 TOBIN CROSSING	Commercial	Maintenance	SC
8/8/2024	1015 PULASKI HWY	Commercial	Maintenance	SC
8/8/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
8/9/2024	1205 MAIN ST	Residential	Maintenance	SC
8/9/2024	611 MAHAN RD	Residential	Maintenance	SC
8/9/2024	2704 ADY RD	Residential	Maintenance	SC
8/9/2024	3144 OLD YORK RD	Residential	Maintenance	SC
8/9/2024	607-E DEMBYTOWN RD	Residential	Maintenance	SC
8/9/2024	1725 O'CONNER RD	Residential	Maintenance	SC
8/9/2024	0 HACKLEY DR	Subdivision	Maintenance	SC
8/9/2024	604 SUGAR HILL RD	Residential	Reinspection	SC
8/9/2024	416 SUNNY VIEW RD	Residential	Complaint	SC
8/9/2024	3144 OLD YORK RD	Residential	Maintenance	SC
8/9/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
8/9/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/9/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC
8/12/2024	2013 SCHUSTER RD	Residential	Maintenance	SC
8/12/2024	330 ENFIELD RD	Subdivision	Maintenance	SC
8/12/2024	330 ENFIELD RD	Residential	Maintenance	SW
8/12/2024	2011 SCHUSTER RD	Residential	Maintenance	SC
8/12/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/12/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
8/12/2024	338 EARLTON RD	Residential	Maintenance	SC
8/12/2024	2013 SCHUSTER RD	Residential	Pre-Inspection	SC
8/12/2024	1127 Belcamp Garth	Capital Project	Pre-Inspection	SC
8/12/2024	Inspection Number: 040106-2024	Capital Project	Maintenance	SC
8/12/2024	1127 Belcamp Garth	Capital Project	Pre-Con	SW
8/12/2024	2551 UREY RD	Residential	Complaint	SC
8/12/2024	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
8/12/2024	3205 SUDATH LN	Residential	Maintenance	SC
8/12/2024	401 THOMAS RUN RD	Institutional	Maintenance	SC
8/12/2024	4370 NORRISVILLE RD	Residential	Maintenance	SC
8/12/2024	0 HYSSOP CT		Complaint	SW
8/12/2024	0 SHINGLE OAK CT		Maintenance	SW
8/13/2024	1603 BULLS LN	Residential	Pre-Inspection	SC
8/13/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SW
8/13/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/13/2024	2508 PALMER VIEW DR	Residential	Maintenance	SC
8/13/2024	1408 THOMAS RUN RD	Residential	Maintenance	SC
8/13/2024	2315 BEL AIR RD	Commercial	Maintenance	SC
8/13/2024	2208 CONNOLLY RD	Commercial	Maintenance	SC
8/13/2024	0 LAUREL BUSH RD	Residential	Maintenance	SC
8/13/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
8/13/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
8/13/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
8/14/2024	1903 MITCHELL DR	Residential	Maintenance	SC
8/14/2024	3205 SUDATH LN	Residential	Maintenance	SW
8/14/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
8/14/2024	3064 WHITEFORD RD	Residential	Final	SC
8/14/2024	331 MARINA AVE	Residential	Maintenance	SC
8/14/2024	1410 THOMAS RUN RD	Residential	Approval	SC
8/14/2024	0 Whiteford and Rocks RD	Commercial	Approval	SC
8/14/2024	1615 INGLESIDE RD	Residential	Approval	SC
8/14/2024	1525 PHILADELPHIA BLVD	Commercial	Maintenance	SC
8/14/2024	416 SUNNY VIEW RD	Residential	Final	SC
8/14/2024	320 RECKORD RD	Residential	Final	SC
8/14/2024	0 HANSON RD	Subdivision	Maintenance	SC
8/15/2024	0 JOPPA FARM RD	Subdivision	Reinspection	SC
8/15/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/15/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
8/15/2024	928 Fenario RD	Residential	Maintenance	SC
8/15/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
8/15/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
8/15/2024	0 MANTLEWOOD WAY	Subdivision	Maintenance	SC
8/15/2024	3839 ALDINO RD	Commercial	Maintenance	SC
8/15/2024	617 MAHAN RD	Residential	Maintenance	SC
8/15/2024	4624 MERCEDES DR	Commercial	Maintenance	SC
8/15/2024	2421 HARKINS RD			SC
8/15/2024	608 HENDERSON RD	Residential	Complaint	SW
8/15/2024	555 Joppa Farm RD		Maintenance	SW
8/15/2024	1806 EDGEWOOD RD		Maintenance	SW
8/16/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC
8/16/2024	905 HENDERSON RD	Residential	Maintenance	SC
8/16/2024	4998 JOLLY ACRES RD	Residential	Maintenance	SC
8/16/2024	1406 MANDEVILLE RD	Residential	Maintenance	SC
8/16/2024	1929 SUSQUEHANNA HALL RD	Commercial		SC
8/16/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
8/16/2024	2014 PACKARD DR	Residential	Maintenance	SC
8/16/2024	4370 NORRISVILLE RD	Residential	Maintenance	SC
8/16/2024	2301 Carrs Mill RD	Commercial	Final	SC
8/16/2024	4370 NORRISVILLE RD	Residential	Maintenance	SC
8/16/2024	781 PRIESTFORD RD	Residential	Maintenance	SC
8/16/2024	2013 PACKARD DR	Residential	Approval	SC
8/16/2024	2000 CALVARY RD	Commercial	Maintenance	SC
8/16/2024	354 OLD BAY LN	Commercial	Maintenance	SC
8/16/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
8/16/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/16/2024	1714 RIDGE RD	Residential	Approval	SC
8/16/2024	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
8/17/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/19/2024	3116 TUCKER RD	Residential	Maintenance	SC
8/19/2024	1166 RIDGE RD	Forested	Maintenance	SC
8/19/2024	2300 EDWARDS LN	Residential	Maintenance	SC
8/19/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/19/2024	3507 NORTH FURNACE RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
8/19/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
8/19/2024	2009 E CHURCHVILLE RD		Maintenance	SW
8/19/2024	Bynum Road at Water Tower Way		Maintenance	SW
8/19/2024	1725 JARRETTSVILLE RD		Maintenance	SW
8/20/2024	401 THOMAS RUN RD	Institutional	Maintenance	SC
8/20/2024	215 KENNARD AVE	Residential	Maintenance	SC
8/20/2024	615 SCHUCKS RD	Subdivision	Maintenance	SC
8/20/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/20/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
8/20/2024	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
8/20/2024	2113 NUTTAL AVE	Subdivision	Maintenance	SC
8/20/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
8/20/2024	2720 ADY RD	Residential	Approval	SC
8/20/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
8/20/2024	0 PURPLE PL	Subdivision	Maintenance	SC
8/20/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
8/20/2024	1408 THOMAS RUN RD	Residential	Maintenance	SC
8/20/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
8/20/2024	2309 SNOW RD	Residential	Maintenance	SC
8/20/2024	2011 SCHUSTER RD	Residential	Request As-Built	SW
8/20/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
8/20/2024	2205 JACK LN	Residential	Maintenance	SC
8/20/2024	2421 HARKINS RD	Residential	Approval	SC
8/20/2024	4625 JOLLY ACRES RD	Residential		SW
8/21/2024	1615 INGLESIDE RD	Residential	Maintenance	SC
8/21/2024	1225 BUSH RD	Residential	Maintenance	SC
8/21/2024	1373 TRAPPE RD	Residential	Maintenance	SC
8/21/2024	1121 DEER CREEK CHURCH RD	Residential - Single	Pre-Con	SW
8/21/2024	2010 MOUNTAIN RD	Commercial	Complaint	SC
8/21/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/21/2024	711 PHILADELPHIA RD	Commercial	Complaint	SC
8/21/2024	1373 TRAPPE RD	Residential - Single	Pre-Con	SW
8/21/2024	3205 SUDATH LN	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
8/21/2024	100 THOMAS RUN RD	Institutional	Maintenance	SC
8/21/2024	1408 THOMAS RUN RD	Residential - Single	Pre-Con	SW
8/21/2024	3144 OLD YORK RD	Residential	Maintenance	SC
8/21/2024	1410 THOMAS RUN RD	Residential	Pre-Con	SW
8/21/2024	2011 SCHUSTER RD	Residential	Final	SC
8/21/2024	0 UP AND OVER LN		Maintenance	SW
8/21/2024	1107 UP AND OVER LN		Maintenance	SW
8/21/2024	0 BENTGRASS DR		Maintenance	SW
8/21/2024	Inspection Number: 048105-2023		Maintenance	SW
8/22/2024	2626 TALL OAKS DR	Subdivision	Approval	SC
8/22/2024	1410 THOMAS RUN RD	Residential	Maintenance	SC
8/22/2024	300 PULASKI HWY	Commercial	Maintenance	SC
8/22/2024	0 NUTTAL AVE	Capital Project	Maintenance	SC
8/22/2024	3118 CHARLES ST			SC
8/22/2024	2204 ARDEN DR	Residential	Complaint	SC
8/22/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
8/22/2024	3118 CHARLES ST	Residential	Request As-Built	SW
8/22/2024	1615 INGLESIDE RD	Residential	Pre-Con	SW
8/22/2024	3118 CHARLES ST			SC
8/22/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/22/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
8/22/2024	3118 CHARLES ST			SC
8/22/2024	0 HANSON RD	Subdivision	Maintenance	SC
8/23/2024	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
8/23/2024	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
8/23/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
8/23/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/23/2024	3144 OLD YORK RD	Residential	Maintenance	SC
8/23/2024	607-E DEMBYTOWN RD	Residential	Maintenance	SC
8/23/2024	2704 ADY RD	Residential	Maintenance	SC
8/23/2024	0 Whiteford and Rocks RD	Commercial	Maintenance	SC
8/23/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
8/23/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
8/23/2024	2013 PACKARD DR	Residential	Maintenance	SC
8/23/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
8/23/2024	2014 PACKARD DR	Residential	Maintenance	SC
8/23/2024	3314 ABINGDON RD	Commercial	Installation	SC
8/23/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC
8/23/2024	664 Trimble RD	Subdivision	Complaint	SC
8/23/2024	728 BALTIMORE PIK	Commercial	As-Built	SW
8/24/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/26/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/26/2024	303 SEAR CT	Subdivision	Maintenance	SC
8/26/2024	928 Fenario RD	Residential	Maintenance	SC
8/26/2024	320 RECKORD RD	Residential		SC
8/26/2024	2300 EDWARDS LN	Residential	Maintenance	SC
8/26/2024	Yearling Drive @ Webster Lapidum Road	Residential	Construction	SW
8/27/2024	1603 BULLS LN	Residential	Maintenance	SC
8/27/2024	2720 ADY RD	Residential	Maintenance	SC
8/27/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
8/27/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/27/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
8/27/2024	301 FOUNTAIN GREEN RD	Subdivision	Maintenance	SC
8/27/2024	741 HOOKERS MILL RD	Residential	Complaint	SC
8/27/2024	2208 CONNOLLY RD	Commercial	Maintenance	SC
8/27/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
8/27/2024	2720 ADY RD	Residential - Single	Pre-Con	SW
8/28/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SW
8/28/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
8/28/2024	2025 CASTLETON RD	Residential	Maintenance	SW
8/28/2024	2688 COMPROMISE ST	Commercial	Pre-Con	SW
8/28/2024	2205 JACK LN	Residential	Maintenance	SW
8/28/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/28/2024	2697 COMPROMISE ST	Commercial	Pre-Con	SW
8/28/2024	1035 JOPPA RD	Commercial	Complaint	SC
8/28/2024	1526 OLD TOWER RD	Residential - Single		SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
8/28/2024	2720 ADY RD	Residential	Maintenance	SC
8/28/2024	2704 ADY RD	Residential - Single	Request As-Built	SW
8/28/2024	2246 GIBSON RD	Residential	Maintenance	SW
8/28/2024	3881 ROCKS STATION RD	Institutional	Complaint	SC
8/28/2024	1111 VALE RD	Residential	Maintenance	SC
8/28/2024	2013 SCHUSTER RD	Residential	Maintenance	SC
8/28/2024	3144 OLD YORK RD	Residential	Maintenance	SC
8/28/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
8/28/2024	0 WHEEL RD	Residential	Request As-Built	SW
8/29/2024	854 STANSBURY RD	Residential	Maintenance	SC
8/29/2024	0 INCLINE CT	Residential		SW
8/29/2024	2509 PORT LN	Subdivision	Installation	SC
8/29/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/29/2024	0 MAGNOLIA RD	Forested	Complaint	SC
8/29/2024	Inspection Number: 041495-2024	Capital Project	Maintenance	SC
8/29/2024	3205 SUDATH LN	Residential	Maintenance	SC
8/29/2024	2303 CARRS MILL RD	Capital Project	Pre-Con	SW
8/29/2024	607-E DEMBYTOWN RD	Residential	Reinspection	SC
8/29/2024	0 CARRS MILL RD	Capital Project	Pre-Inspection	SC
8/29/2024	1373 TRAPPE RD	Residential	Maintenance	SC
8/29/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
8/29/2024	1609 HEIMS LN	Residential	Complaint	SC
8/29/2024	0 HANSON RD	Subdivision	Maintenance	SC
8/29/2024	664 Trimble RD	Subdivision	Complaint	SC
8/30/2024	904 EDGEWOOD RD	Commercial	Maintenance	SW
8/30/2024	1812 WALTON RD	Commercial	Maintenance	SW
8/30/2024	2551 UREY RD	Residential	Reinspection	SC
8/30/2024	781 PRIESTFORD RD	Residential	Maintenance	SC
8/30/2024	0 SHINGLE OAK CT	Residential	Pre-Con	SW
8/30/2024	1812 WALTON RD	Commercial	Maintenance	SC
8/30/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
8/30/2024	3116 TUCKER RD	Residential	Maintenance	SC
8/30/2024	4370 NORRISVILLE RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
8/30/2024	1501 PERRYMAN RD	Commercial	Maintenance	SC
8/30/2024	2704 ADY RD	Residential - Single	Maintenance	SW
8/30/2024	0 SHINGLE OAK CT	Residential	Pre-Con	SW
8/30/2024	904 EDGEWOOD RD	Commercial	Maintenance	SW
8/30/2024	0 SHINGLE OAK CT	Residential	Pre-Inspection	SC
8/30/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
8/30/2024	1405 BERWICK CT	Residential	Request As-Built	SW
8/30/2024	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
8/30/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
8/30/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
8/30/2024	1714 RIDGE RD	Residential	Maintenance	SC
8/30/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
8/30/2024	0 Surf Scoter LA	Subdivision	Maintenance	SC
8/30/2024	905 HENDERSON RD	Residential	Maintenance	SC
9/2/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/2/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
9/2/2024	119 HOPEWELL RD	Residential	Maintenance	SC
9/3/2024	4805 PHILADELPHIA RD	Commercial	Final	SC
9/3/2024	104 MOONLIGHT DR	Subdivision	Maintenance	SC
9/3/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
9/3/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/3/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
9/3/2024	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
9/3/2024	417-A Calvary RD	Residential	Maintenance	SC
9/3/2024	3507 NORTH FURNACE RD	Residential - Single	As-Built	SW
9/3/2024	2421 HARKINS RD	Residential	Maintenance	SC
9/3/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC
9/3/2024	2315 BEL AIR RD	Commercial	Maintenance	SC
9/3/2024	0 LAUREL BUSH RD	Residential	Maintenance	SC
9/3/2024	0 CHELSEA RD	Commercial	Maintenance	SC
9/3/2024	1406 MANDEVILLE RD	Residential	Maintenance	SC
9/3/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
9/3/2024	1406 MANDEVILLE RD	Residential - Single	Request As-Built	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
9/3/2024	1525 PHILADELPHIA BLVD	Commercial	Maintenance	SC
9/4/2024	215 KENNARD AVE	Residential	Maintenance	SC
9/4/2024	2113 NUTTAL AVE	Subdivision	Maintenance	SC
9/4/2024	3026 SNAKE LN	Residential	Maintenance	SC
9/4/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/4/2024	300 PULASKI HWY	Commercial	Maintenance	SC
9/4/2024	Inspection Number: 057763-2023		Maintenance	SW
9/4/2024	0 SELVIN DR C22		Maintenance	SW
9/5/2024	1903 MITCHELL DR	Residential	Maintenance	SC
9/5/2024	1166 RIDGE RD	Forested	Maintenance	SC
9/5/2024	0 PURPLE PL	Subdivision	Maintenance	SC
9/5/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/5/2024	1035 JOPPA RD	Commercial	Maintenance	SC
9/5/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
9/5/2024	2025 CASTLETON RD	Residential	Maintenance	SC
9/5/2024	617 MAHAN RD	Residential	Maintenance	SC
9/5/2024	611 MAHAN RD	Residential	Final	SC
9/5/2024	2309 SNOW RD	Residential	Maintenance	SC
9/5/2024	331 MARINA AVE	Residential	Maintenance	SC
9/5/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
9/5/2024	4147 CONOWINGO RD	Residential - Single	Maintenance	SW
9/5/2024	2626 TALL OAKS DR	Subdivision	Maintenance	SC
9/5/2024	2822 CHARLES ST	Residential	Maintenance	SC
9/5/2024	0 HANSON RD	Subdivision	Maintenance	SC
9/6/2024	34 MC DERMOTT RD	Residential - Single	Pre-Con	SW
9/6/2024	2208 CONNOLLY RD	Commercial		SC
9/6/2024	1225 BUSH RD	Residential	Maintenance	SC
9/6/2024	2600 TOBIN CROSSING	Commercial	Maintenance	SC
9/6/2024	2708 Belair Rd. S Belair Rd. E 2708	Commercial		SC
9/6/2024	Belair Rd. 2020 PACKARD DR	Subdivision	Maintenance	SC
9/6/2024	2421 HARKINS RD	Residential - Single	Pre-Con	SW
9/6/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
9/6/2024	2013 PACKARD DR	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
9/6/2024	1203 TECHNOLOGY DR	Commercial	Installation	SC
9/6/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC
9/6/2024	1307 GOVERNOR CT	Commercial	Maintenance	SW
9/6/2024	1827 BALDWIN MILL RD	Residential - Single	Construction	SW
9/6/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC
9/6/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/6/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
9/6/2024	2551 UREY RD	Residential	Reinspection	SC
9/6/2024	3314 ABINGDON RD	Commercial	Maintenance	SC
9/6/2024	2014 PACKARD DR	Residential	Maintenance	SC
9/6/2024	2013 SCHUSTER RD	Residential	Maintenance	SC
9/6/2024	34 MC DERMOTT RD	Residential	Maintenance	SC
9/6/2024	1615 INGLESIDE RD	Residential	Maintenance	SC
9/6/2024	3881 ROCKS STATION RD	Institutional	Final	SC
9/7/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/9/2024	2205 JACK LN	Residential	Maintenance	SC
9/9/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/9/2024	0 YEARLING DR	Subdivision	Maintenance	SC
9/9/2024	3839 ALDINO RD	Commercial	Final	SC
9/9/2024	3538 ALDINO RD	Commercial	Maintenance	SC
9/9/2024	319 COOLEY MILL RD	Residential	Maintenance	SC
9/9/2024	928 Fenario RD	Residential	Maintenance	SC
9/9/2024	1111 VALE RD	Residential	Maintenance	SC
9/9/2024	0 GRAVEL HILL RD	Commercial	Maintenance	SC
9/9/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
9/9/2024	2300 EDWARDS LN	Residential	Maintenance	SC
9/9/2024	409 C TRIMBLE RD	Residential	As-Built	SW
9/10/2024	301 FOUNTAIN GREEN RD	Subdivision	Maintenance	SC
9/10/2024	1714 RIDGE RD	Residential	Pre-Con	SW
9/10/2024	330 ENFIELD RD	Subdivision	Maintenance	SC
9/10/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
9/10/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/10/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
9/10/2024	904 EDGEWOOD RD	Commercial	Maintenance	SW
9/10/2024	1605 ALGONQUIN CT	Residential - Single	Pre-Con	SW
9/10/2024	0 GRAVEL HILL RD		Maintenance	SC
9/10/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
9/10/2024	617 MAHAN RD	Residential	Maintenance	SC
9/10/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
9/10/2024	1605 ALGONQUIN CT	Residential	Pre-Inspection	SC
9/11/2024	604 SUGAR HILL RD	Residential	Maintenance	SC
9/11/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
9/11/2024	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
9/11/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
9/11/2024	0 CEDAR DR	Commercial	Maintenance	SW
9/11/2024	0 CEDAR DR	Commercial	Maintenance	SC
9/11/2024	2818 OLD JOPPA RD	Residential	Final	SC
9/11/2024	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
9/11/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/11/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
9/11/2024	2000 CALVARY RD	Commercial	Reinspection	SC
9/11/2024	4624 MERCEDES DR	Commercial	Maintenance	SC
9/11/2024	2589 MEDICAL HALL RD	Residential - Single	Construction	SW
9/11/2024	2589 MEDICAL HALL RD	Residential	Maintenance	SC
9/11/2024	16 ROCKDALE AVE	Residential - Single	Construction	SW
9/11/2024	0 GLEN COVE RD		Maintenance	SW
9/11/2024	2215 CHURCHVILLE RD		Maintenance	SW
9/11/2024	0 CHELSEA RD	Commercial	Maintenance	SC
9/12/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
9/12/2024	0 SHINGLE OAK CT	Residential	Installation	SC
9/12/2024	401 THOMAS RUN RD	Government / Institutional	Maintenance	SW
9/12/2024	2246 GIBSON RD	Residential	Maintenance	SC
9/12/2024	2409 HARFORD RD	Residential	Maintenance	SW
9/12/2024	2509 PORT LN	Subdivision	Maintenance	SC
9/12/2024	4147 CONOWINGO RD	Residential	Approval	SC
9/12/2024	100 THOMAS RUN RD	Institutional	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
9/12/2024	1373 TRAPPE RD	Residential - Single	Maintenance	SW
9/12/2024	1408 THOMAS RUN RD	Residential - Single	Maintenance	SW
9/12/2024	2246 GIBSON RD	Residential	Maintenance	SW
9/12/2024	401 THOMAS RUN RD	Institutional	Maintenance	SC
9/12/2024	1408 THOMAS RUN RD	Residential	Maintenance	SC
9/12/2024	104 MOONLIGHT DR	Subdivision	Maintenance	SC
9/12/2024	1373 TRAPPE RD	Residential	Maintenance	SC
9/12/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
9/12/2024	1657 Robin CIR	Commercial	Maintenance	SC
9/12/2024	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
9/12/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/12/2024	1812 WALTON RD	Commercial	Maintenance	SC
9/12/2024	1410 THOMAS RUN RD	Residential	Maintenance	SW
9/12/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
9/12/2024	1410 THOMAS RUN RD	Residential	Maintenance	SC
9/12/2024	4147 CONOWINGO RD	Residential - Single	Request As-Built	SW
9/12/2024	0 MANTLEWOOD WAY	Subdivision	Maintenance	SC
9/12/2024	928 Fenario RD	Residential	Reinspection	SC
9/12/2024	100 THOMAS RUN RD	Institutional	Maintenance	SC
9/12/2024	4299 CHURCH CREEK RD	Government / Institutional	As-Built	SW
9/12/2024	555 Joppa Farm RD		Maintenance	SW
9/12/2024	2201 BEL AIR RD	Commercial	As-Built	SW
9/12/2024	2899 STRASBAUGH DR	Commercial	As-Built	SW
9/13/2024	1015 PULASKI HWY	Commercial	Maintenance	SC
9/13/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/13/2024	2013 PACKARD DR	Residential	Maintenance	SC
9/13/2024	2014 PACKARD DR	Residential	Maintenance	SC
9/13/2024	0 ARDEN DR	Subdivision	Maintenance	SC
9/13/2024	Inspection Number: 044829-2024	Capital Project	Maintenance	SC
9/13/2024	0 NUTTAL AVE	Capital Project	Maintenance	SC
9/13/2024	0 HANSON RD	Subdivision	Maintenance	SC
9/14/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/16/2024	1127 Belcamp Garth	Capital Project	Pre-Inspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
9/16/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
9/16/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
9/16/2024	1603 BULLS LN	Residential	Maintenance	SC
9/16/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/16/2024	2899 STRASBAUGH DR	Commercial	As-Built	SW
9/17/2024	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
9/17/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
9/17/2024	1605 ALGONQUIN CT	Residential	Maintenance	SC
9/17/2024	607-E DEMBYTOWN RD	Residential	Maintenance	SC
9/17/2024	354 OLD BAY LN	Commercial	Maintenance	SC
9/17/2024	3333 JAMES RUN RD	Residential	Reinspection	SC
9/17/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC
9/17/2024	2209 APOLLO TER			SC
9/17/2024	0 CARRS MILL RD	Capital Project	Pre-Inspection	SC
9/17/2024	1702 MOONRIVER CT	Subdivision	Maintenance	SC
9/17/2024	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
9/17/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/17/2024	905 HENDERSON RD	Residential	Maintenance	SC
9/17/2024	Inspection Number: ESCCI-036746-2024	Commercial	Reinspection	SC
9/18/2024	3747 FEDERAL HILL RD	Commercial		SC
9/18/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
9/18/2024	119 HOPEWELL RD	Residential	Maintenance	SC
9/18/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
9/18/2024	1903 MITCHELL DR	Residential	Maintenance	SC
9/18/2024	2011 SCHUSTER RD	Residential		SW
9/18/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
9/18/2024	7 LOCUST RD	Residential	Maintenance	SC
9/18/2024	2013 PACKARD DR	Residential	Reinspection	SC
9/18/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
9/18/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/18/2024	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
9/18/2024	0 HANSON RD		Pre-Inspection	SC
9/18/2024	331 MARINA AVE	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<b><i>Start Date</i></b>	<b><i>Address</i></b>	<b><i>Property Type</i></b>	<b><i>Purpose</i></b>	<b><i>Type</i></b>
9/18/2024	3747 FEDERAL HILL RD	Commercial	Complaint	SC
9/19/2024	2025 CASTLETON RD	Residential	Maintenance	SW
9/19/2024	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
9/19/2024	5129 FAWN GROVE RD	Residential	Maintenance	SW
9/19/2024	2000 CALVARY RD	Commercial	Maintenance	SC
9/19/2024	215 KENNARD AVE	Residential	Maintenance	SC
9/19/2024	3026 SNAKE LN	Residential	Maintenance	SC
9/19/2024	417-A Calvary RD	Residential	Maintenance	SC
9/19/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
9/19/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC
9/19/2024	2626 TALL OAKS DR	Subdivision	Maintenance	SC
9/19/2024	2113 NUTTAL AVE	Subdivision	Maintenance	SC
9/19/2024	0 CONNOLLY RD	Subdivision	Reinspection	SC
9/19/2024	300 PULASKI HWY	Commercial	Maintenance	SC
9/19/2024	2309 SNOW RD	Residential	Maintenance	SC
9/19/2024	2248 GIBSON RD	Residential - Single	Maintenance	SW
9/19/2024	North of MD Rt 7 West of Burnt Hill	Subdivision	Reinspection	SC
9/19/2024	Trail 2704 ADY RD	Residential	Maintenance	SC
9/19/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/19/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
9/19/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
9/19/2024	664 Trimble RD	Subdivision	Complaint	SC
9/19/2024	0 HANSON RD	Subdivision	Maintenance	SC
9/20/2024	2014 PACKARD DR	Residential	Maintenance	SC
9/20/2024	2421 HARKINS RD	Residential	Maintenance	SC
9/20/2024	611 MAHAN RD	Residential - Single	Request As-Built	SW
9/20/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
9/20/2024	3118 CHARLES ST	Residential		SW
9/20/2024	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
9/20/2024	0 Surf Scoter LA	Subdivision	Maintenance	SC
9/20/2024	1525 PHILADELPHIA BLVD	Commercial	Maintenance	SC
9/20/2024	0 PURPLE PL	Subdivision	Maintenance	SC
9/20/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
9/20/2024	3144 OLD YORK RD	Residential	Maintenance	SC
9/20/2024	34 MC DERMOTT RD	Residential	Maintenance	SC
9/20/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC
9/20/2024	3839 ALDINO RD	Commercial		SC
9/20/2024	0 LAUREL BUSH RD	Residential	Maintenance	SC
9/20/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/20/2024	2818 OLD JOPPA RD	Residential		SC
9/20/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
9/20/2024	1615 INGLESIDE RD	Residential	Maintenance	SW
9/23/2024	0 YEARLING DR	Subdivision	Maintenance	SC
9/23/2024	2013 PACKARD DR	Residential	Reinspection	SC
9/23/2024	2300 EDWARDS LN	Residential	Maintenance	SC
9/23/2024	1410 THOMAS RUN RD	Residential	Maintenance	SC
9/23/2024	1319 PERRYMAN RD	Commercial	Pre-Inspection	SC
9/23/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/23/2024	3314 ABINGDON RD	Commercial	Maintenance	SC
9/23/2024	2205 JACK LN	Residential	Maintenance	SC
9/23/2024	903 OLD PYLESVILLE RD			SC
9/23/2024	North of MD Rt 7 West of Burnt Hill	Subdivision	Reinspection	SC
9/23/2024	Trail 3538 ALDINO RD	Commercial	Maintenance	SC
9/23/2024	1225 BUSH RD	Residential	Maintenance	SC
9/23/2024	4147 CONOWINGO RD	Residential - Single	As-Built	SW
9/23/2024	1373 TRAPPE RD	Residential	Approval	SC
9/23/2024	800 W Jarrettsville RD	Residential	Maintenance	SW
9/23/2024	711 PHILADELPHIA RD	Commercial	Complaint	SC
9/23/2024	1408 THOMAS RUN RD	Residential	Maintenance	SC
9/23/2024	1111 VALE RD	Residential	Maintenance	SC
9/23/2024	319 COOLEY MILL RD	Residential	Maintenance	SC
9/23/2024	1127 Belcamp Garth	Capital Project	Pre-Inspection	SC
9/23/2024	3010 RECKORD RD	Residential	Maintenance	SC
9/24/2024	1609 HEIMS LN	Residential	Complaint	SC
9/24/2024	904 EDGEWOOD RD	Commercial	Maintenance	SW
9/24/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
9/24/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
9/24/2024	2809 BELCAMP RD	Residential - Single	Pre-Con	SW
9/24/2024	781 PRIESTFORD RD	Residential	Maintenance	SC
9/24/2024	5640 LONG CORNER RD	Residential	Pre-Inspection	SC
9/24/2024	1714 RIDGE RD	Residential	Maintenance	SC
9/24/2024	5640 LONG CORNER RD	Residential - Single	Pre-Con	SW
9/24/2024	330 ENFIELD RD	Subdivision	Maintenance	SC
9/24/2024	2010 MOUNTAIN RD	Commercial	Complaint	SC
9/24/2024	104 MOONLIGHT DR	Subdivision	Maintenance	SC
9/24/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/24/2024	2025 CASTLETON RD	Residential	Maintenance	SC
9/24/2024	617 MAHAN RD	Residential	Maintenance	SC
9/24/2024	0 GRAVEL HILL RD		Final	SC
9/24/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
9/24/2024	301 FOUNTAIN GREEN RD	Subdivision	Final	SC
9/24/2024	1107 UP AND OVER LN		Maintenance	SW
9/24/2024	0 BENTGRASS DR		Maintenance	SW
9/24/2024	0 UP AND OVER LN		Maintenance	SW
9/24/2024	Inspection Number: 049559-2024		Maintenance	SW
9/24/2024	4299 CHURCH CREEK RD	Government / Institutional	As-Built	SW
9/25/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SW
9/25/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/25/2024	1035 JOPPA RD	Commercial	Complaint	SC
9/25/2024	4624 MERCEDES DR	Commercial	Maintenance	SC
9/25/2024	0 CHELSEA RD	Commercial	Maintenance	SC
9/25/2024	2720 ADY RD	Residential - Single	Maintenance	SW
9/25/2024	1406 MANDEVILLE RD	Residential	Maintenance	SC
9/25/2024	2626 TALL OAKS DR	Subdivision	Complaint	SC
9/25/2024	3205 SUDATH LN	Residential	Request As-Built	SW
9/25/2024	1691 LAUREL BROOK RD		As-Built	SW
9/26/2024	1605 ALGONQUIN CT	Residential	Maintenance	SC
9/26/2024	2589 MEDICAL HALL RD	Residential	Maintenance	SC
9/26/2024	0 CONNOLLY RD	Subdivision	Reinspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
9/26/2024	928 Fenario RD	Residential	Maintenance	SC
9/26/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/26/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
9/26/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/26/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
9/26/2024	0 SHINGLE OAK CT	Residential	Installation	SC
9/26/2024	2205 JACK LN	Residential	Request As-Built	SW
9/26/2024	2703 FALLSBROOKE MANOR DR	Residential		SW
9/26/2024	3205 SUDATH LN	Residential	Maintenance	SW
9/26/2024	0 MANTLEWOOD WAY	Subdivision	Maintenance	SC
9/26/2024	0 Whiteford and Rocks RD	Commercial	Maintenance	SC
9/26/2024	0 HANSON RD	Subdivision	Maintenance	SC
9/27/2024	1205 MAIN ST	Residential	Final	SC
9/27/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
9/27/2024	3116 TUCKER RD	Residential	Maintenance	SC
9/27/2024	2014 PACKARD DR	Residential	Maintenance	SC
9/27/2024	2600 TOBIN CROSSING	Residential	Construction	SW
9/27/2024	3205 SUDATH LN	Residential	Maintenance	SC
9/27/2024	0 ARDEN DR	Subdivision	Maintenance	SC
9/27/2024	0 OATGRASS CT	Residential	Maintenance	SW
9/27/2024	509 CHERRY HILL RD	Residential	Approval	SC
9/27/2024	2013 PACKARD DR	Residential	Construction	SW
9/27/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
9/27/2024	Inspection Number: 047527-2024	Capital Project	Maintenance	SC
9/27/2024	34 MC DERMOTT RD	Residential - Single	Maintenance	SW
9/27/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
9/27/2024	2509 PORT LN	Subdivision	Maintenance	SC
9/27/2024	2421 HARKINS RD	Residential - Single	Maintenance	SW
9/28/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/30/2024	4998 JOLLY ACRES RD	Residential	Maintenance	SC
9/30/2024	40 FORT HOYLE RD	Commercial	Pre-Inspection	SC
9/30/2024	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
9/30/2024	2720 ADY RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
9/30/2024	2911 VERBENA DR	Capital Project	Final	SC
9/30/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
9/30/2024	40 FORT HOYLE RD	Commercial	Pre-Inspection	SC
9/30/2024	1603 BULLS LN	Residential	Maintenance	SC
9/30/2024	1015 PULASKI HWY	Commercial	Maintenance	SC
9/30/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
9/30/2024	607-E DEMBYTOWN RD	Residential	Maintenance	SC
9/30/2024	2551 UREY RD	Residential	Final	SC
9/30/2024	2000 CALVARY RD	Commercial	Maintenance	SC
9/30/2024	3144 OLD YORK RD	Residential	Maintenance	SC
9/30/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
9/30/2024	1812 WALTON RD	Commercial	Maintenance	SC
9/30/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
9/30/2024	40 FORT HOYLE RD	Commercial	Pre-Con	SW
9/30/2024	3507 NORTH FURNACE RD	Residential	Maintenance	SC
10/1/2024	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
10/1/2024	615 SCHUCKS RD	Residential		SW
10/1/2024	905 HENDERSON RD	Residential	Final	SC
10/1/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
10/1/2024	3616 ADY RD	Residential	Approval	SC
10/1/2024	601 CARSINS RUN RD	Forested	Maintenance	SC
10/1/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC
10/1/2024	215 KENNARD AVE	Residential	Maintenance	SC
10/1/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/1/2024	0 SHINGLE OAK CT	Residential	Reinspection	SC
10/1/2024	1725 O'CONNER RD	Residential		SC
10/1/2024	0 TOLLGATE RD	Commercial	Maintenance	SW
10/2/2024	34 MC DERMOTT RD	Residential	Maintenance	SC
10/2/2024	1903 MITCHELL DR	Residential	Final	SC
10/2/2024	0 CEDAR DR	Commercial	Maintenance	SC
10/2/2024	0 SHINGLE OAK CT		Construction	SW
10/2/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
10/2/2024	2626 TALL OAKS DR	Subdivision	Complaint	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/2/2024	0 CONOWINGO RD	Institutional	Final	SC
10/2/2024	331 MARINA AVE	Residential		SC
10/2/2024	1702 MOONRIVER CT	Subdivision	Maintenance	SC
10/2/2024	1714 RIDGE RD	Residential	Maintenance	SW
10/2/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
10/2/2024	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
10/2/2024	7 LOCUST RD	Residential	Final	SC
10/2/2024	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
10/2/2024	2246 GIBSON RD	Residential	Maintenance	SC
10/2/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/3/2024	2626 TALL OAKS DR	Subdivision	Maintenance	SC
10/3/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
10/3/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
10/3/2024	0 CARRS MILL RD	Capital Project	Maintenance	SC
10/3/2024	3026 SNAKE LN	Residential	Maintenance	SC
10/3/2024	1307 GOVERNOR CT	Commercial	Maintenance	SW
10/3/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
10/3/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
10/3/2024	1725 O'CONNER RD	Residential	Maintenance	SC
10/3/2024	119 HOPEWELL RD	Residential	Maintenance	SC
10/3/2024	401 THOMAS RUN RD	Institutional	Maintenance	SC
10/3/2024	2309 SNOW RD	Residential	Reinspection	SC
10/3/2024	354 OLD BAY LN	Commercial	Maintenance	SC
10/3/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
10/3/2024	1725 O'CONNER RD	Residential	Maintenance	SC
10/3/2024	2248 GIBSON RD	Residential	Maintenance	SC
10/3/2024	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
10/3/2024	1500 VAN BIBBER RD	Residential	Maintenance	SW
10/3/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/3/2024	2704 ADY RD	Residential - Single	Request As-Built	SW
10/3/2024	401 THOMAS RUN RD	Government / Institutional	Construction	SW
10/3/2024	417-A Calvary RD	Residential	Maintenance	SC
10/3/2024	330 ENFIELD RD	Subdivision	Reinspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/3/2024	664 Trimble RD	Subdivision	Maintenance	SC
10/3/2024	0 HANSON RD	Subdivision	Maintenance	SC
10/4/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC
10/4/2024	2113 NUTTAL AVE	Subdivision	Maintenance	SC
10/4/2024	2201 OLD JOPPA RD	Residential - Single	Maintenance	SW
10/4/2024	2720 ADY RD	Residential	Maintenance	SC
10/4/2024	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
10/4/2024	300 PULASKI HWY	Commercial	Maintenance	SC
10/4/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC
10/4/2024	2239 ENGLE RD	Residential	Maintenance	SC
10/4/2024	1373 TRAPPE RD	Residential	Maintenance	SC
10/4/2024	4800 OLD PHILADELPHIA RD	Subdivision	Reinspection	SC
10/4/2024	1127 Belcamp Garth	Capital Project	Maintenance	SC
10/4/2024	1525 PHILADELPHIA BLVD	Commercial	Maintenance	SC
10/4/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
10/4/2024	0 GRAVEL HILL RD		2018 IBC as adopted Chap 82 Harford	SC
10/4/2024	1525 PHILADELPHIA BLVD	Commercial	Construction	SW
10/4/2024	2000 CALVARY RD	Commercial	Reinspection	SC
10/4/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
10/4/2024	2013 PACKARD DR	Residential	Maintenance	SC
10/4/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/7/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/7/2024	0 YEARLING DR	Subdivision	Maintenance	SC
10/7/2024	3538 ALDINO RD	Commercial	Maintenance	SC
10/7/2024	781 PRIESTFORD RD	Residential	Maintenance	SC
10/7/2024	0 PURPLE PL	Subdivision	Maintenance	SC
10/7/2024	319 COOLEY MILL RD	Residential	Maintenance	SC
10/7/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
10/8/2024	1408 PERSIMMON PL		Complaint	SC
10/8/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
10/8/2024	5640 LONG CORNER RD	Residential	Maintenance	SC
10/8/2024	1702 MOONRIVER CT	Residential	Maintenance	SW
10/8/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/8/2024	2300 EDWARDS LN	Residential	Maintenance	SC
10/8/2024	2205 JACK LN	Residential	Maintenance	SC
10/8/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
10/8/2024	0 SHINGLE OAK CT		Conversion	SW
10/8/2024	617 MAHAN RD	Residential	Maintenance	SC
10/8/2024	3205 SUDATH LN	Residential	Maintenance	SC
10/8/2024	1408 THOMAS RUN RD	Residential	Maintenance	SC
10/8/2024	1319 PERRYMAN RD	Commercial	Installation	SC
10/8/2024	0 GRAVEL HILL RD	Commercial	Maintenance	SC
10/9/2024	4624 MERCEDES DR	Commercial	Request As-Built	SW
10/9/2024	1111 VALE RD	Residential	Maintenance	SC
10/9/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
10/9/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
10/9/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/9/2024	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
10/9/2024	104 MOONLIGHT DR	Subdivision	Maintenance	SC
10/9/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
10/9/2024	4624 MERCEDES DR	Commercial	Maintenance	SC
10/9/2024	812 OLD JOPPA RD	Residential	Pre-Inspection	SC
10/9/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
10/9/2024	0 CHELSEA RD	Commercial	Maintenance	SC
10/9/2024	812 OLD JOPPA RD		Pre-Con	SW
10/9/2024	2101 GLEN COVE RD	Residential	Approval	SC
10/9/2024	2626 TALL OAKS DR	Subdivision	Complaint	SC
10/9/2024	2025 CASTLETON RD	Residential	As-Built Received	SW
10/10/2024	3116 TUCKER RD	Residential	Final	SC
10/10/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
10/10/2024	928 Fenario RD	Residential	Maintenance	SC
10/10/2024	2248 GIBSON RD	Residential - Single	Construction	SW
10/10/2024	2309 SNOW RD	Residential	Maintenance	SC
10/10/2024	0 SHINGLE OAK CT	Residential	Installation	SC
10/10/2024	1725 O'CONNER RD	Residential		SW
10/10/2024	2704 ADY RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/10/2024	301 FOUNTAIN GREEN RD	Subdivision		SC
10/10/2024	0 MANTLEWOOD WAY	Subdivision	Maintenance	SC
10/10/2024	2822 CHARLES ST	Residential	Maintenance	SC
10/10/2024	1714 RIDGE RD	Residential	Maintenance	SC
10/10/2024	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
10/10/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/10/2024	1657 Robin CIR	Commercial		SC
10/10/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
10/10/2024	1605 ALGONQUIN CT	Residential	Maintenance	SC
10/10/2024	0 HANSON RD	Subdivision	Maintenance	SC
10/10/2024	330 ENFIELD RD	Subdivision	Maintenance	SC
10/11/2024	Inspection Number: 050202-2024	Capital Project	Maintenance	SC
10/11/2024	2025 CASTLETON RD	Residential	Maintenance	SC
10/11/2024	1526 QUARRY RD			SW
10/11/2024	2595 MEDICAL HALL RD			SC
10/11/2024	1903 MITCHELL DR	Residential		SC
10/11/2024	4147 CONOWINGO RD	Residential	Maintenance	SC
10/11/2024	3632 PROSPECT RD			SC
10/11/2024	2718 ADY RD			SC
10/11/2024	614 PHILADELPHIA RD			SC
10/11/2024	7 LOCUST RD	Residential		SC
10/11/2024	852 STANSBURY RD			SC
10/11/2024	2509 PORT LN	Subdivision	Maintenance	SC
10/11/2024	1166 RIDGE RD	Forested	Final	SC
10/11/2024	2014 PACKARD DR	Residential	Maintenance	SC
10/11/2024	2911 VERBENA DR	Capital Project		SC
10/11/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/11/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
10/11/2024	0 ARDEN DR	Subdivision	Maintenance	SC
10/11/2024	614 PHILADELPHIA RD			SC
10/14/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/14/2024	607-E DEMBYTOWN RD	Residential	Maintenance	SC
10/14/2024	0 MANTLEWOOD WAY	Subdivision	Reinspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/14/2024	100 KEARNEY DR	Capital Project	Pre-Con	SW
10/14/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
10/14/2024	119 HOPEWELL RD	Residential	Maintenance	SC
10/14/2024	1812 WALTON RD	Commercial	Maintenance	SC
10/14/2024	3314 ABINGDON RD	Commercial	Maintenance	SC
10/14/2024	1225 BUSH RD	Residential	Maintenance	SC
10/14/2024	913 FAWN CT			SC
10/14/2024	2013 SCHUSTER RD	Residential	Maintenance	SC
10/14/2024	2589 MEDICAL HALL RD	Residential	Maintenance	SC
10/14/2024	2589 MEDICAL HALL RD	Residential - Single	Construction	SW
10/14/2024	101 CHERRY HILL RD	Commercial	Maintenance	SC
10/14/2024	2421 HARKINS RD	Residential	Maintenance	SC
10/14/2024	1406 MANDEVILLE RD	Residential	Maintenance	SC
10/14/2024	3538 ALDINO RD	Commercial	Reinspection	SC
10/14/2024	3144 OLD YORK RD	Residential	Maintenance	SC
10/14/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
10/14/2024	100 KEARNEY DR	Capital Project	Pre-Inspection	SC
10/14/2024	0 Surf Scoter LA	Subdivision	Maintenance	SC
10/14/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
10/14/2024	1623 SHADY TREE CT	Subdivision	Complaint	SC
10/15/2024	34 MC DERMOTT RD	Residential - Single	Maintenance	SW
10/15/2024	0 NUTTAL AVE	Capital Project	Maintenance	SC
10/15/2024	0 VAN BIBBER RD		Request As-Built	SW
10/15/2024	904 EDGEWOOD RD	Commercial	Request As-Built	SW
10/15/2024	1903 MITCHELL DR			SW
10/15/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
10/15/2024	601 CARSINS RUN RD	Forested	Final	SC
10/15/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
10/15/2024	2208 CONNOLLY RD	Commercial	Maintenance	SC
10/15/2024	509 CHERRY HILL RD	Residential	Maintenance	SC
10/15/2024	672 ROCK SPRING CHURCH RD	Residential	Final	SC
10/15/2024	1408 THOMAS RUN RD	Residential - Single	Construction	SW
10/15/2024	215 KENNARD AVE	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/15/2024	0 CEDAR DR	Commercial	Maintenance	SC
10/15/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/15/2024	2600 TOBIN CROSSING	Commercial	Maintenance	SC
10/15/2024	2600 TOBIN CROSSING	Commercial	Construction	SW
10/15/2024	0 CEDAR DR	Commercial	Maintenance	SW
10/15/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
10/15/2024	664 Trimble RD	Subdivision	Complaint	SC
10/15/2024	0 HANSON RD	Subdivision	Maintenance	SC
10/15/2024	3026 SNAKE LN	Residential	Maintenance	SC
10/16/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
10/16/2024	34 MC DERMOTT RD	Residential - Single	Maintenance	SW
10/16/2024	1615 INGLESIDE RD	Residential	Maintenance	SC
10/16/2024	1501 PERRYMAN RD	Commercial	Maintenance	SC
10/16/2024	1702 MOONRIVER CT	Subdivision	Maintenance	SC
10/16/2024	2720 ADY RD	Residential	Maintenance	SC
10/16/2024	338 EARLTON RD	Residential	Maintenance	SC
10/16/2024	331 MARINA AVE	Residential	Maintenance	SC
10/16/2024	417-A Calvary RD	Residential	Maintenance	SC
10/16/2024	2626 TALL OAKS DR	Subdivision	Maintenance	SC
10/16/2024	1111 VALE RD	Residential	Maintenance	SC
10/16/2024	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
10/16/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/16/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
10/16/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC
10/16/2024	1410 THOMAS RUN RD	Residential	Maintenance	SC
10/16/2024	2215 CHURCHVILLE RD		Final	SW
10/16/2024	0 PURPLE PL	Subdivision	Maintenance	SC
10/17/2024	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
10/17/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/17/2024	330 ENFIELD RD	Subdivision	Maintenance	SC
10/17/2024	23 JACQUELINE WAY			SW
10/17/2024	2409 HARFORD RD		Construction	SW
10/17/2024	3205 SUDATH LN	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/17/2024	2720 ADY RD	Residential - Single	Request As-Built	SW
10/17/2024	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
10/17/2024	1725 O'CONNOR RD	Residential	Maintenance	SW
10/17/2024	854 STANSBURY RD	Residential	Approval	SC
10/17/2024	0 Surf Scoter LA	Subdivision	Reinspection	SC
10/18/2024	1127 Belcamp Garth	Capital Project	Maintenance	SC
10/18/2024	1605 ALGONQUIN CT	Residential	Maintenance	SC
10/18/2024	300 PULASKI HWY	Commercial	Maintenance	SC
10/18/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
10/18/2024	2113 NUTTAL AVE	Subdivision	Maintenance	SC
10/18/2024	0 MANTLEWOOD WAY	Subdivision	Reinspection	SC
10/18/2024	1408 PERSIMMON PL		Complaint	SC
10/18/2024	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
10/18/2024	1525 PHILADELPHIA BLVD	Commercial	Final	SC
10/18/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC
10/18/2024	100 THOMAS RUN RD	Institutional	Maintenance	SC
10/18/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC
10/18/2024	2003 LAUREL BROOK RD	Residential	Request As-Built	SW
10/18/2024	1430 QUAKER CHURCH RD	Residential	Construction	SW
10/18/2024	2014 PACKARD DR	Residential	Maintenance	SC
10/18/2024	2013 PACKARD DR	Residential	Maintenance	SC
10/18/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
10/18/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
10/18/2024	2626 TALL OAKS DR	Subdivision		SC
10/18/2024	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
10/18/2024	0 UP AND OVER LN		Final	SW
10/18/2024	1107 UP AND OVER LN		Final	SW
10/18/2024	0 BENTGRASS DR		Final	SW
10/18/2024	Inspection Number: 054859-2024		Final	SW
10/21/2024	529 PRITT LN	Residential	Maintenance	SC
10/21/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
10/21/2024	20 FORT HOYLE RD	Residential	Pre-Inspection	SC
10/21/2024	20 FORT HOYLE RD	Residential - Single	Pre-Con	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/21/2024	800 W Jarrettsville RD	Residential	Request As-Built	SW
10/21/2024	354 OLD BAY LN	Commercial	Maintenance	SC
10/21/2024	903 OLD PYLESVILLE RD	Residential	Approval	SC
10/21/2024	Inspection Number: ESCCI-048094-2024	Commercial	Reinspection	SC
10/21/2024	2246 GIBSON RD	Residential	Request As-Built	SW
10/21/2024	0 CARRS MILL RD	Capital Project	Maintenance	SC
10/21/2024	2209 APOLLO TER			SC
10/21/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
10/21/2024	529 PRITT LN	Residential	Pre-Con	SW
10/21/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
10/21/2024	854 STANSBURY RD	Residential	Maintenance	SC
10/21/2024	2000 CALVARY RD	Commercial	Maintenance	SC
10/21/2024	1603 BULLS LN	Residential	Maintenance	SC
10/21/2024	812 OLD JOPPA RD	Residential	Maintenance	SC
10/21/2024	3333 JAMES RUN RD	Residential	Reinspection	SC
10/21/2024	2315 BEL AIR RD	Commercial	Maintenance	SC
10/22/2024	2239 ENGLE RD	Residential	Maintenance	SC
10/22/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
10/22/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
10/22/2024	604 SUGAR HILL RD	Residential	Maintenance	SC
10/22/2024	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
10/22/2024	2704 ADY RD	Residential	Maintenance	SC
10/22/2024	672 ROCK SPRING CHURCH RD	Residential		SC
10/22/2024	5640 LONG CORNER RD	Residential	Maintenance	SC
10/22/2024	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
10/22/2024	2300 EDWARDS LN	Residential	Maintenance	SC
10/22/2024	781 PRIESTFORD RD	Residential	Maintenance	SC
10/22/2024	0 YEARLING DR	Subdivision	Maintenance	SC
10/22/2024	800 W Jarrettsville RD	Residential		SW
10/22/2024	2205 JACK LN	Residential	Maintenance	SC
10/22/2024	711 PHILADELPHIA RD	Commercial	Complaint	SC
10/22/2024	319 COOLEY MILL RD	Residential	Maintenance	SC
10/22/2024	617 MAHAN RD	Residential	Maintenance	SC

# *Inspections By Date*

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/22/2024	0 VAN BIBBER RD		Conversion	SW
10/22/2024	2720 ADY RD	Residential	Maintenance	SC
10/22/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
10/22/2024	1319 PERRYMAN RD	Commercial	Maintenance	SC
10/22/2024	3144 OLD YORK RD	Residential	Maintenance	SC
10/22/2024	3507 NORTH FURNACE RD	Residential	Final	SC
10/22/2024	1714 RIDGE RD	Residential	Maintenance	SC
10/22/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
10/22/2024	3632 PROSPECT RD	Residential	Pre-Con	SW
10/22/2024	3632 PROSPECT RD	Residential	Maintenance	SC
10/22/2024	1725 JARRETTSVILLE RD		Maintenance	SW
10/22/2024	608 HENDERSON RD	Residential	Request As-Built	SW
10/23/2024	1410 THOMAS RUN RD	Residential	Maintenance	SC
10/23/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
10/23/2024	1751 JARRETTSVILLE RD	Residential	Complaint	SC
10/23/2024	2248 GIBSON RD	Residential	Maintenance	SC
10/23/2024	1035 JOPPA RD	Commercial	Complaint	SC
10/23/2024	2029 CONNOLLY RD	Residential	Construction	SW
10/23/2024	2101 GLEN COVE RD	Residential	Maintenance	SC
10/23/2024	0 CHELSEA RD	Commercial	Maintenance	SC
10/23/2024	2246 GIBSON RD	Residential	Maintenance	SC
10/23/2024	0 MAGNOLIA RD	Forested	Complaint	SC
10/23/2024	4624 MERCEDES DR	Commercial	Maintenance	SC
10/23/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
10/23/2024	2600 TOBIN CROSSING	Residential	Construction	SW
10/23/2024	2809 BELCAMP RD	Residential - Single		SW
10/23/2024	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
10/23/2024	2600 TOBIN CROSSING	Residential	Construction	SW
10/23/2024	1609 HEIMS LN	Residential	Complaint	SC
10/23/2024	529 PRITT LN	Residential	Construction	SW
10/23/2024	0 LAUREL BUSH RD	Residential	Maintenance	SC
10/23/2024	0 OATGRASS CT	Residential	Maintenance	SW
10/23/2024	2010 MOUNTAIN RD	Commercial	Complaint	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/24/2024	741 HOOKERS MILL RD	Residential	Complaint	SC
10/24/2024	0 SHINGLE OAK CT	Residential	Installation	SC
10/24/2024	928 Fenario CIR		Request As-Built	SW
10/24/2024	5129 FAWN GROVE RD	Residential	Construction	SW
10/24/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
10/24/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
10/24/2024	1225 BUSH RD	Residential	Maintenance	SC
10/24/2024	1714 RIDGE RD	Residential	Maintenance	SW
10/24/2024	104 MOONLIGHT DR	Subdivision	Maintenance	SC
10/24/2024	1605 ALGONQUIN CT	Residential	Reinspection	SC
10/24/2024	2703 FALLSBROOKE MANOR DR	Residential	Request As-Built	SW
10/24/2024	0 HARFORD SQUARE DR	Capital Project	Reinspection	SC
10/24/2024	812 OLD JOPPA RD	Residential	Complaint	SC
10/24/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
10/24/2024	4147 CONOWINGO RD	Residential	Maintenance	SC
10/24/2024	928 Fenario RD	Residential	Maintenance	SC
10/24/2024	664 Trimble RD	Subdivision	Maintenance	SC
10/24/2024	0 HANSON RD	Subdivision	Maintenance	SC
10/25/2024	601 CARSINS RUN RD	Forested	Final	SC
10/25/2024	1408 THOMAS RUN RD	Residential	Maintenance	SC
10/25/2024	401 THOMAS RUN RD	Institutional	Installation	SC
10/25/2024	2205 JACK LN	Residential		SW
10/25/2024	2589 MEDICAL HALL RD	Residential	Final	SC
10/25/2024	1408 PERSIMMON PL		Reinspection	SC
10/25/2024	Inspection Number: 053113-2024	Capital Project	Maintenance	SC
10/25/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
10/28/2024	3538 ALDINO RD	Commercial	Maintenance	SC
10/28/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
10/28/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
10/28/2024	509 CHERRY HILL RD	Residential	Final	SC
10/28/2024	2421 HARKINS RD	Residential	Maintenance	SC
10/28/2024	101 CHERRY HILL RD	Commercial	Maintenance	SC
10/28/2024	1015 PULASKI HWY	Commercial	Reinspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/28/2024	1812 WALTON RD	Commercial	Maintenance	SC
10/28/2024	2720 ADY RD	Residential	Maintenance	SC
10/28/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
10/28/2024	2509 PORT LN	Subdivision	Maintenance	SC
10/28/2024	34 MC DERMOTT RD	Residential	Maintenance	SC
10/28/2024	119 HOPEWELL RD	Residential	Maintenance	SC
10/28/2024	607-E DEMBYTOWN RD	Residential	Maintenance	SC
10/28/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
10/28/2024	0 ARDEN DR	Subdivision	Maintenance	SC
10/28/2024	1812 WALTON RD	Commercial	Maintenance	SW
10/28/2024	2600 TOBIN CROSSING	Residential	Conversion	SW
10/28/2024	2809 BELCAMP RD	Residential	Pre-Inspection	SC
10/29/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
10/29/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
10/29/2024	0 NUTTAL AVE	Capital Project	Reinspection	SC
10/29/2024	2600 TOBIN CROSSING	Commercial	Maintenance	SC
10/29/2024	2309 SNOW RD		Maintenance	SW
10/29/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
10/29/2024	3507 NORTH FURNACE RD	Residential	Maintenance	SC
10/29/2024	615 SCHUCKS RD	Residential	Maintenance	SW
10/29/2024	2309 SNOW RD	Residential	Maintenance	SC
10/29/2024	2208 CONNOLLY RD	Commercial	Maintenance	SC
10/29/2024	3026 SNAKE LN	Residential	Maintenance	SC
10/29/2024	5640 LONG CORNER RD	Residential - Single	Maintenance	SW
10/29/2024	1500 VAN BIBBER RD	Residential	Maintenance	SW
10/29/2024	2305 SNOW RD	Residential	Maintenance	SW
10/30/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
10/30/2024	1307 GOVERNOR CT	Commercial	Maintenance	SW
10/30/2024	417-A Calvary RD	Residential	Maintenance	SC
10/30/2024	2113 NUTTAL AVE	Subdivision	Maintenance	SC
10/30/2024	2626 TALL OAKS DR	Subdivision	Maintenance	SC
10/30/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
10/30/2024	1702 MOONRIVER CT	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
10/30/2024	331 MARINA AVE	Residential	Maintenance	SC
10/30/2024	0 PURPLE PL	Subdivision	Maintenance	SC
10/30/2024	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
10/30/2024	100 KEARNEY DR	Capital Project	Installation	SC
10/30/2024	1111 VALE RD	Residential	Maintenance	SC
10/30/2024	330 ENFIELD RD	Subdivision	Maintenance	SC
10/31/2024	1615 INGLESIDE RD	Residential	Maintenance	SC
10/31/2024	2014 EMMORTON RD			SW
10/31/2024	1406 MANDEVILLE RD	Residential	Final	SC
10/31/2024	4260 FEDERAL HILL RD	Institutional	Pre-Inspection	SC
10/31/2024	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
10/31/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
10/31/2024	2416 WHITT RD	Residential	Complaint	SC
10/31/2024	1725 O'CONNER RD	Residential	Maintenance	SW
10/31/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC
10/31/2024	2014 EMMORTON RD	Commercial	Complaint	SC
10/31/2024	4372 FEDERAL HILL RD	Commercial	Pre-Inspection	SC
10/31/2024	1406 MANDEVILLE RD	Residential - Single		SW
10/31/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
10/31/2024	1615 INGLESIDE RD	Residential	Maintenance	SC
10/31/2024	1615 INGLESIDE RD	Residential	Maintenance	SC
10/31/2024	0 HANSON RD	Subdivision	Maintenance	SC
11/1/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
11/1/2024	0 MANTLEWOOD WAY	Subdivision	Maintenance	SC
11/1/2024	100 KEARNEY DR	Capital Project	Maintenance	SC
11/1/2024	1127 Belcamp Garth	Capital Project	Maintenance	SC
11/1/2024	2013 PACKARD DR	Residential	Maintenance	SC
11/1/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC
11/1/2024	0 SHINGLE OAK CT	Residential	Maintenance	SC
11/1/2024	2911 OLD JOPPA RD		Complaint	SC
11/1/2024	2014 PACKARD DR	Residential	Maintenance	SC
11/1/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
11/1/2024	672 ROCK SPRING CHURCH RD	Residential		SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
11/1/2024	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
11/1/2024	2209 APOLLO TER			SC
11/1/2024	1714 RIDGE RD	Residential	Maintenance	SC
11/1/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
11/1/2024	300 PULASKI HWY	Commercial	Maintenance	SC
11/3/2024	4260 FEDERAL HILL RD	Institutional	Maintenance	SC
11/3/2024	4372 FEDERAL HILL RD	Commercial	Final	SC
11/4/2024	0 CARRS MILL RD	Capital Project	Maintenance	SC
11/4/2024	2110 BEL AIR RD	Commercial	Request As-Built	SW
11/4/2024	607-E DEMBYTOWN RD	Residential	Maintenance	SC
11/4/2024	3314 ABINGDON RD	Commercial	Maintenance	SC
11/4/2024	2000 CALVARY RD	Commercial	Maintenance	SC
11/4/2024	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
11/4/2024	0 NUTTAL AVE	Capital Project	Reinspection	SC
11/4/2024	5640 LONG CORNER RD	Residential	Maintenance	SC
11/4/2024	354 OLD BAY LN	Commercial	Maintenance	SC
11/4/2024	20 FORT HOYLE RD	Residential	Maintenance	SC
11/4/2024	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
11/4/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC
11/4/2024	1406 MANDEVILLE RD	Residential		SC
11/4/2024	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
11/4/2024	1603 BULLS LN	Residential	Maintenance	SC
11/4/2024	1827 BALDWIN MILL RD	Residential - Single		SW
11/4/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
11/4/2024	529 PRITT LN	Residential	Maintenance	SC
11/5/2024	2205 JACK LN	Residential	Maintenance	SC
11/5/2024	3616 ADY RD	Residential	Maintenance	SC
11/5/2024	4998 JOLLY ACRES RD	Residential	Maintenance	SC
11/5/2024	604 SUGAR HILL RD	Residential	Maintenance	SC
11/5/2024	3632 PROSPECT RD	Residential	Maintenance	SC
11/5/2024	2421 HARKINS RD	Residential	Maintenance	SC
11/5/2024	2600 TOBIN CROSSING	Residential	Conversion	SW
11/5/2024	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
11/5/2024	508 PULASKI HWY	Commercial	Pre-Con	SW
11/5/2024	0 GRAVEL HILL RD	Commercial	Maintenance	SC
11/5/2024	3144 OLD YORK RD	Residential	Maintenance	SC
11/5/2024	4370 NORRISVILLE RD	Residential	Maintenance	SC
11/5/2024	1416 & 1418 Philadelphia RD	Commercial	Reinspection	SC
11/5/2024	2300 EDWARDS LN	Residential	Maintenance	SC
11/5/2024	319 COOLEY MILL RD	Residential	Maintenance	SC
11/5/2024	781 PRIESTFORD RD	Residential	Maintenance	SC
11/5/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
11/5/2024	508 PULASKI HWY	Commercial	Pre-Inspection	SC
11/5/2024	617 MAHAN RD	Residential	Maintenance	SC
11/5/2024	0 YEARLING DR	Subdivision	Maintenance	SC
11/5/2024	215 KENNARD AVE	Residential	Maintenance	SC
11/5/2024	0 CEDAR DR	Commercial	Maintenance	SC
11/5/2024	34 MC DERMOTT RD	Residential	Maintenance	SC
11/5/2024	2704 ADY RD	Residential	Maintenance	SC
11/5/2024	854 STANSBURY RD	Residential	Maintenance	SC
11/6/2024	0 CHELSEA RD	Commercial	Maintenance	SC
11/6/2024	4624 MERCEDES DR	Commercial	Maintenance	SC
11/6/2024	529 PRITT LN	Residential	Maintenance	SC
11/6/2024	1615 INGLESIDE RD	Residential	Maintenance	SW
11/6/2024	1319 PERRYMAN RD	Commercial	Maintenance	SC
11/6/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
11/6/2024	508 PULASKI HWY	Commercial	Maintenance	SC
11/6/2024	0 HANSON RD	Subdivision	Maintenance	SC
11/6/2024	529 PRITT LN	Residential	Request As-Built	SW
11/7/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
11/7/2024	928 Fenario RD	Residential	Maintenance	SC
11/7/2024	0 Surf Scoter LA	Subdivision	Maintenance	SC
11/7/2024	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
11/7/2024	2509 MOUNTAIN RD	Residential	Reinspection	SC
11/7/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
11/7/2024	1605 ALGONQUIN CT	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
11/7/2024	2014 EMMORTON RD	Commercial		SC
11/7/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
11/7/2024	3205 SUDATH LN	Residential	Maintenance	SC
11/7/2024	1751 JARRETTSVILLE RD	Residential	Final	SC
11/7/2024	812 OLD JOPPA RD	Residential	Maintenance	SC
11/8/2024	3808 SEWELL RD	Residential	Maintenance	SC
11/8/2024	3158 OLD FORGE HILL RD	Residential - Single	Request As-Built	SW
11/8/2024	2416 WHITT RD	Residential		SC
11/8/2024	2101 GLEN COVE RD	Residential	Maintenance	SC
11/8/2024	0 ABBEY CIR	Residential	Maintenance	SC
11/8/2024	1406 MANDEVILLE RD	Residential - Single	As-Built Received	SW
11/8/2024	1121 DEER CREEK CHURCH RD	Residential - Single		SW
11/8/2024	4147 CONOWINGO RD	Residential	Maintenance	SC
11/8/2024	Inspection Number: 055686-2024	Capital Project	Maintenance	SC
11/8/2024	2248 GIBSON RD	Residential	Maintenance	SC
11/8/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SW
11/8/2024	1225 BUSH RD	Residential	Maintenance	SC
11/8/2024	3808 SEWELL RD	Residential - Single	Pre-Con	SW
11/8/2024	2246 GIBSON RD	Residential	Maintenance	SC
11/8/2024	1406 MANDEVILLE RD	Residential		SC
11/8/2024	4370 NORRISVILLE RD	Residential - Single	As-Built	SW
11/11/2024	1408 THOMAS RUN RD	Residential	Maintenance	SC
11/11/2024	100 THOMAS RUN RD	Institutional	Maintenance	SC
11/11/2024	104 MOONLIGHT DR	Subdivision	Maintenance	SC
11/11/2024	401 THOMAS RUN RD	Institutional	Maintenance	SC
11/11/2024	101 CHERRY HILL RD	Commercial	Maintenance	SC
11/11/2024	2421 HARKINS RD	Residential - Single	Maintenance	SW
11/11/2024	1410 THOMAS RUN RD	Residential	Maintenance	SC
11/11/2024	854 STANSBURY RD	Residential	Final	SC
11/11/2024	0 CEDAR DR	Commercial	Reinspection	SC
11/12/2024	2822 CHARLES ST	Residential	Maintenance	SC
11/12/2024	119 HOPEWELL RD	Residential	Maintenance	SC
11/12/2024	2309 SNOW RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
11/12/2024	3538 ALDINO RD	Commercial	Maintenance	SC
11/12/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
11/12/2024	1219 FOUNTAIN GREEN RD	Residential	Complaint	SC
11/12/2024	3146 OLD YORK RD	Residential	Maintenance	SC
11/12/2024	119 HOPEWELL RD	Residential - Single	Construction	SW
11/12/2024	4370 NORRISVILLE RD	Residential	Maintenance	SC
11/12/2024	3144 OLD YORK RD	Residential	Maintenance	SC
11/12/2024	5640 LONG CORNER RD	Residential	Maintenance	SC
11/12/2024	3026 SNAKE LN	Residential	Maintenance	SC
11/12/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
11/12/2024	0 Whiteford and Rocks RD	Commercial	Maintenance	SC
11/12/2024	409 PHILADELPHIA RD	Residential	Complaint	SC
11/12/2024	2013 SCHUSTER RD	Residential	Maintenance	SC
11/12/2024	2720 ADY RD	Residential	Maintenance	SC
11/12/2024	1812 WALTON RD	Commercial	Request As-Built	SW
11/12/2024	2239 ENGLE RD	Residential	Maintenance	SC
11/12/2024	1812 WALTON RD	Commercial	Maintenance	SC
11/13/2024	417-A Calvary RD	Residential	Maintenance	SC
11/13/2024	0 JOHNSON MILL RD	Institutional	Maintenance	SC
11/13/2024	2600 TOBIN CROSSING	Commercial	Maintenance	SC
11/13/2024	529 PRITT LN	Residential	Maintenance	SC
11/13/2024	1035 JOPPA RD	Commercial	Complaint	SC
11/13/2024	0 PURPLE PL	Subdivision	Maintenance	SC
11/13/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
11/13/2024	330 ENFIELD RD	Subdivision	Maintenance	SC
11/13/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
11/13/2024	3532 MILLER RD	Residential	Maintenance	SC
11/13/2024	2300 EDWARDS LN	Residential - Single	Construction	SW
11/13/2024	1000 TOLLGATE RD	Residential	Maintenance	SW
11/13/2024	331 MARINA AVE	Residential	Maintenance	SC
11/13/2024	2113 NUTTAL AVE	Subdivision	Maintenance	SC
11/13/2024	0 HANSON RD	Subdivision	Maintenance	SC
11/14/2024	0 YEARLING DR	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
11/14/2024	100 KEARNEY DR	Capital Project	Maintenance	SC
11/14/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
11/14/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
11/14/2024	0 Whiteford and Rocks RD	Commercial	Maintenance	SC
11/14/2024	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
11/14/2024	2101 GLEN COVE RD	Residential	Construction	SW
11/14/2024	0 NUTTAL AVE	Capital Project	Maintenance	SC
11/14/2024	1111 VALE RD	Residential		SW
11/14/2024	2208 CONNOLLY RD	Commercial	Maintenance	SC
11/14/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
11/14/2024	0 ARDEN DR	Subdivision	Maintenance	SC
11/14/2024	854 STANSBURY RD	Residential	Maintenance	SC
11/14/2024	0 GRAVEL HILL RD	Commercial	Maintenance	SC
11/14/2024	100 KEARNEY DR	Capital Project	Maintenance	SW
11/15/2024	3532 MILLER RD	Residential	Maintenance	SC
11/15/2024	0 MANTLEWOOD WAY	Subdivision	Maintenance	SC
11/15/2024	300 PULASKI HWY	Commercial	Maintenance	SC
11/15/2024	2509 PORT LN	Subdivision	Maintenance	SC
11/15/2024	2809 BELCAMP RD	Residential	Maintenance	SC
11/15/2024	812 OLD JOPPA RD	Residential	Maintenance	SC
11/15/2024	1111 VALE RD	Residential	Maintenance	SC
11/15/2024	2626 TALL OAKS DR	Subdivision	Maintenance	SC
11/15/2024	607-E DEMBYTOWN RD	Residential	Reinspection	SC
11/15/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
11/15/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
11/15/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
11/15/2024	1127 Belcamp Garth	Capital Project	Maintenance	SC
11/15/2024	0 SHINGLE OAK CT	Residential	Maintenance	SC
11/18/2024	354 OLD BAY LN	Commercial	Maintenance	SC
11/18/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
11/18/2024	1373 TRAPPE RD	Residential - Single	Maintenance	SW
11/18/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
11/18/2024	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
11/18/2024	40 FORT HOYLE RD	Commercial	Maintenance	SC
11/18/2024	20 FORT HOYLE RD	Residential	Maintenance	SC
11/18/2024	2949 CONOWINGO RD	Forested	Complaint	SC
11/18/2024	617 MAHAN RD	Residential	Maintenance	SC
11/18/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
11/18/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
11/18/2024	854 STANSBURY RD	Residential - Single	As-Built Received	SW
11/18/2024	1603 BULLS LN	Residential	Maintenance	SC
11/18/2024	3146 OLD YORK RD	Residential - Single	Maintenance	SW
11/18/2024	3532 MILLER RD	Residential	Pre-Inspection	SC
11/18/2024	1373 TRAPPE RD	Residential	Approval	SC
11/18/2024	2025 CASTLETON RD	Residential	Maintenance	SC
11/19/2024	604 SUGAR HILL RD	Residential	Maintenance	SC
11/19/2024	0 YEARLING DR	Subdivision	Maintenance	SC
11/19/2024	2600 TOBIN CROSSING	Residential	Conversion	SW
11/19/2024	2718 ADY RD	Residential		SC
11/19/2024	2718 ADY RD	Residential	Maintenance	SC
11/19/2024	34 MC DERMOTT RD	Residential	Maintenance	SC
11/19/2024	1714 RIDGE RD	Residential	Maintenance	SC
11/19/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
11/19/2024	4998 JOLLY ACRES RD	Residential	Maintenance	SC
11/19/2024	2421 HARKINS RD	Residential	Maintenance	SC
11/19/2024	2013 PACKARD DR	Residential	Maintenance	SC
11/19/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
11/19/2024	2718 ADY RD	Residential	Installation	SC
11/19/2024	3314 ABINGDON RD	Commercial	Maintenance	SC
11/19/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
11/19/2024	2000 CALVARY RD	Commercial	Maintenance	SC
11/19/2024	2718 ADY RD	Residential	Pre-Inspection	SC
11/19/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
11/19/2024	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
11/19/2024	781 PRIESTFORD RD	Residential	Maintenance	SC
11/19/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
11/19/2024	319 COOLEY MILL RD	Residential	Maintenance	SC
11/19/2024	2246 GIBSON RD	Residential		SW
11/19/2024	2014 PACKARD DR	Residential	Maintenance	SC
11/19/2024	3696 LOVE RD		Pre-Inspection	SC
11/19/2024	2589 MEDICAL HALL RD	Residential - Single	Request As-Built	SW
11/20/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC
11/20/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
11/20/2024	3808 SEWELL RD	Residential	Maintenance	SC
11/20/2024	2600 TOBIN CROSSING	Commercial	Maintenance	SC
11/20/2024	2205 JACK LN	Residential	Maintenance	SC
11/20/2024	0 NUTTAL AVE	Capital Project	Maintenance	SC
11/20/2024	0 CARRS MILL RD	Capital Project	Maintenance	SC
11/20/2024	2300 EDWARDS LN	Residential	Maintenance	SC
11/20/2024	1319 PERRYMAN RD	Commercial	Maintenance	SC
11/20/2024	1301 GOVERNOR CT	Commercial	Maintenance	SC
11/20/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
11/20/2024	0 CHELSEA RD	Commercial	Maintenance	SC
11/20/2024	508 PULASKI HWY	Commercial	Maintenance	SC
11/20/2024	0 HANSON RD	Subdivision	Maintenance	SC
11/21/2024	529 PRITT LN	Residential		SW
11/21/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
11/21/2024	104 MOONLIGHT DR	Subdivision	Maintenance	SC
11/21/2024	3040 LEVEL RD		Pre-Con	SW
11/21/2024	0 JOPPA FARM RD	Residential	Maintenance	SW
11/21/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
11/21/2024	0 JOPPA FARM RD	Residential	Maintenance	SW
11/21/2024	3040 LEVEL RD	Residential	Pre-Inspection	SC
11/21/2024	0 HARLING CT		Maintenance	SC
11/21/2024	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
11/21/2024	2704 ADY RD	Residential	Final	SC
11/21/2024	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
11/21/2024	928 Fenario RD	Residential	Final	SC
11/21/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
11/21/2024	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
11/21/2024	0 Surf Scoter LA	Subdivision	Maintenance	SC
11/21/2024	3616 ADY RD	Residential	Maintenance	SC
11/21/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
11/21/2024	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
11/21/2024	1605 ALGONQUIN CT	Residential	Maintenance	SC
11/21/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
11/21/2024	4624 MERCEDES DR	Commercial		SC
11/21/2024	0 HANSON RD	Subdivision	Maintenance	SC
11/22/2024	3205 SUDATH LN	Residential	Maintenance	SC
11/22/2024	3205 SUDATH LN	Residential	Request As-Built	SW
11/22/2024	103 NANCY CT		Complaint	SC
11/22/2024	1225 BUSH RD	Residential	Maintenance	SC
11/22/2024	101 CHERRY HILL RD	Commercial	Maintenance	SC
11/22/2024	2209 APOLLO TER		Final	SC
11/22/2024	928 Fenario CIR			SW
11/22/2024	1219 FOUNTAIN GREEN RD	Residential		SC
11/22/2024	3333 JAMES RUN RD	Residential	Reinspection	SC
11/22/2024	Inspection Number: ESCCI-054908-2024	Commercial	Reinspection	SC
11/22/2024	1702 MOONRIVER CT	Subdivision	Maintenance	SC
11/22/2024	2703 FALLSBROOKE MANOR DR	Residential		SW
11/22/2024	1655 Robin CIR	Commercial	Request As-Built	SW
11/22/2024	0 MAGNOLIA RD	Forested	Reinspection	SC
11/22/2024	Inspection Number: 058571-2024	Capital Project	Maintenance	SC
11/22/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
11/25/2024	0 LAUREL BUSH RD	Residential	Maintenance	SC
11/25/2024	0 CEDAR DR	Commercial	Maintenance	SC
11/25/2024	812 OLD JOPPA RD	Residential	Maintenance	SC
11/25/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
11/25/2024	1609 HEIMS LN	Residential	Complaint	SC
11/25/2024	2626 TALL OAKS DR	Subdivision	Maintenance	SC
11/25/2024	2800 E MEDICAL HALL RD	Residential - Single	As-Built Received	SW
11/25/2024	5640 LONG CORNER RD	Residential - Single	Maintenance	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
11/25/2024	805 THOMAS RUN RD	Residential - Single	Pre-Con	SW
11/25/2024	0 CEDAR DR	Commercial	Maintenance	SW
11/25/2024	1812 WALTON RD	Commercial	Maintenance	SC
11/25/2024	0 OATGRASS CT	Residential	Maintenance	SW
11/26/2024	1500 VAN BIBBER RD	Residential	Maintenance	SW
11/26/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
11/26/2024	2305 SNOW RD	Residential	Maintenance	SW
11/26/2024	2309 SNOW RD	Residential	Maintenance	SC
11/26/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
11/26/2024	215 KENNARD AVE	Residential	Maintenance	SC
11/26/2024	741 HOOKERS MILL RD	Residential	Complaint	SC
11/26/2024	2309 SNOW RD		Maintenance	SW
11/26/2024	2010 MOUNTAIN RD	Commercial	Complaint	SC
11/26/2024	3924 NORRISVILLE RD	Residential	Pre-Inspection	SC
11/26/2024	215 KENNARD AVE		Maintenance	SW
11/26/2024	2822 CHARLES ST	Residential	Maintenance	SW
11/26/2024	0 HANSON RD	Subdivision	Maintenance	SC
11/27/2024	4370 NORRISVILLE RD	Residential	Maintenance	SC
11/27/2024	0 PURPLE PL	Subdivision	Maintenance	SC
11/27/2024	0 834 W Ring Factory Rd	Commercial	Complaint	SC
11/27/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
11/27/2024	812 OLD JOPPA RD	Residential	Complaint	SC
11/27/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
11/27/2024	2215 CRESWELL RD		Request As-Built	SW
11/27/2024	2248 GIBSON RD	Residential	Maintenance	SC
11/27/2024	3144 OLD YORK RD	Residential	Maintenance	SC
11/27/2024	3146 OLD YORK RD	Residential	Maintenance	SC
11/27/2024	2113 NUTTAL AVE	Subdivision	Maintenance	SC
11/27/2024	2208 CONNOLLY RD	Commercial	Maintenance	SC
11/27/2024	3146 OLD YORK RD	Residential	Maintenance	SC
11/27/2024	5640 LONG CORNER RD	Residential	Maintenance	SC
11/27/2024	1307 GOVERNOR CT	Commercial	Request As-Built	SW
11/27/2024	330 ENFIELD RD	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
11/27/2024	529 PRITT LN	Residential	Maintenance	SC
11/27/2024	3146 OLD YORK RD	Residential	Maintenance	SC
11/27/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
11/28/2024	2246 GIBSON RD	Residential	Maintenance	SC
11/28/2024	2101 GLEN COVE RD	Residential	Maintenance	SC
11/28/2024	1410 THOMAS RUN RD	Residential	Maintenance	SC
11/28/2024	4147 CONOWINGO RD	Residential	Final	SC
11/28/2024	2239 ENGLE RD	Residential	Maintenance	SC
11/28/2024	1408 THOMAS RUN RD	Residential	Maintenance	SC
11/29/2024	1121 DEER CREEK CHURCH RD	Residential - Single	Maintenance	SW
11/29/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SW
12/2/2024	3538 ALDINO RD	Commercial	Maintenance	SC
12/2/2024	1111 VALE RD	Residential	Maintenance	SC
12/2/2024	2509 PORT LN	Subdivision	Maintenance	SC
12/2/2024	617 MAHAN RD	Residential	Maintenance	SC
12/2/2024	3632 PROSPECT RD	Residential	Maintenance	SC
12/2/2024	1603 BULLS LN	Residential	Maintenance	SC
12/2/2024	3026 SNAKE LN	Residential	Maintenance	SC
12/2/2024	417-A Calvary RD	Residential	Maintenance	SC
12/2/2024	2822 CHARLES ST	Residential	Maintenance	SC
12/2/2024	119 HOPEWELL RD	Residential	Maintenance	SC
12/2/2024	20 FORT HOYLE RD	Residential	Maintenance	SC
12/2/2024	2013 SCHUSTER RD	Residential	Maintenance	SC
12/2/2024	0 ARDEN DR	Subdivision	Maintenance	SC
12/2/2024	928 Fenario RD	Residential		SC
12/2/2024	40 FORT HOYLE RD	Commercial	Maintenance	SC
12/2/2024	1623 SHADY TREE CT	Residential	Construction	SW
12/2/2024	854 STANSBURY RD	Residential	Maintenance	SC
12/2/2024	100 KEARNEY DR	Capital Project	Maintenance	SC
12/2/2024	2025 CASTLETON RD	Residential	Maintenance	SC
12/2/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
12/2/2024	1307 GOVERNOR CT	Commercial		SW
12/2/2024	2720 ADY RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/2/2024	2315 BEL AIR RD	Commercial	Maintenance	SC
12/3/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
12/3/2024	2101 CONNOLLY RD	Residential	Request As-Built	SW
12/3/2024	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
12/3/2024	401 THOMAS RUN RD	Institutional	Maintenance	SC
12/3/2024	2718 ADY RD	Residential - Single	Pre-Con	SW
12/3/2024	2718 ADY RD	Residential	Approval	SC
12/3/2024	2029 CONNOLLY RD	Residential	Request As-Built	SW
12/3/2024	755 CHELSEA RD	Commercial	Construction	SW
12/3/2024	1416 PHILADELPHIA RD	Commercial	Maintenance	SW
12/3/2024	2350 CONOWINGO RD	Institutional	Complaint	SC
12/3/2024	711 PHILADELPHIA RD	Commercial	Complaint	SC
12/3/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
12/3/2024	1501 PERRYMAN RD	Commercial	Maintenance	SC
12/3/2024	3314 ABINGDON RD	Commercial	Maintenance	SC
12/3/2024	0 CHELSEA RD	Commercial	Maintenance	SC
12/3/2024	2800 E MEDICAL HALL RD	Residential	Maintenance	SC
12/3/2024	2718 ADY RD	Residential		SC
12/3/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
12/3/2024	331 MARINA AVE	Residential	Maintenance	SC
12/3/2024	1319 PERRYMAN RD	Commercial	Maintenance	SC
12/3/2024	2029 CONNOLLY RD	Residential	Request As-Built	SW
12/3/2024	604 SUGAR HILL RD	Residential	Maintenance	SC
12/4/2024	0 MANTLEWOOD WAY	Subdivision	Maintenance	SC
12/4/2024	4624 MERCEDES DR	Commercial	Maintenance	SC
12/4/2024	508 PULASKI HWY	Commercial	Maintenance	SC
12/4/2024	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
12/4/2024	2013 PACKARD DR	Residential	Maintenance	SC
12/4/2024	1301 GOVERNOR CT	Commercial	Maintenance	SC
12/4/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
12/4/2024	2014 PACKARD DR	Residential	Maintenance	SC
12/4/2024	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
12/4/2024	3808 SEWELL RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/4/2024	1934 PLEASANTVILLE RD	Residential	Maintenance	SC
12/4/2024	0 SHINGLE OAK CT	Residential	Maintenance	SC
12/4/2024	0 HANSON RD	Subdivision	Maintenance	SC
12/5/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC
12/5/2024	800 W Jarrettsville RD	Residential	Request As-Built	SW
12/5/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
12/5/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
12/5/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
12/5/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
12/5/2024	319 COOLEY MILL RD	Residential	Maintenance	SC
12/5/2024	812 OLD JOPPA RD	Residential	Reinspection	SC
12/5/2024	0 VAN BIBBER RD	Commercial	Complaint	SC
12/5/2024	2205 JACK LN	Residential	Maintenance	SC
12/5/2024	354 OLD BAY LN	Commercial	Maintenance	SC
12/5/2024	0 GRAVEL HILL RD	Commercial	Maintenance	SC
12/5/2024	2300 EDWARDS LN	Residential	Maintenance	SC
12/5/2024	1934 PLEASANTVILLE RD	Residential	Construction	SW
12/5/2024	3040 LEVEL RD	Residential	Installation	SC
12/5/2024	2626 TALL OAKS DR	Subdivision	Maintenance	SC
12/5/2024	1373 TRAPPE RD	Residential		SC
12/6/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
12/6/2024	0 CARRS MILL RD	Capital Project	Maintenance	SC
12/6/2024	812 OLD JOPPA RD	Residential	Maintenance	SC
12/6/2024	607-E DEMBYTOWN RD	Residential	Maintenance	SC
12/6/2024	0 JOHNSON MILL RD	Institutional	Maintenance	SC
12/6/2024	1714 RIDGE RD	Residential	Maintenance	SC
12/6/2024	300 PULASKI HWY	Commercial	Maintenance	SC
12/6/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
12/6/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
12/6/2024	101 CHERRY HILL RD	Commercial	Maintenance	SC
12/6/2024	616 MAGNOLIA RD	Institutional	Final	SC
12/6/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
12/6/2024	1605 ALGONQUIN CT	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/6/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
12/6/2024	1127 Belcamp Garth	Capital Project	Maintenance	SC
12/6/2024	34 MC DERMOTT RD	Residential	Maintenance	SC
12/6/2024	3538 ALDINO RD	Commercial	Construction	SW
12/6/2024	2809 BELCAMP RD	Residential	Maintenance	SC
12/6/2024	0 HARLING CT		Maintenance	SC
12/6/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
12/6/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
12/6/2024	2809 BELCAMP RD	Residential	Maintenance	SC
12/6/2024	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
12/6/2024	104 MOONLIGHT DR	Subdivision	Maintenance	SC
12/6/2024	338 EARLTON RD	Residential	Maintenance	SC
12/6/2024	664 Trimble RD	Subdivision	Maintenance	SC
12/9/2024	1015 PULASKI HWY	Commercial	Maintenance	SC
12/9/2024	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
12/9/2024	Inspection Number: 061409-2024	Capital Project	Maintenance	SC
12/9/2024	4998 JOLLY ACRES RD	Residential	Maintenance	SC
12/9/2024	1812 WALTON RD	Commercial	Maintenance	SC
12/9/2024	2626 TALL OAKS DR	Subdivision	Complaint	SC
12/9/2024	1711 JARRETTSVILLE RD	Residential	Maintenance	SW
12/9/2024	3158 OLD FORGE HILL RD	Residential - Single		SW
12/9/2024	1702 MOONRIVER CT	Subdivision	Maintenance	SC
12/9/2024	2000 CALVARY RD	Commercial	Maintenance	SC
12/9/2024	2600 TOBIN CROSSING	Commercial		SC
12/9/2024	3532 MILLER RD	Residential	Maintenance	SC
12/9/2024	0 CEDAR DR	Commercial	Maintenance	SC
12/9/2024	1307 GOVERNOR CT	Commercial	As-Built	SW
12/10/2024	1913-C CHURCHVILLE RD	Residential	Construction	SW
12/10/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
12/10/2024	1111 VALE RD	Residential	Maintenance	SC
12/10/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
12/10/2024	1307 GOVERNOR CT	Commercial	Maintenance	SC
12/10/2024	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/10/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
12/10/2024	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
12/10/2024	4370 NORRISVILLE RD	Residential	Maintenance	SC
12/10/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
12/10/2024	781 PRIESTFORD RD	Residential	Maintenance	SC
12/10/2024	215 KENNARD AVE	Residential	Maintenance	SC
12/10/2024	2309 SNOW RD	Residential	Maintenance	SC
12/10/2024	2008 PULASKI HWY		Complaint	SC
12/10/2024	2720 ADY RD	Residential	Final	SC
12/10/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
12/10/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
12/10/2024	2248 GIBSON RD	Residential	Maintenance	SC
12/10/2024	2421 HARKINS RD	Residential	Maintenance	SC
12/10/2024	2246 GIBSON RD	Residential	Maintenance	SC
12/10/2024	5640 LONG CORNER RD	Residential	Maintenance	SC
12/11/2024	330 ENFIELD RD	Subdivision	Maintenance	SC
12/11/2024	2208 CONNOLLY RD	Commercial	Maintenance	SC
12/11/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
12/11/2024	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
12/11/2024	1035 JOPPA RD	Commercial	Complaint	SC
12/11/2024	2113 NUTTAL AVE	Subdivision	Maintenance	SC
12/11/2024	2101 GLEN COVE RD	Residential	Maintenance	SC
12/11/2024	2718 ADY RD	Residential	Maintenance	SC
12/11/2024	2350 CONOWINGO RD	Institutional	Complaint	SC
12/11/2024	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
12/11/2024	0 HANSON RD	Subdivision	Maintenance	SC
12/12/2024	1905 ROCKSPRING RD	Commercial	Maintenance	SC
12/12/2024	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
12/12/2024	2101 GLEN COVE RD	Residential	Construction	SW
12/12/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC
12/12/2024	2301 RUTLEDGE RD		Final	SC
12/12/2024	2837 MOORES RD		Final	SC
12/12/2024	0 Surf Scoter LA	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/12/2024	2503 S TOLLGATE RD	Commercial	Maintenance	SC
12/12/2024	2121 DEADORA RD	Residential	Final	SC
12/12/2024	2013 PACKARD DR	Residential	Maintenance	SC
12/12/2024	1307 GOVERNOR CT	Commercial	As-Built	SW
12/13/2024	1225 BUSH RD	Residential	Maintenance	SC
12/13/2024	3727 Old Federal Hill Road	Residential	Maintenance	SC
12/13/2024	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
12/13/2024	2509 PORT LN	Subdivision	Maintenance	SC
12/13/2024	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
12/13/2024	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Reinspection	SC
12/13/2024	0 PURPLE PL	Subdivision	Maintenance	SC
12/13/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
12/13/2024	1373 TRAPPE RD	Residential	Maintenance	SC
12/13/2024	4800 OLD PHILADELPHIA RD	Subdivision	Reinspection	SC
12/16/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
12/16/2024	417-A Calvary RD	Residential	Maintenance	SC
12/16/2024	3146 OLD YORK RD	Residential	Maintenance	SC
12/16/2024	3616 ADY RD	Residential	Maintenance	SC
12/16/2024	2111 CONNOLLY RD	Residential	Request As-Built	SW
12/16/2024	2115 CONNOLLY RD	Residential	Request As-Built	SW
12/16/2024	617 MAHAN RD	Residential	Maintenance	SC
12/16/2024	119 HOPEWELL RD	Residential	Maintenance	SC
12/16/2024	2025 CASTLETON RD	Residential	Final	SC
12/16/2024	2109 CONNOLLY RD	Residential	Maintenance	SW
12/16/2024	1408 THOMAS RUN RD	Residential	Maintenance	SC
12/16/2024	100 KEARNEY DR	Capital Project	Maintenance	SC
12/16/2024	3144 OLD YORK RD	Residential	Maintenance	SC
12/16/2024	1410 THOMAS RUN RD	Residential	Maintenance	SC
12/16/2024	1603 BULLS LN	Residential	Maintenance	SC
12/16/2024	2107 CONNOLLY RD	Residential	Request As-Built	SW
12/16/2024	4260 FEDERAL HILL RD	Institutional	Maintenance	SC
12/16/2024	40 FORT HOYLE RD	Commercial	Maintenance	SC
12/16/2024	2103 CONNOLLY RD	Residential	Request As-Built	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/16/2024	34 MC DERMOTT RD	Residential	Maintenance	SC
12/16/2024	3538 ALDINO RD	Commercial	Maintenance	SC
12/16/2024	20 FORT HOYLE RD	Residential	Maintenance	SC
12/16/2024	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
12/16/2024	2013 SCHUSTER RD	Residential	Maintenance	SC
12/16/2024	3026 SNAKE LN	Residential	Maintenance	SC
12/16/2024	0 HYSSOP CT	Residential	Final	SW
12/16/2024	0 HYSSOP CT		Final	SW
12/16/2024	0 HYSSOP CT		Conversion	SW
12/17/2024	1501 PERRYMAN RD	Commercial		SC
12/17/2024	0 ARDEN DR	Subdivision	Maintenance	SC
12/17/2024	2248 GIBSON RD	Residential	Maintenance	SC
12/17/2024	2239 ENGLE RD	Residential	Approval	SC
12/17/2024	212 FINNEY AVE			SC
12/17/2024	3314 ABINGDON RD	Commercial	Maintenance	SC
12/17/2024	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
12/17/2024	529 PRITT LN	Residential	Maintenance	SC
12/17/2024	212 FINNEY AVE		Complaint	SC
12/17/2024	16 ROCKDALE AVE	Residential	Maintenance	SC
12/17/2024	2822 CHARLES ST	Residential	Maintenance	SC
12/17/2024	1203 TECHNOLOGY DR	Commercial		SC
12/17/2024	2822 CHARLES ST	Residential	Maintenance	SC
12/17/2024	604 SUGAR HILL RD	Residential	Maintenance	SC
12/17/2024	2246 GIBSON RD	Residential	Final	SC
12/18/2024	1301 GOVERNOR CT	Commercial	Maintenance	SC
12/18/2024	1934 PLEASANTVILLE RD	Residential	Final	SC
12/18/2024	607-E DEMBYTOWN RD	Residential	Maintenance	SC
12/18/2024	0 CHELSEA RD	Commercial	Maintenance	SC
12/18/2024	1203 TECHNOLOGY DR	Commercial	Complaint	SC
12/18/2024	4624 MERCEDES DR	Commercial	Maintenance	SC
12/18/2024	2013 PACKARD DR	Residential	Maintenance	SC
12/18/2024	331 MARINA AVE	Residential	Maintenance	SC
12/18/2024	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/18/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
12/18/2024	3808 SEWELL RD	Residential	Maintenance	SC
12/18/2024	2014 PACKARD DR	Residential	Maintenance	SC
12/18/2024	508 PULASKI HWY	Commercial	Maintenance	SC
12/18/2024	1934 PLEASANTVILLE RD	Residential	Construction	SW
12/18/2024	1319 PERRYMAN RD	Commercial	Maintenance	SC
12/18/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
12/18/2024	0 HANSON RD	Subdivision	Maintenance	SC
12/19/2024	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
12/19/2024	3532 MILLER RD	Residential	Maintenance	SC
12/19/2024	0 VAN BIBBER RD	Commercial	Maintenance	SC
12/19/2024	913 FAWN CT		Pre-Con	SW
12/19/2024	3040 LEVEL RD	Residential	Installation	SC
12/19/2024	0 GRAVEL HILL RD	Commercial	Maintenance	SC
12/19/2024	2205 WILLOUGHBY BEACH RD	Residential	Reinspection	SC
12/19/2024	319 COOLEY MILL RD	Residential	Maintenance	SC
12/19/2024	1408 THOMAS RUN RD	Residential - Single	Construction	SW
12/19/2024	0 SHINGLE OAK CT	Residential		SC
12/19/2024	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
12/19/2024	0 MANTLEWOOD WAY	Subdivision	Maintenance	SC
12/19/2024	2800 E MEDICAL HALL RD	Residential	Maintenance	SC
12/19/2024	2626 TALL OAKS DR	Subdivision	Maintenance	SC
12/19/2024	2110 BEL AIR RD	Commercial	Maintenance	SC
12/19/2024	598 MOUNTAIN RD	Residential	Maintenance	SC
12/19/2024	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
12/19/2024	1111 VALE RD	Residential	Maintenance	SC
12/19/2024	913 FAWN CT		Pre-Inspection	SC
12/19/2024	3532 MILLER RD	Residential		SC
12/20/2024	904 EDGEWOOD RD	Commercial	Maintenance	SC
12/20/2024	300 PULASKI HWY	Commercial	Maintenance	SC
12/20/2024	1127 Belcamp Garth	Capital Project	Maintenance	SC
12/20/2024	2809 BELCAMP RD	Residential	Maintenance	SC
12/20/2024	800 W Jarrettsville RD	Residential		SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/20/2024	2301 RUTLEDGE RD			SC
12/20/2024	40 FORT HOYLE RD	Commercial	Reinspection	SC
12/20/2024	354 OLD BAY LN	Commercial	Maintenance	SC
12/20/2024	2509 PORT LN	Subdivision	Maintenance	SC
12/20/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
12/20/2024	2121 DEADORA RD	Residential		SC
12/20/2024	2837 MOORES RD			SC
12/20/2024	1605 ALGONQUIN CT	Residential	Maintenance	SC
12/20/2024	2201 OLD JOPPA RD	Residential	Maintenance	SC
12/20/2024	1827 BALDWIN MILL RD	Residential	Maintenance	SC
12/20/2024	5129 FAWN GROVE RD	Residential	Maintenance	SC
12/20/2024	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
12/20/2024	3801 PEACH ORCHARD RD	Institutional	Approval	SC
12/20/2024	812 OLD JOPPA RD	Residential	Maintenance	SC
12/20/2024	2600 TOBIN CROSSING	Commercial	Maintenance	SC
12/20/2024	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
12/20/2024	2008 PULASKI HWY			SC
12/22/2024	Inspection Number: ESCCI-061445-2024	Commercial	Reinspection	SC
12/22/2024	3333 JAMES RUN RD	Residential	Reinspection	SC
12/23/2024	3205 SUDATH LN	Residential	Maintenance	SC
12/23/2024	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
12/23/2024	2014 EMMORTON RD	Subdivision	Maintenance	SC
12/23/2024	1655 Robin CIR	Commercial		SW
12/23/2024	Inspection Number: 064302-2024	Capital Project	Maintenance	SC
12/23/2024	2205 JACK LN	Residential	Maintenance	SC
12/23/2024	1812 WALTON RD	Commercial	Maintenance	SC
12/23/2024	805 THOMAS RUN RD	Residential - Single	Maintenance	SW
12/23/2024	1609 HEIMS LN	Residential	Complaint	SC
12/23/2024	805 THOMAS RUN RD	Residential	Installation	SC
12/23/2024	104 MOONLIGHT DR	Subdivision	Maintenance	SC
12/23/2024	2300 EDWARDS LN	Residential	Maintenance	SC
12/23/2024	1714 RIDGE RD	Residential	Maintenance	SC
12/23/2024	0 CARRS MILL RD	Capital Project	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/23/2024	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
12/23/2024	3205 SUDATH LN	Residential		SW
12/23/2024	805 THOMAS RUN RD	Residential	Maintenance	SC
12/23/2024	2010 MOUNTAIN RD	Commercial	Complaint	SC
12/23/2024	0 CEDAR DR	Commercial	Maintenance	SC
12/23/2024	781 PRIESTFORD RD	Residential	Maintenance	SC
12/24/2024	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
12/24/2024	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
12/24/2024	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
12/26/2024	2718 ADY RD	Residential	Complaint	SC
12/26/2024	0 MARINER RD		Maintenance	SW
12/26/2024	2020 PACKARD DR	Subdivision	Maintenance	SC
12/26/2024	2113 NUTTAL AVE	Subdivision	Maintenance	SC
12/26/2024	5640 LONG CORNER RD	Residential	Maintenance	SC
12/26/2024	2101 GLEN COVE RD	Residential	Maintenance	SC
12/26/2024	0 LAUREL BUSH RD	Residential	Maintenance	SC
12/26/2024	2013 SCHUSTER RD	Residential - Single	Request As-Built	SW
12/26/2024	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
12/26/2024	0 ARDEN DR	Subdivision	Maintenance	SC
12/26/2024	741 HOOKERS MILL RD	Residential	Complaint	SC
12/26/2024	330 ENFIELD RD	Subdivision	Maintenance	SC
12/26/2024	1373 TRAPPE RD	Residential	Maintenance	SC
12/26/2024	2215 CRESWELL RD			SW
12/26/2024	2509 MOUNTAIN RD	Residential	Maintenance	SC
12/26/2024	2014 PACKARD DR	Residential	Maintenance	SC
12/26/2024	2350 CONOWINGO RD	Institutional	Complaint	SC
12/26/2024	3632 PROSPECT RD	Residential	Approval	SC
12/26/2024	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
12/26/2024	5640 LONG CORNER RD	Residential - Single	Maintenance	SW
12/26/2024	0 OATGRASS CT	Residential	Maintenance	SW
12/27/2024	0 MAGNOLIA RD	Forested	Reinspection	SC
12/27/2024	3727 Old Federal Hill Road	Residential	Maintenance	SC
12/27/2024	1225 BUSH RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/27/2024	2215 CRESWELL RD	Institutional	Maintenance	SC
12/27/2024	401 THOMAS RUN RD	Institutional	Maintenance	SC
12/27/2024	1111 VALE RD	Residential	Maintenance	SC
12/27/2024	3532 MILLER RD	Residential	Maintenance	SC
12/27/2024	0 Surf Scoter LA	Subdivision	Maintenance	SC
12/27/2024	0 HARLING CT		Final	SC
12/27/2024	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
12/27/2024	0 PURPLE PL	Subdivision	Maintenance	SC
12/27/2024	2421 HARKINS RD	Residential	Maintenance	SC
12/27/2024	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
12/27/2024	1702 MOONRIVER CT	Subdivision	Maintenance	SC
12/27/2024	100 THOMAS RUN RD	Institutional	Maintenance	SC
12/27/2024	1203 TECHNOLOGY DR	Commercial	Reinspection	SC
12/30/2024	3538 ALDINO RD	Commercial	Maintenance	SC
12/30/2024	2626 TALL OAKS DR	Subdivision	Maintenance	SC
12/30/2024	2003 LAUREL BROOK RD	Residential	Maintenance	SC
12/30/2024	2205 WILLOUGHBY BEACH RD	Residential	Reinspection	SC
12/30/2024	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
12/30/2024	20 FORT HOYLE RD	Residential	Maintenance	SC
12/30/2024	10 MC GREGOR WAY	Residential	Maintenance	SC
12/30/2024	1603 BULLS LN	Residential	Maintenance	SC
12/30/2024	1623 SHADY TREE CT	Subdivision	Maintenance	SC
12/30/2024	2350 CONOWINGO RD	Institutional	Maintenance	SC
12/30/2024	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
12/30/2024	100 KEARNEY DR	Capital Project	Maintenance	SW
12/30/2024	100 KEARNEY DR	Capital Project	Maintenance	SC
12/30/2024	617 MAHAN RD	Residential	Maintenance	SC
12/30/2024	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
12/30/2024	40 FORT HOYLE RD	Commercial	Maintenance	SC
12/30/2024	0 HANSON RD	Subdivision	Maintenance	SC
12/30/2024	2208 CONNOLLY RD	Commercial	Maintenance	SC
12/30/2024	0 CONNOLLY RD	Subdivision	Maintenance	SC
12/30/2024	4998 JOLLY ACRES RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
12/30/2024	2115 CONNOLLY RD	Residential		SW
12/30/2024	2107 CONNOLLY RD	Residential		SW
12/31/2024	5129 FAWN GROVE RD	Residential	Request As-Built	SW
1/1/2025	1410 THOMAS RUN RD	Residential	Maintenance	SW
1/1/2025	4370 NORRISVILLE RD	Residential	Maintenance	SC
1/1/2025	3616 ADY RD	Residential	Maintenance	SC
1/1/2025	1373 TRAPPE RD	Residential	Maintenance	SC
1/1/2025	854 STANSBURY RD	Residential	Maintenance	SC
1/1/2025	1373 TRAPPE RD	Residential - Single	Maintenance	SW
1/1/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
1/1/2025	3146 OLD YORK RD	Residential	Maintenance	SC
1/1/2025	3632 PROSPECT RD	Residential	Maintenance	SC
1/1/2025	3144 OLD YORK RD	Residential	Maintenance	SC
1/1/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
1/2/2025	119 HOPEWELL RD	Residential - Single	Construction	SW
1/2/2025	2503 S TOLLGATE RD	Commercial	Maintenance	SC
1/2/2025	904 EDGEWOOD RD	Commercial	Maintenance	SC
1/2/2025	331 MARINA AVE	Residential	Maintenance	SC
1/2/2025	2013 PACKARD DR	Residential	Maintenance	SC
1/2/2025	2248 GIBSON RD	Residential	Maintenance	SC
1/2/2025	1934 PLEASANTVILLE RD	Residential	Request As-Built	SW
1/2/2025	119 HOPEWELL RD	Residential	Maintenance	SC
1/2/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
1/2/2025	608 PHILADELPHIA RD	Commercial	Pre-Inspection	SC
1/2/2025	1934 PLEASANTVILLE RD	Residential		SC
1/2/2025	1007 PROSPECT MILL RD	Residential - Single	Request As-Built	SW
1/2/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
1/2/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
1/2/2025	2101 CONNOLLY RD	Residential		SW
1/2/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
1/2/2025	0 OATGRASS CT	Residential	Maintenance	SW
1/2/2025	2035 CONNOLLY RD	Residential		SW
1/2/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
1/2/2025	913 FAWN CT		Maintenance	SC
1/2/2025	300 PULASKI HWY	Commercial	Maintenance	SC
1/2/2025	1319 PERRYMAN RD	Commercial	Maintenance	SC
1/2/2025	0 CHELSEA RD	Commercial	Maintenance	SC
1/2/2025	212 FINNEY AVE			SC
1/2/2025	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
1/2/2025	0 VAN BIBBER RD	Commercial	As-Built	SW
1/3/2025	5129 FAWN GROVE RD	Residential	Maintenance	SC
1/3/2025	2688 COMPROMISE ST	Commercial	Construction	SW
1/3/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
1/3/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
1/3/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
1/3/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
1/3/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
1/3/2025	529 PRITT LN	Residential	Maintenance	SC
1/3/2025	0 ARDEN DR	Subdivision	Maintenance	SC
1/3/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
1/6/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
1/6/2025	212 FINNEY AVE			SC
1/6/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
1/6/2025	2509 PORT LN	Subdivision	Maintenance	SC
1/6/2025	2110 BEL AIR RD	Commercial	Maintenance	SC
1/6/2025	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
1/6/2025	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
1/6/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Complaint	SC
1/7/2025	2000 CALVARY RD	Commercial	Maintenance	SC
1/7/2025	2205 WILLOUGHBY BEACH RD	Residential	Maintenance	SC
1/7/2025	Inspection Number: 067010-2024	Capital Project	Maintenance	SC
1/7/2025	215 KENNARD AVE	Residential	Maintenance	SC
1/7/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
1/7/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
1/7/2025	1812 WALTON RD	Commercial	Maintenance	SC
1/7/2025	0 NUTTAL AVE	Capital Project	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
1/7/2025	0 CEDAR DR	Commercial	Maintenance	SC
1/7/2025	2014 PACKARD DR	Residential	Maintenance	SC
1/8/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
1/8/2025	2205 JACK LN	Residential	Maintenance	SC
1/8/2025	1913-C CHURCHVILLE RD	Residential		SW
1/8/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
1/8/2025	1307 GOVERNOR CT	Commercial	Maintenance	SC
1/8/2025	354 OLD BAY LN	Commercial	Maintenance	SC
1/8/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
1/8/2025	2309 SNOW RD	Residential	Maintenance	SC
1/8/2025	2809 BELCAMP RD	Residential	Maintenance	SC
1/8/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
1/8/2025	3040 LEVEL RD	Residential	Maintenance	SC
1/8/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
1/8/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
1/8/2025	2300 EDWARDS LN	Residential	Maintenance	SC
1/8/2025	Inspection Number: 001160-2025	Residential	Pre-Con	SW
1/8/2025	0 HANSON RD	Subdivision	Maintenance	SC
1/9/2025	4370 NORRISVILLE RD	Residential	Maintenance	SC
1/9/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
1/9/2025	2215 CRESWELL RD	Institutional	Maintenance	SC
1/9/2025	1212 CHELSEA RD	Capital Project	Pre-Inspection	SC
1/9/2025	1714 RIDGE RD	Residential	Maintenance	SC
1/9/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
1/9/2025	3532 MILLER RD	Residential	Maintenance	SC
1/9/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
1/9/2025	0 CARRS MILL RD	Capital Project	Maintenance	SC
1/9/2025	319 COOLEY MILL RD	Residential	Maintenance	SC
1/9/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
1/9/2025	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
1/9/2025	2003 LAUREL BROOK RD	Residential	Maintenance	SC
1/9/2025	0 PURPLE PL	Subdivision	Maintenance	SC
1/10/2025	2611 CHESTNUT HILL RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
1/10/2025	1203 TECHNOLOGY DR	Commercial		SC
1/10/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
1/10/2025	508 PULASKI HWY	Commercial	Maintenance	SC
1/10/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
1/10/2025	3808 SEWELL RD	Residential	Maintenance	SC
1/10/2025	1225 BUSH RD	Residential	Maintenance	SC
1/10/2025	1035 JOPPA RD	Commercial	Reinspection	SC
1/10/2025	1111 VALE RD	Residential	Maintenance	SC
1/10/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
1/10/2025	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
1/10/2025	1702 MOONRIVER CT	Subdivision	Maintenance	SC
1/10/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
1/10/2025	0 HARLING CT			SC
1/10/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
1/13/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
1/13/2025	2718 ADY RD	Residential	Maintenance	SC
1/13/2025	1603 BULLS LN	Residential	Maintenance	SC
1/13/2025	3727 Old Federal Hill Road	Residential	Maintenance	SC
1/13/2025	2315 BEL AIR RD	Commercial	Maintenance	SC
1/13/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
1/13/2025	0 YEARLING DR	Subdivision	Maintenance	SC
1/13/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
1/13/2025	2421 HARKINS RD	Residential	Maintenance	SC
1/13/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
1/13/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
1/13/2025	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
1/13/2025	5640 LONG CORNER RD	Residential	Maintenance	SC
1/13/2025	0 CONNOLLY RD	Subdivision	Maintenance	SC
1/13/2025	0 WALTER WARD BLVD			SC
1/13/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
1/13/2025	3158 OLD FORGE HILL RD		Maintenance	SC
1/13/2025	2205 JACK LN	Residential	As-Built	SW
1/13/2025	1525 PHILADELPHIA BLVD	Commercial	As-Built	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
1/13/2025	1111 VALE RD	Residential	Construction	SW
1/13/2025	4612 MERCEDES DR		Maintenance	SW
1/14/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
1/14/2025	2809 BELCAMP RD	Residential		SC
1/14/2025	119 HOPEWELL RD	Residential		SC
1/14/2025	2014 EMMORTON RD	Subdivision	Maintenance	SC
1/14/2025	2103 CONNOLLY RD	Residential		SW
1/14/2025	741 HOOKERS MILL RD	Residential	Complaint	SC
1/14/2025	2111 CONNOLLY RD	Residential		SW
1/14/2025	1615 INGLESIDE RD	Residential	Maintenance	SC
1/14/2025	711 PHILADELPHIA RD	Commercial	Complaint	SC
1/14/2025	1525 PHILADELPHIA BLVD	Commercial	As-Built	SW
1/14/2025	3727 Old Federal Hill Road	Residential	Maintenance	SC
1/14/2025	904 EDGEWOOD RD	Commercial	Maintenance	SC
1/14/2025	854 STANSBURY RD	Residential	Maintenance	SC
1/14/2025	100 KEARNEY DR	Capital Project	Maintenance	SC
1/14/2025	1452 STAFFORD RD	Institutional	Maintenance	SC
1/14/2025	331 MARINA AVE	Residential	Reinspection	SC
1/14/2025	672 ROCK SPRING CHURCH RD	Residential - Single	Construction	SW
1/14/2025	2110 BEL AIR RD	Commercial	As-Built	SW
1/14/2025	2589 MEDICAL HALL RD	Residential - Single	As-Built	SW
1/15/2025	617 MAHAN RD	Residential	Maintenance	SC
1/15/2025	300 PULASKI HWY	Commercial	Maintenance	SC
1/15/2025	0 ARDEN DR	Subdivision	Maintenance	SC
1/15/2025	617 MAHAN RD	Residential - Single	Construction	SW
1/15/2025	2626 TALL OAKS DR	Subdivision	Maintenance	SC
1/15/2025	852 STANSBURY RD	Residential	Maintenance	SC
1/15/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
1/15/2025	2208 KALMIA RD	Residential	Maintenance	SC
1/15/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
1/15/2025	2503 S TOLLGATE RD	Commercial	Maintenance	SC
1/15/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
1/15/2025	1623 SHADY TREE CT	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
1/15/2025	5125 CAREA RD	Residential	Maintenance	SC
1/15/2025	1657 Robin CIR	Commercial	As-Built	SW
1/15/2025	2215 CRESWELL RD		As-Built	SW
1/15/2025	615 SCHUCKS RD	Residential	As-Built	SW
1/16/2025	1714 RIDGE RD	Residential		SW
1/16/2025	1934 PLEASANTVILLE RD	Residential		SW
1/16/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
1/16/2025	0 VAN BIBBER CT	Residential	Pre-Con	SW
1/16/2025	0 CHELSEA RD	Commercial	Maintenance	SC
1/16/2025	115 INDUSTRY LN		Request As-Built	SW
1/16/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
1/16/2025	3040 LEVEL RD			SW
1/16/2025	2014 PACKARD DR		Construction	SW
1/16/2025	2013 SCHUSTER RD	Residential	Maintenance	SC
1/16/2025	115 INDUSTRY LN	Commercial	Final	SC
1/16/2025	0 VAN BIBBER RD	Residential	Pre-Inspection	SC
1/16/2025	1212 CHELSEA RD	Capital Project		SC
1/16/2025	913 FAWN CT		Maintenance	SC
1/16/2025	0 HANSON RD	Subdivision	Maintenance	SC
1/17/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
1/17/2025	401 THOMAS RUN RD	Government / Institutional	Construction	SW
1/17/2025	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
1/17/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
1/17/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
1/17/2025	1373 TRAPPE RD	Residential	Maintenance	SC
1/17/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
1/17/2025	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
1/17/2025	529 PRITT LN	Residential	Maintenance	SC
1/17/2025	4998 JOLLY ACRES RD	Residential	Maintenance	SC
1/17/2025	401 THOMAS RUN RD	Institutional	Maintenance	SC
1/17/2025	100 THOMAS RUN RD	Institutional	Maintenance	SC
1/17/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
1/17/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
1/20/2025	0 CEDAR DR	Commercial	Maintenance	SC
1/20/2025	1812 WALTON RD	Commercial	Maintenance	SC
1/20/2025	215 KENNARD AVE	Residential	Maintenance	SC
1/21/2025	2239 ENGLE RD	Residential	Maintenance	SC
1/21/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
1/21/2025	354 OLD BAY LN	Commercial	Maintenance	SC
1/21/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
1/21/2025	2013 SCHUSTER RD		As-Built	SW
1/21/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
1/21/2025	2309 SNOW RD	Residential	Maintenance	SC
1/21/2025	319 COOLEY MILL RD	Residential	Maintenance	SC
1/21/2025	1015 PULASKI HWY	Commercial	Maintenance	SC
1/21/2025	2509 PORT LN	Subdivision	Maintenance	SC
1/21/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
1/21/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
1/21/2025	2205 WILLOUGHBY BEACH RD	Residential	Maintenance	SC
1/22/2025	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
1/22/2025	2110 BEL AIR RD	Commercial	Maintenance	SC
1/22/2025	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
1/22/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
1/22/2025	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
1/22/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
1/22/2025	781 PRIESTFORD RD	Residential	Maintenance	SC
1/22/2025	3532 MILLER RD	Residential - Single	Maintenance	SW
1/22/2025	0 ARDEN DR	Subdivision	Maintenance	SC
1/22/2025	3040 LEVEL RD	Residential	Maintenance	SC
1/22/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
1/22/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
1/22/2025	508 PULASKI HWY	Commercial	Maintenance	SC
1/22/2025	854 STANSBURY RD	Residential - Single	Request As-Built	SW
1/22/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
1/22/2025	1408 THOMAS RUN RD	Residential - Single	Maintenance	SW
1/22/2025	1609 HEIMS LN	Residential	Complaint	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
1/22/2025	2409 HARFORD RD	Residential	As-Built	SW
1/23/2025	0 PURPLE PL	Subdivision	Maintenance	SC
1/23/2025	3146 OLD YORK RD	Residential	Maintenance	SC
1/23/2025	2000 CALVARY RD	Commercial	Maintenance	SC
1/23/2025	3144 OLD YORK RD	Residential	Maintenance	SC
1/23/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
1/23/2025	1623 SHADY TREE CT	Subdivision	Maintenance	SC
1/23/2025	2010 MOUNTAIN RD	Commercial	Complaint	SC
1/23/2025	Inspection Number: 001382-2025	Capital Project	Maintenance	SC
1/23/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
1/23/2025	2014 PACKARD DR	Residential	Maintenance	SC
1/23/2025	2013 PACKARD DR	Residential	Maintenance	SC
1/23/2025	417-A Calvary RD	Residential	Maintenance	SC
1/23/2025	4370 NORRISVILLE RD	Residential	Maintenance	SC
1/23/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
1/23/2025	5129 FAWN GROVE RD	Residential	Maintenance	SC
1/23/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
1/23/2025	3026 SNAKE LN	Residential	Maintenance	SC
1/23/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
1/23/2025	Inspection Number: 003750-2025	Capital Project	Maintenance	SC
1/23/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
1/23/2025	0 HANSON RD	Subdivision	Maintenance	SC
1/24/2025	115 INDUSTRY LN	Commercial		SC
1/24/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
1/24/2025	2205 JACK LN	Residential	Maintenance	SC
1/24/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
1/24/2025	3808 SEWELL RD	Residential	Maintenance	SC
1/24/2025	3616 ADY RD	Residential	Approval	SC
1/24/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
1/24/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
1/24/2025	2300 EDWARDS LN	Residential	Maintenance	SC
1/24/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
1/24/2025	3538 ALDINO RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
1/24/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
1/24/2025	617 MAHAN RD	Residential	Maintenance	SC
1/24/2025	1725 O'CONNER RD	Residential	Maintenance	SC
1/24/2025	1212 CHELSEA RD	Capital Project	Maintenance	SC
1/24/2025	805 THOMAS RUN RD	Residential	Approval	SC
1/24/2025	1225 BUSH RD	Residential	Maintenance	SC
1/24/2025	119 HOPEWELL RD	Residential		SC
1/27/2025	2003 LAUREL BROOK RD	Residential	Maintenance	SC
1/27/2025	0 MAGNOLIA RD	Forested	Maintenance	SC
1/27/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
1/27/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
1/27/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
1/27/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
1/27/2025	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
1/27/2025	1111 VALE RD	Residential	Maintenance	SC
1/27/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
1/27/2025	1603 BULLS LN	Residential	Maintenance	SC
1/27/2025	1603 BULLS LN	Residential - Single	Maintenance	SW
1/28/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Complaint	SC
1/28/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
1/28/2025	2300 PUTNAM RD			SW
1/28/2025	904 EDGEWOOD RD	Commercial	Maintenance	SC
1/28/2025	1106 WALTERS MILL RD	Residential	Final	SC
1/28/2025	604 SUGAR HILL RD	Residential - Single	Pre-Con	SW
1/28/2025	101 CHERRY HILL RD	Commercial	Maintenance	SC
1/28/2025	100 KEARNEY DR	Capital Project	Maintenance	SC
1/28/2025	2809 BELCAMP RD	Residential	Maintenance	SC
1/28/2025	2215 CRESWELL RD	Institutional	Maintenance	SC
1/28/2025	119 HOPEWELL RD	Residential	Maintenance	SC
1/28/2025	3632 PROSPECT RD	Residential	Maintenance	SC
1/28/2025	604 SUGAR HILL RD	Residential	Pre-Inspection	SC
1/28/2025	0 CONNOLLY RD	Subdivision	Maintenance	SC
1/28/2025	331 MARINA AVE	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
1/28/2025	741 HOOKERS MILL RD	Residential	Complaint	SC
1/28/2025	711 PHILADELPHIA RD	Commercial	Maintenance	SC
1/29/2025	1452 STAFFORD RD	Institutional	Final	SC
1/29/2025	1300 BUSINESS CENTER WAY		Pre-Con	SW
1/29/2025	338 EARLTON RD	Residential	Maintenance	SC
1/29/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
1/29/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
1/29/2025	2626 TALL OAKS DR	Subdivision	Maintenance	SC
1/29/2025	3935 PROSPECT RD	Residential	Maintenance	SC
1/29/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
1/29/2025	1300 BUSINESS CENTER WAY		Pre-Inspection	SC
1/29/2025	0 CARRS MILL RD	Capital Project	Maintenance	SC
1/29/2025	0 ARDEN DR	Subdivision	Reinspection	SC
1/29/2025	854 STANSBURY RD	Residential	Maintenance	SC
1/29/2025	5125 CAREA RD	Residential	Maintenance	SC
1/29/2025	852 STANSBURY RD	Residential	Maintenance	SC
1/29/2025	2208 KALMIA RD	Residential	Maintenance	SC
1/29/2025	5129 FAWN GROVE RD	Residential		SW
1/29/2025	103 MATTE LN	Residential - Single	Pre-Con	SW
1/29/2025	103 MATTE LN	Residential	Pre-Inspection	SC
1/29/2025	103 KENNARD AVE	Residential	Complaint	SC
1/29/2025	300 PULASKI HWY	Commercial	Maintenance	SC
1/29/2025	2215 CHURCHVILLE RD	Commercial	Pre-Inspection	SC
1/29/2025	0 HANSON RD	Subdivision	Maintenance	SC
1/30/2025	1212 CHELSEA RD	Capital Project	Installation	SC
1/30/2025	913 FAWN CT		Maintenance	SC
1/30/2025	0 SPRUCE PINE RD	Residential	Maintenance	SW
1/30/2025	4624 MERCEDES DR	Commercial	Maintenance	SC
1/30/2025	0 OATGRASS CT	Residential	Maintenance	SW
1/30/2025	0 LAUREL BUSH RD	Residential	Maintenance	SC
1/30/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
1/30/2025	755 CHELSEA RD	Commercial		SW
1/30/2025	0 CHELSEA RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
1/30/2025	0 IRON OAK CT	Residential	Maintenance	SW
1/30/2025	405 DAVIS RD	Residential		SC
1/30/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
1/30/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
1/30/2025	0 OATGRASS CT	Residential	Maintenance	SW
1/31/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
1/31/2025	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
1/31/2025	1121 DEER CREEK CHURCH RD	Residential - Single	Maintenance	SW
1/31/2025	529 PRITT LN	Residential	Maintenance	SC
1/31/2025	3144 OLD YORK RD	Residential	Maintenance	SC
1/31/2025	401 THOMAS RUN RD	Institutional	Maintenance	SC
1/31/2025	3205 SUDATH LN	Residential	Maintenance	SC
1/31/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
1/31/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
1/31/2025	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
1/31/2025	2503 S TOLLGATE RD	Commercial	Maintenance	SC
1/31/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
1/31/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
1/31/2025	2800 E MEDICAL HALL RD	Residential	Maintenance	SC
1/31/2025	730 BURNSIDE DR			SC
1/31/2025	1913-C CHURCHVILLE RD	Residential	Request As-Built	SW
1/31/2025	331 MARINA AVE	Residential	Maintenance	SC
1/31/2025	103 KENNARD AVE	Residential	Complaint	SC
1/31/2025	STILLMEADOW STREAM			SC
1/31/2025	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
1/31/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
2/2/2025	1319 PERRYMAN RD	Commercial	Maintenance	SC
2/3/2025	103 KENNARD AVE	Residential	Complaint	SC
2/3/2025	1501 PERRYMAN RD	Commercial	Maintenance	SC
2/3/2025	527 Pritt LA		Final	SC
2/3/2025	0 HARTLEY WAY	Residential	Final	SC
2/3/2025	1331 BALTIMORE PIKE	Commercial	Final	SC
2/3/2025	3333 JAMES RUN RD	Residential	Reinspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/3/2025	2024 EDEN MILL RD	Forested	Complaint	SC
2/3/2025	215 KENNARD AVE	Residential	Maintenance	SC
2/3/2025	0 ROUTE 1	Commercial	Complaint	SC
2/3/2025	1812 WALTON RD	Commercial	Maintenance	SC
2/3/2025	1702 MOONRIVER CT	Subdivision	Maintenance	SC
2/3/2025	0 CEDAR DR	Commercial	Maintenance	SC
2/3/2025	0 WHEEL RD		Final	SW
2/3/2025	0 WHEEL RD		Maintenance	SW
2/4/2025	1416 & 1418 Philadelphia Rd	Commercial	Maintenance	SC
2/4/2025	354 OLD BAY LN	Commercial	Maintenance	SC
2/4/2025	0 834 W Ring Factory Rd	Commercial	Complaint	SC
2/4/2025	2509 PORT LN	Subdivision	Maintenance	SC
2/4/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
2/4/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
2/4/2025	2309 SNOW RD	Residential	Maintenance	SC
2/4/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
2/4/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
2/4/2025	301 FOUNTAIN GREEN RD		Maintenance	SW
2/4/2025	301 FOUNTAIN GREEN RD		Maintenance	SW
2/4/2025	301 FOUNTAIN GREEN RD		Maintenance	SW
2/5/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
2/5/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
2/5/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
2/5/2025	2110 BEL AIR RD	Commercial	Maintenance	SC
2/5/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
2/5/2025	100 KEARNEY DR	Capital Project	Maintenance	SC
2/5/2025	319 COOLEY MILL RD	Residential	Maintenance	SC
2/5/2025	1007 PROSPECT MILL RD	Residential	Maintenance	SC
2/5/2025	508 PULASKI HWY	Commercial	Maintenance	SC
2/5/2025	781 PRIESTFORD RD	Residential	Maintenance	SC
2/5/2025	100 KEARNEY DR	Capital Project	Maintenance	SW
2/5/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
2/5/2025	2822 CHARLES ST	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/5/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
2/5/2025	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
2/5/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
2/5/2025	0 ARDEN DR	Subdivision	Reinspection	SC
2/5/2025	2218 ARDEN DR		Construction	SW
2/5/2025	1225 BUSH RD	Residential - Single	As-Built Received	SW
2/5/2025	0 HANSON RD	Subdivision	Maintenance	SC
2/6/2025	0 OATGRASS CT	Residential	Maintenance	SW
2/6/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
2/6/2025	Inspection Number: 004046-2025	Capital Project	Maintenance	SC
2/6/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
2/6/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
2/6/2025	3040 LEVEL RD	Residential	Maintenance	SC
2/6/2025	2013 PACKARD DR	Residential	Maintenance	SC
2/6/2025	0 PURPLE PL	Subdivision	Maintenance	SC
2/6/2025	2000 CALVARY RD	Commercial	Maintenance	SC
2/6/2025	1373 TRAPPE RD	Residential	Maintenance	SC
2/6/2025	417-A Calvary RD	Residential	Maintenance	SC
2/6/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
2/6/2025	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
2/6/2025	0 VAN BIBBER RD	Commercial	Complaint	SC
2/6/2025	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
2/6/2025	2014 PACKARD DR	Residential	Maintenance	SC
2/6/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
2/6/2025	0 LAUREL BUSH RD	Residential	Maintenance	SC
2/7/2025	3538 ALDINO RD	Commercial	Maintenance	SC
2/7/2025	18 ROCKDALE AVE	Residential - Single	Pre-Con	SW
2/7/2025	3026 SNAKE LN	Residential	Maintenance	SC
2/7/2025	3808 SEWELL RD	Residential	Maintenance	SC
2/7/2025	2300 EDWARDS LN	Residential	Maintenance	SC
2/7/2025	1225 BUSH RD	Residential	Maintenance	SC
2/7/2025	2013 PACKARD DR	Residential	Request As-Built	SW
2/7/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/7/2025	2013 SCHUSTER RD	Residential	Maintenance	SC
2/7/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
2/7/2025	5129 FAWN GROVE RD	Residential	Maintenance	SC
2/7/2025	0 CONNOLLY RD	Subdivision	Maintenance	SC
2/7/2025	2205 JACK LN	Residential	Maintenance	SC
2/7/2025	4370 NORRISVILLE RD	Residential	Maintenance	SC
2/7/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
2/7/2025	417-A Calvary RD	Residential - Single	Construction	SW
2/7/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
2/7/2025	3146 OLD YORK RD	Residential	Maintenance	SC
2/7/2025	1725 O'CONNER RD	Residential	Maintenance	SC
2/7/2025	1307 GOVERNOR CT	Commercial	Maintenance	SC
2/7/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
2/7/2025	18 ROCKDALE AVE	Residential	Pre-Inspection	SC
2/7/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
2/7/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
2/10/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
2/10/2025	805 THOMAS RUN RD	Residential	Maintenance	SC
2/10/2025	1603 BULLS LN	Residential	Maintenance	SC
2/10/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
2/10/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
2/10/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
2/10/2025	2003 LAUREL BROOK RD	Residential	Maintenance	SC
2/10/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
2/10/2025	1111 VALE RD	Residential	Maintenance	SC
2/10/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
2/10/2025	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
2/10/2025	1035 JOPPA RD	Commercial	Reinspection	SC
2/10/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
2/10/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
2/10/2025	3616 ADY RD	Residential	Maintenance	SC
2/10/2025	1212 CHELSEA RD	Capital Project	Maintenance	SC
2/10/2025	115 INDUSTRY LN	Commercial	As-Built	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/11/2025	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
2/11/2025	2503 S TOLLGATE RD	Commercial	Reinspection	SC
2/11/2025	2000 CALVARY RD	Commercial	Reinspection	SC
2/11/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
2/11/2025	741 HOOKERS MILL RD	Residential	Complaint	SC
2/11/2025	2014 EMMORTON RD	Subdivision	Reinspection	SC
2/11/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
2/11/2025	2215 CRESWELL RD	Institutional	Maintenance	SC
2/11/2025	0 CARRS MILL RD	Capital Project	Reinspection	SC
2/11/2025	4624 MERCEDES DR	Commercial	Maintenance	SC
2/11/2025	3538 ALDINO RD	Commercial	Reinspection	SC
2/11/2025	0 CARRS MILL RD	Capital Project	Maintenance	SC
2/11/2025	101 CHERRY HILL RD	Commercial	Maintenance	SC
2/11/2025	904 EDGEWOOD RD	Commercial	Maintenance	SC
2/11/2025	1111 VALE RD	Residential	Construction	SW
2/11/2025	617 MAHAN RD	Residential	Maintenance	SC
2/11/2025	711 PHILADELPHIA RD	Commercial	Complaint	SC
2/12/2025	2626 TALL OAKS DR	Subdivision	Maintenance	SC
2/12/2025	100 THOMAS RUN RD	Institutional	Maintenance	SC
2/12/2025	2809 BELCAMP RD	Residential	Maintenance	SC
2/12/2025	1623 SHADY TREE CT	Subdivision	Maintenance	SC
2/12/2025	300 PULASKI HWY		Maintenance	SC
2/12/2025	300 PULASKI HWY	Commercial		SC
2/12/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
2/12/2025	119 HOPEWELL RD	Residential	Maintenance	SC
2/12/2025	1714 RIDGE RD	Residential	Maintenance	SC
2/12/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
2/12/2025	103 MATTE LN	Residential		SC
2/12/2025	672 ROCK SPRING CHURCH RD	Residential - Single		SW
2/12/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
2/13/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
2/13/2025	1827 BALDWIN MILL RD	Residential - Single	Construction	SW
2/13/2025	854 STANSBURY RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/13/2025	0 CHELSEA RD	Commercial	Maintenance	SC
2/13/2025	4998 JOLLY ACRES RD	Residential	Maintenance	SC
2/13/2025	1615 INGLESIDE RD	Residential	Maintenance	SC
2/13/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
2/13/2025	331 MARINA AVE	Residential	Maintenance	SC
2/13/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
2/13/2025	2718 ADY RD	Residential	Maintenance	SC
2/13/2025	529 PRITT LN	Residential	Maintenance	SC
2/13/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
2/13/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
2/13/2025	5125 CAREA RD	Residential	Maintenance	SC
2/13/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
2/13/2025	852 STANSBURY RD	Residential	Maintenance	SC
2/13/2025	913 FAWN CT		Maintenance	SC
2/13/2025	0 HANSON RD	Subdivision	Maintenance	SC
2/14/2025	2350 CONOWINGO RD	Institutional	Reinspection	SC
2/14/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
2/14/2025	1007 PROSPECT MILL RD	Residential	Maintenance	SC
2/14/2025	2800 E MEDICAL HALL RD	Residential	Maintenance	SC
2/14/2025	2208 KALMIA RD	Residential	Maintenance	SC
2/14/2025	401 THOMAS RUN RD	Institutional	Maintenance	SC
2/14/2025	0 834 W Ring Factory Rd	Commercial		SC
2/14/2025	0 HARTLEY WAY	Residential		SC
2/14/2025	100 KEARNEY DR	Capital Project	Reinspection	SC
2/14/2025	3158 OLD FORGE HILL RD		Complaint	SC
2/14/2025	1373 TRAPPE RD	Residential	Maintenance	SC
2/14/2025	1929 SUSQUEHANNA HALL RD	Commercial	Approval	SC
2/14/2025	527 Pritt LA			SC
2/14/2025	115 INDUSTRY LN			SW
2/14/2025	2205 JACK LN	Residential	As-Built	SW
2/17/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
2/17/2025	215 KENNARD AVE	Residential	Maintenance	SC
2/17/2025	103 KENNARD AVE	Residential	Complaint	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/17/2025	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
2/17/2025	2300 EDWARDS LN	Residential	Maintenance	SC
2/17/2025	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
2/17/2025	1812 WALTON RD	Commercial	Maintenance	SC
2/17/2025	0 CEDAR DR	Commercial	Maintenance	SC
2/18/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
2/18/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
2/18/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
2/18/2025	2309 SNOW RD	Residential	Maintenance	SC
2/18/2025	354 OLD BAY LN	Commercial	Maintenance	SC
2/18/2025	0 NUTTAL AVE	Capital Project	Maintenance	SC
2/18/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
2/18/2025	514 JOPPA FARM RD		Complaint	SC
2/18/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
2/18/2025	2509 PORT LN	Subdivision	Maintenance	SC
2/18/2025	3144 OLD YORK RD	Residential	Maintenance	SC
2/18/2025	1319 PERRYMAN RD	Commercial	Maintenance	SC
2/18/2025	0 WHEEL RD		As-Built	SW
2/19/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
2/19/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
2/19/2025	781 PRIESTFORD RD	Residential	Maintenance	SC
2/19/2025	5640 LONG CORNER RD	Residential	Maintenance	SC
2/19/2025	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
2/19/2025	2822 CHARLES ST	Residential	Maintenance	SC
2/19/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
2/19/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
2/19/2025	0 ARDEN DR	Subdivision	Maintenance	SC
2/19/2025	508 PULASKI HWY	Commercial	Maintenance	SC
2/19/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
2/19/2025	1623 SHADY TREE CT	Subdivision	Maintenance	SC
2/19/2025	1623 SHADY TREE CT	Subdivision	Maintenance	SC
2/19/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
2/19/2025	319 COOLEY MILL RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/19/2025	3532 MILLER RD	Residential	Maintenance	SC
2/19/2025	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
2/19/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
2/19/2025	3632 PROSPECT RD	Residential	Maintenance	SC
2/19/2025	2421 HARKINS RD	Residential	Maintenance	SC
2/19/2025	1215 BALTIMORE PIKE	Commercial	Reinspection	SC
2/19/2025	0 HANSON RD	Subdivision	Maintenance	SC
2/20/2025	417-A Calvary RD	Residential	Maintenance	SC
2/20/2025	2000 CALVARY RD	Commercial	Maintenance	SC
2/20/2025	3040 LEVEL RD	Residential	Maintenance	SC
2/20/2025	3205 SUDATH LN	Residential	Maintenance	SC
2/20/2025	3146 OLD YORK RD	Residential	Maintenance	SC
2/20/2025	0 PURPLE PL	Subdivision	Maintenance	SC
2/20/2025	18 ROCKDALE AVE	Residential	Maintenance	SC
2/20/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
2/20/2025	5640 LONG CORNER RD	Residential - Single	Construction	SW
2/20/2025	854 STANSBURY RD	Residential - Single		SW
2/20/2025	852 STANSBURY RD	Residential	Construction	SW
2/20/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
2/20/2025	Inspection Number: 006551-2025	Capital Project	Maintenance	SC
2/20/2025	1615 INGLESIDE RD	Residential	Request As-Built	SW
2/20/2025	5129 FAWN GROVE RD	Residential	Maintenance	SC
2/20/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
2/20/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
2/20/2025	1408 THOMAS RUN RD	Residential - Single	Maintenance	SW
2/20/2025	2110 BEL AIR RD	Commercial	Maintenance	SC
2/21/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
2/21/2025	3026 SNAKE LN	Residential	Maintenance	SC
2/21/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
2/21/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
2/21/2025	0 MAGNOLIA RD	Commercial	Pre-Con	SW
2/21/2025	1300 BUSINESS CENTER WAY		Maintenance	SC
2/21/2025	2013 PACKARD DR	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/21/2025	1657 Robin CIR	Commercial	Maintenance	SC
2/21/2025	2013 SCHUSTER RD	Residential	Maintenance	SC
2/21/2025	0 MAGNOLIA RD		Pre-Inspection	SC
2/21/2025	3538 ALDINO RD	Commercial	Maintenance	SC
2/21/2025	3808 SEWELL RD	Residential	Maintenance	SC
2/21/2025	1225 BUSH RD	Residential	Maintenance	SC
2/21/2025	2014 PACKARD DR	Residential	Maintenance	SC
2/21/2025	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
2/21/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
2/21/2025	100 KEARNEY DR	Capital Project	Request As-Built	SW
2/24/2025	1603 BULLS LN	Residential	Maintenance	SC
2/24/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
2/24/2025	0 Connolly	Subdivision	Maintenance	SC
2/24/2025	0 CARRS MILL RD	Capital Project	Maintenance	SC
2/24/2025	2315 BEL AIR RD	Commercial	Maintenance	SC
2/24/2025	20 FORT HOYLE RD	Residential - Single	As-Built	SW
2/24/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
2/24/2025	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
2/24/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
2/24/2025	100 KEARNEY DR	Capital Project	Maintenance	SC
2/24/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
2/24/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
2/24/2025	2300 EDWARDS LN	Residential	Reinspection	SC
2/24/2025	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
2/24/2025	3538 ALDINO RD	Commercial	Construction	SW
2/24/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
2/24/2025	1702 MOONRIVER CT	Subdivision	Maintenance	SC
2/24/2025	2205 JACK LN	Residential	Maintenance	SC
2/24/2025	1609 HEIMS LN	Residential	Complaint	SC
2/24/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
2/24/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
2/24/2025	0 CONNOLLY RD	Subdivision		SC
2/24/2025	1212 CHELSEA RD	Capital Project	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/25/2025	903 OLD PYLESVILLE RD	Residential		SC
2/25/2025	4624 MERCEDES DR	Commercial	Maintenance	SC
2/25/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
2/25/2025	2010 MOUNTAIN RD	Commercial	Complaint	SC
2/25/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
2/25/2025	Inspection Number: 009704-2025	Residential	Pre-Inspection	SC
2/25/2025	755 CHELSEA RD	Commercial	Construction	SW
2/25/2025	711 PHILADELPHIA RD	Commercial	Maintenance	SC
2/25/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
2/25/2025	4624 MERCEDES DR	Commercial	Maintenance	SC
2/25/2025	2000 CALVARY RD	Commercial	Reinspection	SC
2/25/2025	1111 VALE RD	Residential	Maintenance	SC
2/25/2025	904 EDGEWOOD RD	Commercial	Maintenance	SC
2/25/2025	2503 S TOLLGATE RD	Commercial	Reinspection	SC
2/25/2025	805 THOMAS RUN RD	Residential	Maintenance	SC
2/25/2025	2003 LAUREL BROOK RD	Residential	Maintenance	SC
2/25/2025	1827 BALDWIN MILL RD	Residential - Single	Request As-Built	SW
2/26/2025	617 MAHAN RD	Residential	Maintenance	SC
2/26/2025	514 JOPPA FARM RD		Complaint	SC
2/26/2025	2809 BELCAMP RD	Residential	Maintenance	SC
2/26/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
2/26/2025	119 HOPEWELL RD	Residential	Maintenance	SC
2/26/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
2/26/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
2/26/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
2/26/2025	2000 CALVARY RD	Commercial	Reinspection	SC
2/26/2025	2215 CRESWELL RD	Institutional	Maintenance	SC
2/26/2025	3538 ALDINO RD	Commercial	Complaint	SC
2/26/2025	103 MATTE LN	Residential	Maintenance	SC
2/26/2025	300 PULASKI HWY		Maintenance	SC
2/26/2025	1300 BUSINESS CENTER WAY		Maintenance	SC
2/26/2025	2509 PORT LN	Subdivision	Reinspection	SC
2/26/2025	4525 CLERMONT MILL RD	Institutional	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/26/2025	0 HANSON RD	Subdivision	Maintenance	SC
2/27/2025	115 Magnolia Rd	Forested	Complaint	SC
2/27/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
2/27/2025	4370 NORRISVILLE RD	Residential	Maintenance	SC
2/27/2025	913 FAWN CT		Maintenance	SC
2/27/2025	331 MARINA AVE	Residential	Maintenance	SC
2/27/2025	4370 NORRISVILLE RD	Residential		SC
2/27/2025	2080 STEWART DR	Residential	Request As-Built	SW
2/27/2025	2025 WATERVALE RD	Residential	Request As-Built	SW
2/27/2025	2053 WATERVALE RD	Residential	Request As-Built	SW
2/27/2025	2049 Watervale RD	Residential	Request As-Built	SW
2/27/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
2/27/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
2/27/2025	2031 WATERVALE RD	Residential	Request As-Built	SW
2/27/2025	529 PRITT LN	Residential	Maintenance	SC
2/27/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
2/27/2025	2037 WATERVALE RD	Residential	Request As-Built	SW
2/27/2025	2626 TALL OAKS DR	Subdivision	Maintenance	SC
2/27/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
2/27/2025	Inspection Number: 010240-2025	Residential	Construction	SW
2/27/2025	2084 Stewart DR	Residential	Request As-Built	SW
2/27/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
2/28/2025	1615 INGLESIDE RD	Residential	Approval	SC
2/28/2025	1615 INGLESIDE RD	Residential	Request As-Built	SW
2/28/2025	2718 ADY RD	Residential	Maintenance	SC
2/28/2025	4998 JOLLY ACRES RD	Residential	Request As-Built	SW
2/28/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
2/28/2025	100 THOMAS RUN RD	Institutional	Maintenance	SC
2/28/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
2/28/2025	805 THOMAS RUN RD	Residential - Single	Maintenance	SW
2/28/2025	100 KEARNEY DR	Capital Project	Maintenance	SC
2/28/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
2/28/2025	2061 WATERVALE RD	Residential	Request As-Built	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
2/28/2025	4998 JOLLY ACRES RD	Residential	Maintenance	SC
2/28/2025	301 FOUNTAIN GREEN RD		Maintenance	SW
2/28/2025	1711 JARRETTSVILLE RD		Maintenance	SW
2/28/2025	900 Block Ring Factory RD W	Institutional	Complaint	SC
2/28/2025	0 ROCKS RD		Maintenance	SW
2/28/2025	301 FOUNTAIN GREEN RD		Maintenance	SW
3/3/2025	0 CEDAR DR	Commercial	Maintenance	SC
3/3/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
3/3/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
3/3/2025	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
3/3/2025	2771 ADMIRAL LN	Commercial	Construction	SW
3/3/2025	3333 JAMES RUN RD	Residential	Reinspection	SC
3/3/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
3/3/2025	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
3/3/2025	215 KENNARD AVE	Residential	Maintenance	SC
3/3/2025	1812 WALTON RD	Commercial	Maintenance	SC
3/3/2025	1915 FOUNTAIN GREEN RD	Commercial	Reinspection	SC
3/3/2025	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
3/3/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
3/3/2025	103 KENNARD AVE		Pre-Inspection	SC
3/3/2025	Inspection Number: ESCCI-056266-2023	Commercial	Maintenance	SC
3/3/2025	409-A TRIMBLE RD		Maintenance	SW
3/3/2025	409-B Trimble RD		Maintenance	SW
3/3/2025	1009 PINE RD		Maintenance	SW
3/3/2025	0 MEADOWOOD DR		Maintenance	SW
3/4/2025	2600 TOBIN CROSSING	Commercial	Complaint	SC
3/4/2025	0 Whiteford and Rocks RD	Commercial	Maintenance	SC
3/4/2025	2503 S TOLLGATE RD	Commercial	Reinspection	SC
3/4/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
3/4/2025	4024 PROSPECT RD	Residential	Maintenance	SC
3/4/2025	1501 PERRYMAN RD	Commercial	Maintenance	SC
3/4/2025	3505 BERKLEY RD	Residential	Pre-Inspection	SC
3/4/2025	3505 BERKLEY RD	Residential - Single	Pre-Con	SW

# *Inspections By Date*

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/4/2025	2309 SNOW RD	Residential	Maintenance	SC
3/4/2025	812 OLD JOPPA RD	Residential	Reinspection	SC
3/4/2025	101 CHERRY HILL RD	Commercial	Maintenance	SC
3/4/2025	2300 EDWARDS LN	Residential	Reinspection	SC
3/4/2025	1015 PULASKI HWY	Commercial	Maintenance	SC
3/4/2025	900 Block Ring Factory RD W	Institutional	Reinspection	SC
3/4/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
3/4/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
3/4/2025	2014 EMMORTON RD	Subdivision	Reinspection	SC
3/4/2025	354 OLD BAY LN	Commercial	Maintenance	SC
3/5/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
3/5/2025	319 COOLEY MILL RD	Residential	Maintenance	SC
3/5/2025	1215 BALTIMORE PIKE	Commercial	Reinspection	SC
3/5/2025	3146 OLD YORK RD	Residential	Maintenance	SC
3/5/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
3/5/2025	2509 PORT LN	Subdivision	Reinspection	SC
3/5/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
3/5/2025	508 PULASKI HWY	Commercial	Maintenance	SC
3/5/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
3/5/2025	0 ARDEN DR	Subdivision	Maintenance	SC
3/5/2025	781 PRIESTFORD RD	Residential	Maintenance	SC
3/5/2025	401 THOMAS RUN RD	Institutional	Maintenance	SC
3/5/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
3/5/2025	0 HANSON RD	Subdivision	Maintenance	SC
3/6/2025	3205 SUDATH LN	Residential	Maintenance	SC
3/6/2025	2110 BEL AIR RD	Commercial	Maintenance	SC
3/6/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
3/6/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
3/6/2025	221 Hopkins RD			SC
3/6/2025	5640 LONG CORNER RD	Residential	Maintenance	SC
3/6/2025	0 GRAVEL HILL RD	Commercial	Pre-Inspection	SC
3/6/2025	0 PURPLE PL	Subdivision	Maintenance	SC
3/6/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/6/2025	0 GRAVEL HILL RD	Commercial	Pre-Inspection	SC
3/6/2025	3040 LEVEL RD	Residential	Maintenance	SC
3/6/2025	18 ROCKDALE AVE	Residential	Maintenance	SC
3/6/2025	Inspection Number: 008917-2025	Capital Project	Maintenance	SC
3/6/2025	2421 HARKINS RD	Residential	Maintenance	SC
3/6/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
3/6/2025	913 FAWN CT		Complaint	SC
3/6/2025	3532 MILLER RD	Residential	Maintenance	SC
3/6/2025	900-H Cedar Crest Ct		Complaint	SC
3/6/2025	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
3/6/2025	338 EARLTON RD	Residential	Maintenance	SC
3/6/2025	0 HANSON RD	Subdivision	Maintenance	SC
3/7/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
3/7/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
3/7/2025	2013 PACKARD DR	Residential	Maintenance	SC
3/7/2025	1373 TRAPPE RD	Residential	Maintenance	SC
3/7/2025	401 THOMAS RUN RD	Institutional	Maintenance	SC
3/7/2025	4525 CLERMONT MILL RD	Institutional		SC
3/7/2025	3146 OLD YORK RD	Residential	Maintenance	SC
3/7/2025	1307 GOVERNOR CT	Commercial	Maintenance	SC
3/7/2025	2303 CARRS MILL RD	Capital Project	Maintenance	SW
3/7/2025	5125 CAREA RD	Residential	Maintenance	SC
3/7/2025	415 TRIMBLE RD	Residential	Complaint	SC
3/7/2025	1225 BUSH RD	Residential	Maintenance	SC
3/7/2025	Inspection Number: 009742-2025	Residential		SC
3/7/2025	3924 NORRISVILLE RD	Residential	Maintenance	SC
3/7/2025	3924 NORRISVILLE RD	Residential - Single	Pre-Con	SW
3/7/2025	3158 OLD FORGE HILL RD		Maintenance	SC
3/7/2025	2014 PACKARD DR	Residential	Maintenance	SC
3/7/2025	3538 ALDINO RD	Commercial	Maintenance	SC
3/7/2025	2208 KALMIA RD	Residential	Maintenance	SC
3/7/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
3/7/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<b>Start Date</b>	<b>Address</b>	<b>Property Type</b>	<b>Purpose</b>	<b>Type</b>
3/7/2025	1714 RIDGE RD	Residential	Maintenance	SW
3/7/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
3/7/2025	3026 SNAKE LN	Residential	Maintenance	SC
3/7/2025	4370 NORRISVILLE RD	Residential		SC
3/7/2025	1714 RIDGE RD	Residential	Maintenance	SC
3/7/2025	3144 OLD YORK RD	Residential	Maintenance	SC
3/7/2025	3808 SEWELL RD	Residential	Maintenance	SC
3/7/2025	417-A Calvary RD	Residential	Maintenance	SC
3/10/2025	1725 O'CONNOR RD	Residential	Construction	SW
3/10/2025	1603 BULLS LN	Residential	Maintenance	SC
3/10/2025	3727 Old Federal Hill Road	Residential	Maintenance	SC
3/10/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
3/10/2025	1035 JOPPA RD	Commercial	Reinspection	SC
3/10/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
3/10/2025	2822 CHARLES ST	Residential	Maintenance	SC
3/10/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
3/10/2025	1657 Robin CIR	Commercial	Pre-Inspection	SC
3/10/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
3/10/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
3/10/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
3/10/2025	1924 PLEASANTVILLE RD	Subdivision	Reinspection	SC
3/10/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
3/10/2025	2771 ADMIRAL LN	Commercial	Construction	SW
3/10/2025	2013 PACKARD DR	Residential		SW
3/10/2025	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
3/10/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
3/10/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
3/10/2025	0 MEADOWOOD DR		Maintenance	SW
3/10/2025	115 INDUSTRY LN	Commercial	As-Built	SW
3/10/2025	1112 BALDWIN MILL RD		Maintenance	SW
3/11/2025	4624 MERCEDES DR	Commercial	Maintenance	SC
3/11/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
3/11/2025	2503 S TOLLGATE RD	Commercial	Reinspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/11/2025	900 Block Ring Factory RD W	Institutional	Reinspection	SC
3/11/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
3/11/2025	2035 CONNOLLY RD	Subdivision	Maintenance	SC
3/11/2025	711 PHILADELPHIA RD	Commercial	Maintenance	SC
3/11/2025	904 EDGEWOOD RD	Commercial	Maintenance	SC
3/11/2025	0 MAGNOLIA RD		Maintenance	SC
3/11/2025	3538 ALDINO RD	Commercial	Complaint	SC
3/11/2025	2800 WILLOUGHBY BEACH RD		Complaint	SC
3/11/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
3/11/2025	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
3/11/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
3/11/2025	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
3/11/2025	2350 CONOWINGO RD	Institutional	Maintenance	SC
3/12/2025	2215 CRESWELL RD	Institutional	Maintenance	SC
3/12/2025	805 THOMAS RUN RD	Residential	Maintenance	SC
3/12/2025	0 CARRS MILL RD	Capital Project	Maintenance	SC
3/12/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
3/12/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
3/12/2025	2509 PORT LN	Subdivision	Reinspection	SC
3/12/2025	1300 BUSINESS CENTER WAY		Maintenance	SC
3/12/2025	755 CHELSEA RD	Commercial	Conversion	SW
3/12/2025	0 CHELSEA RD	Commercial	Maintenance	SC
3/12/2025	1111 VALE RD	Residential	Maintenance	SC
3/12/2025	4108 FEDERAL HILL RD	Residential	Maintenance	SC
3/12/2025	300 PULASKI HWY		Maintenance	SC
3/12/2025	2003 LAUREL BROOK RD	Residential	Maintenance	SC
3/12/2025	4108 FEDERAL HILL RD	Residential - Single	Pre-Con	SW
3/12/2025	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
3/12/2025	514 JOPPA FARM RD		Maintenance	SC
3/12/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
3/12/2025	2000 CALVARY RD	Commercial	Maintenance	SC
3/12/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
3/12/2025	0 HANSON RD	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/13/2025	900-H Cedar Crest Ct		Complaint	SC
3/13/2025	3538 ALDINO RD	Commercial	Complaint	SC
3/13/2025	0 OATGRASS CT	Residential	Construction	SW
3/13/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
3/13/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
3/13/2025	1657 Robin CIR	Commercial	As-Built	SW
3/13/2025	0 OATGRASS CT	Residential	Construction	SW
3/13/2025	0 LAUREL BUSH RD	Residential	Maintenance	SC
3/13/2025	0 IRON OAK CT	Residential	Construction	SW
3/13/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
3/13/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
3/13/2025	913 FAWN CT		Maintenance	SC
3/13/2025	0 SPRUCE PINE RD	Residential	Construction	SW
3/13/2025	5640 LONG CORNER RD	Residential	Maintenance	SC
3/13/2025	331 MARINA AVE	Residential	Maintenance	SC
3/13/2025	2409 HARFORD RD		Request As-Built	SW
3/13/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
3/13/2025	2626 TALL OAKS DR	Subdivision	Maintenance	SC
3/13/2025	1212 CHELSEA RD	Capital Project	Maintenance	SC
3/14/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
3/14/2025	1657 Robin CIR	Commercial	Reinspection	SC
3/14/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
3/14/2025	1827 BALDWIN MILL RD	Residential - Single		SW
3/14/2025	18 ROCKDALE AVE	Residential	Maintenance	SC
3/14/2025	529 PRITT LN	Residential	Maintenance	SC
3/14/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
3/14/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
3/14/2025	2595 MEDICAL HALL RD	Residential	Maintenance	SC
3/14/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
3/14/2025	2205 JACK LN	Residential	Maintenance	SC
3/14/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
3/17/2025	Inspection Number: 001198-2025	Residential		SW
3/17/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/17/2025	852 STANSBURY RD	Residential	Maintenance	SC
3/17/2025	1924 PLEASANTVILLE RD	Subdivision	Reinspection	SC
3/17/2025	2014 PACKARD DR	Residential	Reinspection	SC
3/17/2025	104 MOONLIGHT DR	Subdivision	Reinspection	SC
3/17/2025	1222 TOLLGATE RD			SC
3/17/2025	3808 SEWELL RD	Residential	Maintenance	SC
3/17/2025	1812 WALTON RD	Commercial	Maintenance	SC
3/17/2025	0 CEDAR DR	Commercial	Maintenance	SC
3/17/2025	5129 FAWN GROVE RD	Residential	Maintenance	SC
3/17/2025	2013 PACKARD DR	Residential	Reinspection	SC
3/17/2025	215 KENNARD AVE	Residential	Maintenance	SC
3/17/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
3/17/2025	1222 TOLLGATE RD		Complaint	SC
3/17/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
3/17/2025	854 STANSBURY RD	Residential	Maintenance	SC
3/17/2025	2020 PACKARD DR	Subdivision	Reinspection	SC
3/17/2025	103 KENNARD AVE		Maintenance	SC
3/18/2025	101 CHERRY HILL RD	Commercial		SC
3/18/2025	5125 CAREA RD	Residential	Maintenance	SC
3/18/2025	2718 ADY RD	Residential - Single	Construction	SW
3/18/2025	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
3/18/2025	415 TRIMBLE RD	Residential	Complaint	SC
3/18/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
3/18/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
3/18/2025	2014 EMMORTON RD	Subdivision	Reinspection	SC
3/18/2025	2503 S TOLLGATE RD	Commercial	Reinspection	SC
3/18/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
3/18/2025	940 Ripple Stream Ring Factory CT	Institutional	Reinspection	SC
3/18/2025	101 CHERRY HILL RD	Commercial	Maintenance	SC
3/18/2025	5125 CAREA RD	Residential	Maintenance	SC
3/18/2025	2309 SNOW RD	Residential	Maintenance	SC
3/19/2025	2215 CRESWELL RD	Institutional	Reinspection	SC
3/19/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/19/2025	508 PULASKI HWY	Commercial	Maintenance	SC
3/19/2025	3532 MILLER RD	Residential - Single	Construction	SW
3/19/2025	4024 PROSPECT RD	Residential	Maintenance	SC
3/19/2025	3333 JAMES RUN RD	Residential	Reinspection	SC
3/19/2025	3505 BERKLEY RD	Residential - Single	Sediment Phase	SW
3/19/2025	2013 SCHUSTER RD	Residential	Maintenance	SC
3/19/2025	3632 PROSPECT RD	Residential	Maintenance	SC
3/19/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
3/19/2025	2300 EDWARDS LN	Residential	Reinspection	SC
3/19/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
3/19/2025	1501 PERRYMAN RD	Commercial	Maintenance	SC
3/19/2025	4024 PROSPECT RD	Residential	Pre-Con	SW
3/19/2025	2509 PORT LN	Subdivision	Reinspection	SC
3/19/2025	1111 VALE RD	Residential	Maintenance	SC
3/19/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
3/19/2025	2509 MOUNTAIN RD	Residential - Single	Maintenance	SW
3/19/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
3/19/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
3/19/2025	354 OLD BAY LN	Commercial	Maintenance	SC
3/19/2025	845 CHERRY HILL RD	Residential	Final	SC
3/19/2025	0 HANSON RD	Subdivision	Maintenance	SC
3/20/2025	1215 BALTIMORE PIKE	Commercial	Reinspection	SC
3/20/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
3/20/2025	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
3/20/2025	755 CHELSEA RD	Commercial	Construction	SW
3/20/2025	319 COOLEY MILL RD	Residential	Maintenance	SC
3/20/2025	2208 KALMIA RD	Residential	Maintenance	SC
3/20/2025	1007 PROSPECT MILL RD	Residential	Maintenance	SC
3/20/2025	120 ROCK SPRING CHURCH RD	Residential	Pre-Con	SW
3/20/2025	4998 JOLLY ACRES RD	Residential	Maintenance	SC
3/20/2025	2110 BEL AIR RD	Commercial	Maintenance	SC
3/20/2025	3040 LEVEL RD	Residential	Maintenance	SC
3/20/2025	1212 CHELSEA RD	Capital Project	Reinspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/20/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
3/20/2025	4370 NORRISVILLE RD	Residential	Maintenance	SC
3/20/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
3/20/2025	2421 HARKINS RD	Residential	Maintenance	SC
3/20/2025	0 PURPLE PL	Subdivision	Maintenance	SC
3/20/2025	120 ROCK SPRING CHURCH RD	Residential	Pre-Inspection	SC
3/20/2025	0 ARDEN DR	Subdivision	Maintenance	SC
3/20/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
3/20/2025	3616 ADY RD	Residential	Maintenance	SC
3/20/2025	3924 PULASKI HWY		Maintenance	SW
3/21/2025	3538 ALDINO RD	Commercial	Maintenance	SC
3/21/2025	1657 Robin CIR	Commercial	Maintenance	SC
3/21/2025	Inspection Number: 011950-2025	Capital Project	Maintenance	SC
3/21/2025	2800 E MEDICAL HALL RD	Residential	Maintenance	SC
3/21/2025	1373 TRAPPE RD	Residential	Maintenance	SC
3/21/2025	3505 BERKLEY RD	Residential	Maintenance	SC
3/21/2025	2020 PACKARD DR	Subdivision	Reinspection	SC
3/21/2025	1609 HEIMS LN	Residential	Complaint	SC
3/21/2025	2248 GIBSON RD	Residential	Maintenance	SC
3/21/2025	3505 BERKLEY RD	Residential - Single	Construction	SW
3/21/2025	1714 RIDGE RD	Residential	Maintenance	SC
3/21/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
3/21/2025	617 MAHAN RD	Residential	Maintenance	SC
3/21/2025	2014 PACKARD DR	Residential	Reinspection	SC
3/21/2025	2614 ROCKS RD	Residential	Complaint	SC
3/21/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
3/21/2025	1225 BUSH RD	Residential	Maintenance	SC
3/21/2025	1702 MOONRIVER CT	Subdivision	Maintenance	SC
3/21/2025	119 HOPEWELL RD	Residential		SC
3/21/2025	103 MATTE LN	Residential	Maintenance	SC
3/24/2025	1603 BULLS LN	Residential	Maintenance	SC
3/24/2025	781 PRIESTFORD RD	Residential	Maintenance	SC
3/24/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/24/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
3/24/2025	1111 VALE RD	Residential	Reinspection	SC
3/24/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
3/24/2025	1222 TOLLGATE RD		Reinspection	SC
3/24/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
3/24/2025	0 NUTTAL AVE	Capital Project	Maintenance	SC
3/24/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
3/24/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
3/24/2025	1924 PLEASANTVILLE RD	Subdivision	Reinspection	SC
3/24/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
3/24/2025	100 KEARNEY DR	Capital Project	Maintenance	SC
3/24/2025	3146 OLD YORK RD	Residential	Maintenance	SC
3/24/2025	3924 NORRISVILLE RD	Residential	Installation	SC
3/24/2025	3144 OLD YORK RD	Residential	Maintenance	SC
<b>3/24/2025</b>	<b>2509 MOUNTAIN RD</b>	<b>Residential - Single</b>	<b>Request As-Built</b>	<b>SW</b>
3/25/2025	0 MAGNOLIA RD		Maintenance	SC
3/25/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
3/25/2025	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
3/25/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
3/25/2025	711 PHILADELPHIA RD	Commercial	Complaint	SC
3/25/2025	2010 MOUNTAIN RD	Commercial	Complaint	SC
3/25/2025	1319 PERRYMAN RD	Commercial	Maintenance	SC
3/25/2025	1615 INGLESIDE RD	Residential	Maintenance	SC
3/25/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
<b>3/25/2025</b>	<b>3632 PROSPECT RD</b>	<b>Residential</b>	<b>Construction</b>	<b>SW</b>
3/25/2025	2014 PACKARD DR	Residential	Reinspection	SC
3/25/2025	2035 CONNOLLY RD	Subdivision	Maintenance	SC
3/25/2025	4624 MERCEDES DR	Commercial		SC
3/25/2025	904 EDGEWOOD RD	Commercial	Maintenance	SC
<b>3/25/2025</b>	<b>2109 CONNOLLY RD</b>	<b>Residential</b>		<b>SW</b>
3/26/2025	2300 EDWARDS LN	Residential	Reinspection	SC
3/26/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
3/26/2025	2626 TALL OAKS DR	Subdivision	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/26/2025	2303 CARRS MILL RD	Capital Project	Maintenance	SC
3/26/2025	1300 BUSINESS CENTER WAY		Maintenance	SC
3/26/2025	1614 KINGS VIEW DR			SC
3/26/2025	4108 FEDERAL HILL RD	Residential	Maintenance	SC
3/26/2025	0 GRAVEL HILL RD	Commercial	Final	SC
3/26/2025	1614 KINGS VIEW DR	Residential - Single	Pre-Con	SW
3/26/2025	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
3/26/2025	1304 NORRIS RD		Pre-Inspection	SC
3/26/2025	1725 O'CONNOR RD	Residential	Maintenance	SC
3/26/2025	2000 CALVARY RD	Commercial	Maintenance	SC
3/26/2025	417-A Calvary RD	Residential	Maintenance	SC
3/26/2025	300 PULASKI HWY		Maintenance	SC
3/26/2025	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
3/26/2025	2509 PORT LN	Subdivision	Reinspection	SC
3/26/2025	2503 S TOLLGATE RD	Commercial	Reinspection	SC
3/26/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
3/26/2025	2303 CARRS MILL RD	Capital Project	Maintenance	SW
3/26/2025	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
3/26/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
3/26/2025	514 JOPPA FARM RD		Complaint	SC
3/26/2025	1614 KINGS VIEW DR	Residential	Pre-Inspection	SC
3/26/2025	1304 NORRIS RD		Pre-Con	SW
3/26/2025	0 HANSON RD	Subdivision	Maintenance	SC
3/27/2025	331 MARINA AVE	Residential	Maintenance	SC
3/27/2025	950 OLD JOPPA CT	Residential	Pre-Inspection	SC
3/27/2025	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
3/27/2025	2031 MARGRAVE AVE	Residential	Construction	SW
3/27/2025	0 MARGRAVE AVE	Residential	Maintenance	SW
3/27/2025	2822 CHARLES ST	Residential	Maintenance	SC
3/27/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
3/27/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
3/27/2025	1989 MITCHELL DR		Pre-Con	SW
3/27/2025	1212 CHELSEA RD	Capital Project	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/27/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
3/27/2025	1410 THOMAS RUN RD	Residential	Maintenance	SW
3/27/2025	900-H Cedar Crest Ct		Maintenance	SC
3/27/2025	950 OLD JOPPA CT		Pre-Con	SW
3/27/2025	2718 ADY RD	Residential	Maintenance	SC
3/27/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
3/27/2025	115 Magnolia Rd	Forested	Complaint	SC
3/27/2025	1430 QUAKER CHURCH RD	Residential	Construction	SW
3/27/2025	34 MC DERMOTT RD	Residential - Single	Construction	SW
3/27/2025	2031 MARGRAVE AVE	Residential	Maintenance	SW
3/27/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
3/27/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
3/27/2025	2239 ENGLE RD	Residential	Maintenance	SC
3/27/2025	0 ARABELLA WAY	Residential	Maintenance	SW
3/27/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
3/27/2025	913 FAWN CT		Maintenance	SC
3/27/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
3/27/2025	2421 HARKINS RD	Residential - Single	Construction	SW
3/27/2025	1657 Robin CIR	Commercial	Reinspection	SC
3/27/2025	2718 ADY RD	Residential	Maintenance	SC
3/27/2025	1989 MITCHELL DR	Residential	Installation	SC
3/27/2025	1929 SUSQUEHANNA HALL RD	Commercial	Maintenance	SC
3/28/2025	3532 MILLER RD	Residential	Maintenance	SC
3/28/2025	2248 GIBSON RD	Residential	Maintenance	SC
3/28/2025	18 ROCKDALE AVE	Residential	Maintenance	SC
3/28/2025	2080 STEWART DR	Residential		SW
3/28/2025	2013 PACKARD DR	Residential	Maintenance	SC
3/28/2025	2037 WATERVALE RD	Residential		SW
3/28/2025	2595 MEDICAL HALL RD	Residential	Maintenance	SC
3/28/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
3/28/2025	529 PRITT LN	Residential	Maintenance	SC
3/28/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
3/28/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/28/2025	1408 THOMAS RUN RD	Residential - Single		SW
3/28/2025	2020 PACKARD DR	Subdivision	Reinspection	SC
3/28/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
3/28/2025	2110 BEL AIR RD	Commercial	Reinspection	SC
3/28/2025	845 CHERRY HILL RD	Residential		SC
3/28/2025	0 GRAVEL HILL RD	Commercial		SC
3/28/2025	805 THOMAS RUN RD	Residential	Maintenance	SC
3/28/2025	5640 LONG CORNER RD	Residential	Maintenance	SC
3/28/2025	354 OLD BAY LN	Commercial	Maintenance	SC
3/28/2025	2595 MEDICAL HALL RD	Residential - Single	Maintenance	SW
3/28/2025	401 THOMAS RUN RD	Institutional	Maintenance	SC
3/28/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
3/28/2025	940 Ripple Stream Ring Factory CT	Institutional		SC
3/28/2025	805 THOMAS RUN RD	Residential - Single		SW
3/28/2025	2205 JACK LN	Residential	Maintenance	SC
3/28/2025	1408 THOMAS RUN RD	Residential - Single	Maintenance	SW
3/28/2025	0 YEARLING DR	Subdivision		SC
3/28/2025	1121 DEER CREEK CHURCH RD	Residential - Single	Construction	SW
3/31/2025	1714 RIDGE RD	Residential	Request As-Built	SW
3/31/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
3/31/2025	2809 BELCAMP RD	Residential	Maintenance	SC
3/31/2025	1812 WALTON RD	Commercial	Maintenance	SC
3/31/2025	1111 VALE RD	Residential	Reinspection	SC
3/31/2025	1800 CORNUS WAY		Pre-Inspection	SC
3/31/2025	103 KENNARD AVE		Maintenance	SC
3/31/2025	1516 JONES RD	Residential - Single	Pre-Con	SW
3/31/2025	3808 SEWELL RD	Residential	Maintenance	SC
3/31/2025	3144 OLD YORK RD	Residential	Maintenance	SC
3/31/2025	4998 JOLLY ACRES RD	Residential	Request As-Built	SW
3/31/2025	1534 Jones RD	Residential	Maintenance	SC
3/31/2025	1516 JONES RD	Residential	Maintenance	SC
3/31/2025	215 KENNARD AVE	Residential	Maintenance	SC
3/31/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
3/31/2025	5129 FAWN GROVE RD	Residential	Maintenance	SC
3/31/2025	1534 Jones RD	Residential - Single	Sediment Phase	SW
3/31/2025	852 STANSBURY RD	Residential	Maintenance	SC
3/31/2025	3026 SNAKE LN	Residential	Maintenance	SC
3/31/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
3/31/2025	2003 LAUREL BROOK RD	Residential	Final	SC
3/31/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
3/31/2025	1222 TOLLGATE RD		Reinspection	SC
3/31/2025	1924 PLEASANTVILLE RD	Subdivision	Reinspection	SC
3/31/2025	1615 INGLESIDE RD	Residential		SW
3/31/2025	3535 CONOWINGO RD		Maintenance	SW
3/31/2025	0 HANSON RD	Subdivision	Maintenance	SC
3/31/2025	0 CEDAR DR	Commercial	Maintenance	SC
4/1/2025	0 CHELSEA RD	Commercial	Maintenance	SC
4/1/2025	415 TRIMBLE RD	Residential	Complaint	SC
4/1/2025	2309 SNOW RD	Residential	Maintenance	SC
4/1/2025	2014 EMMORTON RD	Subdivision	Reinspection	SC
4/1/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
4/1/2025	103 MATTE LN	Residential	Maintenance	SC
4/1/2025	755 CHELSEA RD	Commercial	Conversion	SW
4/1/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
4/1/2025	103 MATTE LN	Residential	Maintenance	SC
4/1/2025	2014 PACKARD DR	Residential	Reinspection	SC
4/1/2025	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
4/1/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
4/1/2025	2409 HARFORD RD	Residential	As-Built	SW
4/1/2025	1009 PINE RD		Maintenance	SW
4/2/2025	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
4/2/2025	320 RECKORD RD		As-Built Received	SW
4/2/2025	3632 PROSPECT RD	Residential	Maintenance	SC
4/2/2025	2503 S TOLLGATE RD	Commercial	Reinspection	SC
4/2/2025	508 PULASKI HWY	Commercial	Maintenance	SC
4/2/2025	672 ROCK SPRING CHURCH RD	Residential - Single	Request As-Built	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/2/2025	2300 EDWARDS LN	Residential	Reinspection	SC
4/2/2025	2215 CRESWELL RD	Institutional	Reinspection	SC
4/2/2025	617 MAHAN RD	Residential	Maintenance	SC
4/2/2025	2409 HARFORD RD			SW
4/2/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
4/2/2025	319 COOLEY MILL RD	Residential	Maintenance	SC
4/2/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
4/2/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
4/2/2025	0 HANSON RD	Subdivision	Complaint	SC
4/3/2025	120 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
4/3/2025	0 LEVEL RD	Commercial	Pre-Inspection	SC
4/3/2025	3616 ADY RD	Residential - Single	As-Built Received	SW
4/3/2025	0 PURPLE PL	Subdivision	Maintenance	SC
4/3/2025	2029 CONNOLLY RD	Residential	Construction	SW
4/3/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
4/3/2025	3314 THOMAS BRIDGE RD	Residential - Single	Pre-Con	SW
4/3/2025	2120 ALLIBONE RD		Request As-Built	SW
4/3/2025	420 HIOB LN	Commercial	Pre-Con	SW
4/3/2025	Inspection Number: ESCCI-010862-2025	Commercial	Reinspection	SC
4/3/2025	3040 LEVEL RD	Residential	Maintenance	SC
4/3/2025	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
4/3/2025	420 HIOB LN	Commercial	Pre-Inspection	SC
4/3/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
4/3/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
4/4/2025	1225 BUSH RD	Residential	Maintenance	SC
4/4/2025	3538 ALDINO RD	Commercial	Maintenance	SC
4/4/2025	0 JOHNSON MILL RD	Institutional		SC
4/4/2025	1416 & 1418 Philadelphia RD	Commercial	Reinspection	SC
4/4/2025	Inspection Number: 014858-2025	Capital Project	Maintenance	SC
4/4/2025	119 HOPEWELL RD	Residential	Maintenance	SC
4/4/2025	1714 RIDGE RD	Residential	Maintenance	SC
4/4/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
4/4/2025	3314 THOMAS BRIDGE RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/4/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
4/4/2025	755 CHELSEA RD	Commercial		SW
4/4/2025	0 ARDEN DR	Subdivision	Maintenance	SC
4/4/2025	1373 TRAPPE RD	Residential	Maintenance	SC
4/4/2025	215 KENNARD AVE		Request As-Built	SW
4/7/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
4/7/2025	1603 BULLS LN	Residential	Maintenance	SC
4/7/2025	1614 KINGS VIEW DR	Residential	Maintenance	SC
4/7/2025	1989 MITCHELL DR	Residential		SC
4/7/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
4/7/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
4/7/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
4/7/2025	1222 TOLLGATE RD		Reinspection	SC
4/7/2025	2020 PACKARD DR	Subdivision	Pre-Inspection	SC
4/7/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
4/7/2025	2020 PACKARD DR	Residential	Pre-Con	SW
4/7/2025	2315 BEL AIR RD	Commercial	Maintenance	SC
4/7/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
4/7/2025	781 PRIESTFORD RD	Residential	Maintenance	SC
4/7/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
4/7/2025	1222 TOLLGATE RD	Residential	Maintenance	SC
4/7/2025	0 HANSON RD	Subdivision	Maintenance	SC
4/8/2025	904 EDGEWOOD RD	Commercial	Maintenance	SC
4/8/2025	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
4/8/2025	2035 CONNOLLY RD	Subdivision	Maintenance	SC
4/8/2025	617 MAHAN RD	Residential - Single	As-Built	SW
4/8/2025	617 MAHAN RD	Residential - Single	Request As-Built	SW
4/8/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
4/8/2025	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
4/8/2025	711 PHILADELPHIA RD	Commercial	Complaint	SC
4/8/2025	0 MAGNOLIA RD		Maintenance	SC
4/8/2025	1307 GOVERNOR CT	Commercial	Maintenance	SC
4/8/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/8/2025	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
4/8/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
4/8/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
4/8/2025	3146 OLD YORK RD	Residential	Maintenance	SC
4/8/2025	1714 RIDGE RD	Residential	Maintenance	SC
4/8/2025	101 CHERRY HILL RD	Commercial	Installation	SC
4/8/2025	4624 MERCEDES DR	Commercial	Maintenance	SC
4/8/2025	2013 SCHUSTER RD	Residential	Maintenance	SC
4/8/2025	300 PULASKI HWY		Maintenance	SC
4/9/2025	2626 TALL OAKS DR	Subdivision	Reinspection	SC
4/9/2025	Inspection Number: 018553-2025		Maintenance	SW
4/9/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
4/9/2025	417-A Calvary RD	Residential	Maintenance	SC
4/9/2025	Inspection Number: 018570-2025		Maintenance	SW
4/9/2025	104 MOONLIGHT DR	Subdivision	Reinspection	SC
4/9/2025	0 INDIANSUMMER CT	Residential	Maintenance	SW
4/9/2025	514 JOPPA FARM RD		Complaint	SC
4/9/2025	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
4/9/2025	Inspection Number: 018554-2025		Maintenance	SW
4/9/2025	1300 BUSINESS CENTER WAY		Maintenance	SC
4/9/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
4/9/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
4/9/2025	2000 CALVARY RD	Commercial	Maintenance	SC
4/9/2025	3205 SUDATH LN	Residential	Final	SC
4/9/2025	Inspection Number: 018546-2025		Maintenance	SW
4/9/2025	100 THOMAS RUN RD	Institutional	Maintenance	SC
4/10/2025	950 OLD JOPPA CT	Residential	Maintenance	SC
4/10/2025	2509 PORT LN	Subdivision	Reinspection	SC
4/10/2025	1657B Robin CIR	Commercial	Maintenance	SC
4/10/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
4/10/2025	1657 Robin CIR	Commercial	Reinspection	SC
4/10/2025	401 THOMAS RUN RD	Institutional	Maintenance	SC
4/10/2025	1212 CHELSEA RD	Capital Project	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/10/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
4/10/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
4/10/2025	2248 GIBSON RD	Residential - Single	Construction	SW
4/10/2025	913 FAWN CT		Maintenance	SC
4/10/2025	331 MARINA AVE	Residential	Maintenance	SC
4/10/2025	2208 KALMIA RD	Residential	Maintenance	SC
4/10/2025	900-H Cedar Crest Ct		Complaint	SC
4/10/2025	5640 LONG CORNER RD	Residential - Single	Construction	SW
4/10/2025	1304 NORRIS RD		Maintenance	SC
4/10/2025	1035 JOPPA RD	Commercial	Complaint	SC
4/10/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
4/11/2025	5125 CAREA RD	Residential	Maintenance	SC
4/11/2025	2595 MEDICAL HALL RD	Residential	Maintenance	SC
4/11/2025	1225 BUSH RD	Residential	Maintenance	SC
4/11/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
4/11/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
4/11/2025	3505 BERKLEY RD	Residential - Single	Construction	SW
4/11/2025	1929 SUSQUEHANNA HALL RD	Institutional	Maintenance	SC
4/11/2025	3505 BERKLEY RD	Residential	Maintenance	SC
4/11/2025	2110 BEL AIR RD	Commercial	Maintenance	SC
4/11/2025	354 OLD BAY LN	Commercial	Maintenance	SC
4/11/2025	2718 ADY RD	Residential - Single	Sediment Phase	SW
4/11/2025	18 ROCKDALE AVE	Residential	Maintenance	SC
4/11/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
4/11/2025	0 MAGNOLIA RD		Reinspection	SC
4/11/2025	2350 CONOWINGO RD	Institutional	Complaint	SC
4/11/2025	100 THOMAS RUN RD	Institutional	Maintenance	SC
4/11/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
4/11/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
4/11/2025	3616 ADY RD	Residential	Maintenance	SC
4/11/2025	2205 JACK LN	Residential	Maintenance	SC
4/11/2025	812 OLD JOPPA RD	Residential	Reinspection	SC
4/11/2025	3532 MILLER RD	Residential - Single	Construction	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/11/2025	2003 LAUREL BROOK RD	Residential		SC
4/11/2025	2611 CHESTNUT HILL RD	Residential	Reinspection	SC
4/11/2025	4024 PROSPECT RD	Residential	Maintenance	SC
4/14/2025	1222 TOLLGATE RD			SC
4/14/2025	3801 PEACH ORCHARD RD	Institutional		SC
4/14/2025	2809 BELCAMP RD	Residential	Maintenance	SC
4/14/2025	215 KENNARD AVE	Residential		SC
4/14/2025	1222 TOLLGATE RD			SC
4/14/2025	5640 LONG CORNER RD	Residential	Maintenance	SC
4/14/2025	2014 PACKARD DR	Residential	Maintenance	SC
4/14/2025	3026 SNAKE LN	Residential	Maintenance	SC
4/14/2025	1222 TOLLGATE RD			SC
4/14/2025	100 KEARNEY DR	Capital Project	Maintenance	SC
4/14/2025	0 CEDAR DR	Commercial	Maintenance	SC
4/14/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
4/14/2025	2303 CARRS MILL RD	Capital Project	Maintenance	SW
4/14/2025	1222 TOLLGATE RD			SC
4/14/2025	3808 SEWELL RD	Residential	Maintenance	SC
4/14/2025	2020 PACKARD DR	Subdivision	Reinspection	SC
4/14/2025	1111 VALE RD	Residential	Maintenance	SC
4/14/2025	1614 KINGS VIEW DR	Residential	Maintenance	SC
4/14/2025	1222 TOLLGATE RD	Residential	Reinspection	SC
4/14/2025	2000 CALVARY RD	Commercial	Reinspection	SC
4/14/2025	2013 PACKARD DR	Residential	Maintenance	SC
4/14/2025	1929 SUSQUEHANNA HALL RD	Commercial		SC
4/14/2025	529 PRITT LN	Residential	Maintenance	SC
4/14/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
4/14/2025	215 KENNARD AVE	Residential	Final	SC
4/14/2025	103 KENNARD AVE		Maintenance	SC
4/14/2025	854 STANSBURY RD	Residential	Maintenance	SC
4/14/2025	2303 CARRS MILL RD	Capital Project	Maintenance	SC
4/14/2025	0 MAGNOLIA RD		Reinspection	SC
4/14/2025	1812 WALTON RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/14/2025	1702 MOONRIVER CT	Subdivision	Maintenance	SC
4/14/2025	2014 PACKARD DR		Construction	SW
4/15/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
4/15/2025	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
4/15/2025	3727 Old Federal Hill Road	Residential	Maintenance	SC
4/15/2025	2718 ADY RD	Residential	Maintenance	SC
4/15/2025	1516 JONES RD	Residential	Installation	SC
4/15/2025	103 MATTE LN	Residential	Maintenance	SC
4/15/2025	1714 RIDGE RD	Residential	Reinspection	SC
4/15/2025	2035 CONNOLLY RD	Subdivision	Reinspection	SC
4/15/2025	2014 EMMORTON RD	Subdivision	Reinspection	SC
4/15/2025	319 COOLEY MILL RD	Residential	Maintenance	SC
4/15/2025	2014 EMMORTON RD	Commercial	Reinspection	SC
4/15/2025	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
4/15/2025	3158 OLD FORGE HILL RD		Maintenance	SC
4/15/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
4/15/2025	1534 Jones RD	Residential	Installation	SC
4/15/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
4/15/2025	4525 CLERMONT MILL RD	Institutional	Complaint	SC
4/15/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
4/15/2025	2309 SNOW RD	Residential	Maintenance	SC
4/15/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
4/15/2025	415 TRIMBLE RD	Residential	Complaint	SC
4/15/2025	1015 PULASKI HWY	Commercial	Maintenance	SC
4/15/2025	1615 INGLESIDE RD	Residential	Maintenance	SC
4/15/2025	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
4/15/2025	3632 PROSPECT RD	Residential	Construction	SW
4/15/2025	0 HANSON RD	Subdivision	Maintenance	SC
4/16/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
4/16/2025	617 MAHAN RD	Residential	Maintenance	SC
4/16/2025	2215 CRESWELL RD	Institutional	Reinspection	SC
4/16/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
4/16/2025	508 PULASKI HWY	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/16/2025	121 HOPEWELL RD		Pre-Con	SW
4/16/2025	2300 EDWARDS LN	Residential	Reinspection	SC
4/16/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
4/16/2025	2503 S TOLLGATE RD	Commercial	Reinspection	SC
4/16/2025	904 EDGEWOOD RD	Commercial	As-Built	SW
4/16/2025	420 HIOB LN	Commercial	Installation	SC
4/16/2025	121 HOPEWELL RD	Residential	Pre-Inspection	SC
4/16/2025	0 NUTTAL AVE	Capital Project	Maintenance	SC
4/16/2025	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
4/17/2025	10 YEARLING DR	Residential	Pre-Inspection	SC
4/17/2025	2509 MOUNTAIN RD	Residential - Single	As-Built	SW
4/17/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
4/17/2025	852 STANSBURY RD	Residential	Construction	SW
4/17/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
4/17/2025	1929 SUSQUEHANNA HALL RD	Institutional	Reinspection	SC
4/17/2025	2626 TALL OAKS DR	Subdivision	Reinspection	SC
4/17/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
4/17/2025	401 THOMAS RUN RD	Institutional	Reinspection	SC
4/17/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
4/17/2025	805 THOMAS RUN RD	Residential	Maintenance	SC
4/17/2025	2822 CHARLES ST	Residential	Construction	SW
4/17/2025	120 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
4/17/2025	1657B Robin CIR	Commercial	Maintenance	SC
4/17/2025	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
4/17/2025	1373 TRAPPE RD	Residential	Maintenance	SC
4/17/2025	401 THOMAS RUN RD	Government / Institutional	Construction	SW
4/17/2025	0 PURPLE PL	Subdivision	Maintenance	SC
4/17/2025	3801 PEACH ORCHARD RD	Institutional	Reinspection	SC
4/17/2025	3532 MILLER RD	Residential	Maintenance	SC
4/17/2025	1725 JARRETTSVILLE RD		Maintenance	SW
4/17/2025	1000 TOLLGATE RD		Maintenance	SW
4/18/2025	3808 SEWELL RD	Residential	Reinspection	SC
4/18/2025	Inspection Number: 017664-2025	Capital Project	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/18/2025	101 CHERRY HILL RD	Commercial	Maintenance	SC
4/18/2025	3314 THOMAS BRIDGE RD	Residential	Installation	SC
4/18/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
4/18/2025	1725 O'CONNER RD	Residential	Maintenance	SC
4/18/2025	2248 GIBSON RD	Residential	Maintenance	SC
4/18/2025	0 ARDEN DR	Subdivision	Reinspection	SC
4/18/2025	1225 BUSH RD	Residential	Maintenance	SC
4/21/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
4/21/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
4/21/2025	1603 BULLS LN	Residential	Maintenance	SC
4/21/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
4/21/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
4/21/2025	331 MARINA AVE	Residential		SC
4/21/2025	1609 HEIMS LN	Residential	Complaint	SC
4/21/2025	0 CHELSEA RD	Commercial	Maintenance	SC
4/21/2025	1989 MITCHELL DR	Residential	Maintenance	SC
4/21/2025	420 HIOB LN	Commercial	Installation	SC
4/21/2025	1222 TOLLGATE RD	Residential	Reinspection	SC
4/21/2025	10 YEARLING DR	Residential - Single	Pre-Con	SW
4/21/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
4/21/2025	1614 KINGS VIEW DR	Residential	Reinspection	SC
4/22/2025	300 PULASKI HWY		Maintenance	SC
4/22/2025	711 PHILADELPHIA RD	Commercial	Maintenance	SC
4/22/2025	3801 PEACH ORCHARD RD	Institutional		SC
4/22/2025	852 STANSBURY RD	Residential	Maintenance	SC
4/22/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
4/22/2025	0 MAGNOLIA RD		Maintenance	SC
4/22/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
4/22/2025	2013 SCHUSTER RD	Residential	Maintenance	SC
4/22/2025	2615 PHILADELPHIA RD	Residential	Complaint	SC
4/22/2025	1714 RIDGE RD	Residential	Maintenance	SC
4/22/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Reinspection	SC
4/22/2025	0 Whiteford and Rocks RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/22/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
4/22/2025	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
4/22/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
4/22/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
4/23/2025	2000 CALVARY RD	Commercial	Maintenance	SC
4/23/2025	3146 OLD YORK RD	Residential	Maintenance	SC
4/23/2025	2226 ROCK SPRING RD	Residential	Pre-Con	SW
4/23/2025	0 ROUTE 156	Commercial	Complaint	SC
4/23/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
4/23/2025	2226 ROCK SPRING RD	Subdivision	Maintenance	SC
4/23/2025	34 MC DERMOTT RD	Residential - Single	Construction	SW
4/23/2025	1007 PROSPECT MILL RD	Residential	Maintenance	SC
4/23/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
4/23/2025	4024 PROSPECT RD	Residential	Construction	SW
4/23/2025	100 THOMAS RUN RD	Institutional	Maintenance	SC
4/23/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
4/23/2025	3040 LEVEL RD	Residential	Maintenance	SC
4/23/2025	1300 BUSINESS CENTER WAY		Maintenance	SC
4/23/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
4/23/2025	2421 HARKINS RD	Residential - Single	Construction	SW
4/23/2025	3924 NORRISVILLE RD	Residential	Maintenance	SC
4/23/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
4/23/2025	3146 OLD YORK RD	Residential - Single	Construction	SW
4/23/2025	514 JOPPA FARM RD		Complaint	SC
4/23/2025	1304 NORRIS RD		Maintenance	SC
4/23/2025	0 ROUTE 156			SC
4/23/2025	4108 FEDERAL HILL RD	Residential	Maintenance	SC
4/23/2025	0 HANSON RD	Subdivision	Maintenance	SC
4/24/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
4/24/2025	4998 JOLLY ACRES RD	Residential	Maintenance	SC
4/24/2025	420 HIOB LN	Commercial	Installation	SC
4/24/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
4/24/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/24/2025	2208 KALMIA RD	Residential	Maintenance	SC
4/24/2025	1430 QUAKER CHURCH RD	Residential	Request As-Built	SW
4/24/2025	2239 ENGLE RD	Residential	Maintenance	SC
4/24/2025	913 FAWN CT		Maintenance	SC
4/24/2025	2626 TALL OAKS DR	Subdivision	Reinspection	SC
4/24/2025	2822 CHARLES ST	Residential	Maintenance	SC
4/24/2025	2300 & 2302 Grafton Shop Road	Institutional	Maintenance	SC
4/24/2025	1527 WHITEFORD RD	Capital Project	Pre-Inspection	SC
4/24/2025	3144 OLD YORK RD	Residential	Maintenance	SC
4/24/2025	1657 Robin CIR	Commercial	Maintenance	SC
4/24/2025	5640 LONG CORNER RD	Residential	Maintenance	SC
4/24/2025	900-H Cedar Crest Ct		Complaint	SC
4/24/2025	1527 WHITEFORD RD	Capital Project	Pre-Con	SW
4/24/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
4/24/2025	5640 LONG CORNER RD	Residential - Single	Construction	SW
4/24/2025	950 OLD JOPPA CT	Residential	Maintenance	SC
4/24/2025	1657B Robin CIR	Commercial	Reinspection	SC
4/24/2025	3538 ALDINO RD	Commercial	Maintenance	SC
4/24/2025	2509 PORT LN	Subdivision	Maintenance	SC
4/25/2025	3616 ADY RD	Residential	Maintenance	SC
4/25/2025	10 YEARLING DR	Residential		SC
4/25/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Reinspection	SC
4/25/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
4/25/2025	3505 BERKLEY RD	Residential - Single	Construction	SW
4/25/2025	3532 MILLER RD	Residential - Single	Construction	SW
4/25/2025	1373 TRAPPE RD	Residential - Single	Construction	SW
4/25/2025	338 EARLTON RD	Residential	Maintenance	SC
4/25/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
4/25/2025	0 STANSBURY RD			SC
4/25/2025	3505 BERKLEY RD	Residential	Maintenance	SC
4/25/2025	3010 RECKORD RD	Residential		SC
4/25/2025	805 THOMAS RUN RD	Residential - Single	Construction	SW
4/25/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/25/2025	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
4/25/2025	18 ROCKDALE AVE	Residential	Maintenance	SC
4/25/2025	2595 MEDICAL HALL RD	Residential - Single	Construction	SW
4/25/2025	2595 MEDICAL HALL RD	Residential	Maintenance	SC
4/25/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
4/25/2025	5125 CAREA RD	Residential	Maintenance	SC
4/25/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
4/25/2025	0 ARABELLA WAY	Residential		SW
4/25/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
4/25/2025	2718 ADY RD	Residential - Single	Construction	SW
4/25/2025	2205 JACK LN	Residential	Maintenance	SC
4/25/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
4/25/2025	2110 BEL AIR RD	Commercial	Maintenance	SC
4/25/2025	4024 PROSPECT RD	Residential	Maintenance	SC
4/25/2025	0 LEVEL RD	Commercial		SC
4/28/2025	2010 MOUNTAIN RD	Commercial	Complaint	SC
4/28/2025	2014 PACKARD DR	Residential	Maintenance	SC
4/28/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
4/28/2025	2013 PACKARD DR	Residential	Maintenance	SC
4/28/2025	3333 JAMES RUN RD	Residential	Reinspection	SC
4/28/2025	529 PRITT LN	Residential	Maintenance	SC
4/28/2025	4624 MERCEDES DR	Commercial	Maintenance	SC
4/28/2025	1222 TOLLGATE RD	Residential	Reinspection	SC
4/28/2025	103 KENNARD AVE		Maintenance	SC
4/28/2025	781 PRIESTFORD RD	Residential	Maintenance	SC
4/28/2025	0 CEDAR DR	Commercial	Maintenance	SC
4/28/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
4/28/2025	2020 PACKARD DR	Subdivision	Reinspection	SC
4/28/2025	3808 SEWELL RD	Residential	Maintenance	SC
4/28/2025	1121 DEER CREEK CHURCH RD	Residential - Single	Construction	SW
4/28/2025	1812 WALTON RD	Commercial	Maintenance	SC
4/28/2025	0 NUTTAL AVE	Capital Project	Maintenance	SC
4/28/2025	854 STANSBURY RD	Residential	Final	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/28/2025	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
4/28/2025	2014 PACKARD DR		Construction	SW
4/28/2025	115 Magnolia Rd	Forested	Complaint	SC
4/28/2025	2029 CONNOLLY RD	Residential	Construction	SW
4/29/2025	2528 COOL SPRING RD		Pre-Inspection	SC
4/29/2025	3158 OLD FORGE HILL RD		Maintenance	SC
4/29/2025	1111 VALE RD	Residential	Maintenance	SC
4/29/2025	4144 WEBSTER LAPIDUM RD	Residential	Pre-Inspection	SC
4/29/2025	1714 RIDGE RD	Residential	Construction	SW
4/29/2025	2014 EMMORTON RD	Commercial	Reinspection	SC
4/29/2025	1915 FOUNTAIN GREEN RD	Commercial	Reinspection	SC
4/29/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
4/29/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
4/29/2025	11 NEWPORT DR	Commercial	Pre-Inspection	SC
4/29/2025	3632 PROSPECT RD	Residential	Maintenance	SC
4/29/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
4/29/2025	1516 JONES RD	Residential	Installation	SC
4/29/2025	2528 COOL SPRING RD	Residential - Single	Pre-Con	SW
4/29/2025	3632 PROSPECT RD	Residential	Construction	SW
4/29/2025	2309 SNOW RD	Residential	Maintenance	SC
4/29/2025	2718 ADY RD	Residential	Maintenance	SC
4/29/2025	4144 WEBSTER LAPIDUM RD		Pre-Con	SW
4/29/2025	1534 Jones RD	Residential	Installation	SC
4/29/2025	415 TRIMBLE RD	Residential	Complaint	SC
4/30/2025	417-A Calvary RD	Residential	Maintenance	SC
4/30/2025	1913-C CHURCHVILLE RD	Residential	Maintenance	SC
4/30/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
4/30/2025	1615 INGLESIDE RD	Residential	Maintenance	SC
4/30/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
4/30/2025	0 CHELSEA RD	Commercial	Request As-Built	SW
4/30/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
4/30/2025	3532 MILLER RD	Residential	Maintenance	SC
4/30/2025	508 PULASKI HWY	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
4/30/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
4/30/2025	3727 Old Federal Hill Road	Residential	Maintenance	SC
4/30/2025	3010 RECKORD RD	Commercial		SW
4/30/2025	0 ABBEY CIR	Residential	Maintenance	SC
4/30/2025	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
4/30/2025	800 W Jarrettsville RD	Residential	Maintenance	SC
4/30/2025	2035 CONNOLLY RD	Subdivision	Reinspection	SC
4/30/2025	2300 EDWARDS LN	Residential	Maintenance	SC
4/30/2025	0 HANSON RD	Subdivision	Maintenance	SC
5/1/2025	1657B Robin CIR	Commercial	Maintenance	SC
5/1/2025	101 CHERRY HILL RD	Commercial	Maintenance	SC
5/1/2025	121 HOPEWELL RD	Residential	Installation	SC
5/1/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
5/1/2025	0 PURPLE PL	Subdivision	Maintenance	SC
5/1/2025	1373 TRAPPE RD	Residential	Maintenance	SC
5/1/2025	2509 PORT LN	Subdivision	Maintenance	SC
5/1/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
5/1/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
5/1/2025	100 KEARNEY DR	Capital Project	Maintenance	SC
5/1/2025	5129 FAWN GROVE RD	Residential	Maintenance	SC
5/1/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
5/1/2025	2215 CRESWELL RD	Institutional	Maintenance	SC
5/1/2025	3924 NORRISVILLE RD	Residential - Single	Construction	SW
5/1/2025	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
5/1/2025	2626 TALL OAKS DR	Subdivision	Reinspection	SC
5/1/2025	805 THOMAS RUN RD	Residential	Maintenance	SC
5/1/2025	2503 S TOLLGATE RD	Commercial	Maintenance	SC
5/1/2025	1319 PERRYMAN RD	Commercial	Maintenance	SC
5/1/2025	119 HOPEWELL RD	Residential	Maintenance	SC
5/1/2025	1212 CHELSEA RD	Capital Project	Maintenance	SC
5/1/2025	2300 EDWARDS LN	Residential - Single	Construction	SW
5/1/2025	608 HENDERSON RD	Residential	Complaint	SW
5/2/2025	1725 O'CONNOR RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/2/2025	Inspection Number: 020281-2025	Capital Project	Maintenance	SC
5/2/2025	2800 E MEDICAL HALL RD	Residential	Final	SC
5/2/2025	1929 SUSQUEHANNA HALL RD	Institutional	Maintenance	SC
5/2/2025	4998 JOLLY ACRES RD	Residential		SC
5/2/2025	3314 THOMAS BRIDGE RD	Residential	Maintenance	SC
5/2/2025	1725 O'CONNER RD	Residential	Construction	SW
5/2/2025	2248 GIBSON RD	Residential	Maintenance	SC
5/2/2025	0 VAN BIBBER RD	Residential	Reinspection	SC
5/2/2025	3663 CHURCHVILLE RD	Institutional	Pre-Inspection	SC
5/2/2025	1127 Belcamp Garth	Capital Project	Reinspection	SC
5/2/2025	401 THOMAS RUN RD	Institutional	Maintenance	SC
5/2/2025	1527 WHITEFORD RD	Capital Project	Installation	SC
5/2/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
5/2/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
5/2/2025	1225 BUSH RD	Residential	Maintenance	SC
5/2/2025	2239 ENGLE RD	Residential		SC
5/2/2025	0 ARDEN DR	Subdivision	Reinspection	SC
5/2/2025	120 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
5/2/2025	2013 SCHUSTER RD	Residential		SC
5/3/2025	Inspection Number: ESCCI-017324-2025	Commercial		SC
5/5/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
5/5/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
5/5/2025	1614 KINGS VIEW DR	Residential	Maintenance	SC
5/5/2025	3026 SNAKE LN	Residential	Maintenance	SC
5/5/2025	354 OLD BAY LN	Commercial	Maintenance	SC
5/5/2025	1222 TOLLGATE RD	Residential	Reinspection	SC
5/5/2025	1408 THOMAS RUN RD	Residential - Single	Construction	SW
5/5/2025	1897 CHURCHVILLE RD	Residential	Pre-Con	SW
5/5/2025	2809 BELCAMP RD	Residential	Maintenance	SC
5/5/2025	672 ROCK SPRING CHURCH RD	Residential	Complaint	SC
5/5/2025	2014 PACKARD DR	Residential	Reinspection	SC
5/5/2025	2915 Laurel Bush Road	Subdivision	Pre-Inspection	SC
5/5/2025	2915 Laurel Bush Road	Residential	Pre-Con	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/5/2025	903 OLD PYLESVILLE RD		Construction	SW
5/5/2025	2703 FALLSBROOKE MANOR DR	Residential	Maintenance	SC
5/5/2025	2303 CARRS MILL RD	Capital Project	Maintenance	SC
5/5/2025	1702 MOONRIVER CT	Subdivision	Maintenance	SC
5/5/2025	904 EDGEWOOD RD	Commercial	Maintenance	SC
5/5/2025	2020 PACKARD DR	Subdivision	Reinspection	SC
5/5/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
5/5/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
5/5/2025	1897 CHURCHVILLE RD	Residential	Pre-Inspection	SC
5/5/2025	2528 COOL SPRING RD		Installation	SC
5/5/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
5/5/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
5/5/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
5/5/2025	1603 BULLS LN	Residential	Final	SC
5/5/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
5/5/2025	2915 Laurel Bush Road	Subdivision	Pre-Inspection	SC
5/5/2025	1603 BULLS LN	Residential - Single	Request As-Built	SW
5/5/2025	2303 CARRS MILL RD	Capital Project	Maintenance	SW
5/6/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
5/6/2025	300 PULASKI HWY		Maintenance	SC
5/6/2025	3924 NORRISVILLE RD	Residential	Maintenance	SC
5/6/2025	1915 FOUNTAIN GREEN RD	Commercial	Reinspection	SC
5/6/2025	1714 RIDGE RD	Residential	Maintenance	SC
5/6/2025	4108 FEDERAL HILL RD	Residential	Maintenance	SC
5/6/2025	711 PHILADELPHIA RD	Commercial	Maintenance	SC
5/6/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
5/6/2025	2613 WHITT RD	Residential	Complaint	SC
5/6/2025	1300 BUSINESS CENTER WAY		Maintenance	SC
5/6/2025	103 MATTE LN	Residential	Maintenance	SC
5/6/2025	514 JOPPA FARM RD		Complaint	SC
5/6/2025	0 MAGNOLIA RD		Maintenance	SC
5/6/2025	852 STANSBURY RD	Residential	Maintenance	SC
5/6/2025	852 STANSBURY RD	Residential	Construction	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/6/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
5/6/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
5/6/2025	319 COOLEY MILL RD	Residential		SC
5/6/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
5/6/2025	3535 CONOWINGO RD		Maintenance	SW
5/7/2025	331 MARINA AVE	Residential	Maintenance	SC
5/7/2025	3144 OLD YORK RD	Residential	Maintenance	SC
5/7/2025	3616 ADY RD	Residential	Maintenance	SC
5/7/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
5/7/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
5/7/2025	0 CHELSEA RD	Commercial	Maintenance	SC
5/7/2025	0 ROUTE 156	Commercial	Reinspection	SC
5/7/2025	1304 NORRIS RD		Maintenance	SC
5/7/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
5/7/2025	3146 OLD YORK RD	Residential		SC
5/7/2025	1989 MITCHELL DR	Residential	Maintenance	SC
5/7/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
5/7/2025	4370 NORRISVILLE RD	Residential	Final	SC
5/7/2025	0 Whiteford and Rocks RD	Commercial	Maintenance	SC
5/7/2025	3205 SUDATH LN	Residential	Maintenance	SC
5/7/2025	1007 PROSPECT MILL RD	Residential	Maintenance	SC
5/7/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
5/7/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
5/7/2025	2551 UREY RD	Residential	Complaint	SC
5/7/2025	617 MAHAN RD	Residential - Single		SW
5/7/2025	3146 OLD YORK RD	Residential	Maintenance	SC
5/7/2025	3146 OLD YORK RD	Residential - Single	Construction	SW
5/7/2025	0 HANSON RD	Subdivision	Maintenance	SC
5/8/2025	121 HOPEWELL RD	Residential	Maintenance	SC
5/8/2025	950 OLD JOPPA CT	Residential	Maintenance	SC
5/8/2025	0 HANSON RD	Subdivision	Complaint	SC
5/8/2025	1657 Robin CIR	Commercial	Maintenance	SC
5/8/2025	1410 THOMAS RUN RD	Residential	Construction	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/8/2025	5640 LONG CORNER RD	Residential - Single	Construction	SW
5/8/2025	17 ROCKDALE AVE	Residential - Single	Pre-Con	SW
5/8/2025	913 FAWN CT		Maintenance	SC
5/8/2025	4998 JOLLY ACRES RD	Residential	Construction	SW
5/8/2025	2822 CHARLES ST	Residential	Construction	SW
5/8/2025	1319 PERRYMAN RD	Commercial	Maintenance	SC
5/8/2025	0 VAN BIBBER RD	Residential	Reinspection	SC
5/8/2025	119 HOPEWELL RD	Residential	Maintenance	SC
5/8/2025	2822 CHARLES ST	Residential	Maintenance	SC
5/8/2025	5640 LONG CORNER RD	Residential	Maintenance	SC
5/8/2025	17 ROCKDALE AVE	Residential	Pre-Inspection	SC
5/8/2025	2300 & 2302 Grafton Shop Road	Institutional	Reinspection	SC
5/8/2025	1408 THOMAS RUN RD	Residential	Reinspection	SC
5/9/2025	3538 ALDINO RD	Commercial	Maintenance	SC
5/9/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
5/9/2025	101 CHERRY HILL RD	Commercial		SC
5/9/2025	2110 BEL AIR RD	Commercial	Maintenance	SC
5/9/2025	3158 OLD FORGE HILL RD			SC
5/9/2025	854 STANSBURY RD	Residential		SC
5/9/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
5/9/2025	10 YEARLING DR	Residential	Installation	SC
5/9/2025	2595 MEDICAL HALL RD	Residential	Maintenance	SC
5/9/2025	3505 BERKLEY RD	Residential	Maintenance	SC
5/9/2025	10 YEARLING DR	Residential	Installation	SC
5/9/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
5/9/2025	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
5/9/2025	2205 JACK LN	Residential	Final	SC
5/9/2025	1605 ALGONQUIN CT	Residential	Reinspection	SC
5/9/2025	18 ROCKDALE AVE	Residential	Maintenance	SC
5/9/2025	4024 PROSPECT RD	Residential	Maintenance	SC
5/9/2025	5125 CAREA RD	Residential	Maintenance	SC
5/9/2025	338 EARLTON RD	Residential	Maintenance	SC
5/9/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/12/2025	672 ROCK SPRING CHURCH RD	Residential	Reinspection	SC
5/12/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
5/12/2025	2248 GIBSON RD	Residential	Maintenance	SC
5/12/2025	2013 PACKARD DR	Residential	Maintenance	SC
5/12/2025	1222 TOLLGATE RD	Residential	Reinspection	SC
5/12/2025	0 ARDEN DR	Subdivision	Reinspection	SC
5/12/2025	0 LAUREL BUSH RD	Residential	Final	SC
5/12/2025	0 OATGRASS CT	Residential	Request As-Built	SW
5/12/2025	0 NUTTAL AVE	Capital Project	Maintenance	SC
5/12/2025	420 HIOB LN	Commercial	Maintenance	SC
5/12/2025	0 SPRUCE PINE RD	Residential	Request As-Built	SW
5/12/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
5/12/2025	3040 LEVEL RD	Residential	Maintenance	SC
5/12/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
5/12/2025	0 OATGRASS CT	Residential	Construction	SW
5/12/2025	0 IRON OAK CT	Residential	Request As-Built	SW
5/12/2025	1035 JOPPA RD	Commercial	Complaint	SC
5/13/2025	1516 JONES RD	Residential - Single	Construction	SW
5/13/2025	2014 PACKARD DR	Residential	Reinspection	SC
5/13/2025	2014 EMMORTON RD	Commercial	Reinspection	SC
5/13/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
5/13/2025	3808 SEWELL RD	Residential	Maintenance	SC
5/13/2025	1534 Jones RD	Residential - Single	Construction	SW
5/13/2025	1121 DEER CREEK CHURCH RD	Residential - Single	Construction	SW
5/13/2025	415 TRIMBLE RD	Residential	Complaint	SC
5/13/2025	3632 PROSPECT RD	Residential	Maintenance	SC
5/13/2025	2020 PACKARD DR	Subdivision	Reinspection	SC
5/13/2025	529 PRITT LN	Residential	Maintenance	SC
5/13/2025	2035 CONNOLLY RD	Subdivision	Reinspection	SC
5/13/2025	1534 Jones RD	Residential	Installation	SC
5/13/2025	2315 BEL AIR RD	Commercial	Maintenance	SC
5/13/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
5/13/2025	2119-A ALLIBONE RD	Residential	Installation	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/13/2025	1111 VALE RD	Residential	Maintenance	SC
5/13/2025	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
5/13/2025	319 COOLEY MILL RD	Residential	Maintenance	SC
5/13/2025	2718 ADY RD	Residential - Single	Construction	SW
5/13/2025	103 KENNARD AVE		Maintenance	SC
5/13/2025	2718 ADY RD	Residential	Maintenance	SC
5/13/2025	4624 MERCEDES DR	Commercial	Maintenance	SC
5/13/2025	0 CEDAR DR	Commercial	Maintenance	SC
5/13/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
5/13/2025	1516 JONES RD	Residential	Installation	SC
5/13/2025	1812 WALTON RD	Commercial	Maintenance	SC
5/13/2025	2309 SNOW RD	Residential	Maintenance	SC
5/14/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
5/14/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
5/14/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
5/14/2025	1527 WHITEFORD RD	Capital Project	Installation	SC
5/14/2025	100 THOMAS RUN RD	Institutional	Maintenance	SC
5/14/2025	1615 INGLESIDE RD	Residential	Maintenance	SC
5/14/2025	3532 MILLER RD	Residential	Maintenance	SC
5/14/2025	2000 CALVARY RD	Commercial	Maintenance	SC
5/14/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
5/14/2025	3532 MILLER RD	Residential - Single	Construction	SW
5/14/2025	1913-C CHURCHVILLE RD	Residential	Final	SC
5/14/2025	3727 Old Federal Hill Road	Residential	Maintenance	SC
5/14/2025	4108 FEDERAL HILL RD	Residential - Single	Construction	SW
5/14/2025	100 THOMAS RUN RD	Institutional		SC
5/14/2025	2300 EDWARDS LN	Residential - Single	Request As-Built	SW
5/14/2025	800 W Jarrettsville RD	Residential	Maintenance	SC
5/14/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
5/14/2025	401 THOMAS RUN RD	Institutional	Maintenance	SC
5/14/2025	805 THOMAS RUN RD	Residential - Single	Construction	SW
5/14/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
5/14/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/14/2025	2300 EDWARDS LN	Residential	Maintenance	SC
5/14/2025	0 HANSON RD	Subdivision	Maintenance	SC
5/15/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
5/15/2025	0 PURPLE PL	Subdivision	Maintenance	SC
5/15/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
5/15/2025	301 WHEEL RD	Subdivision	Pre-Inspection	SC
5/15/2025	2626 TALL OAKS DR	Subdivision	Maintenance	SC
5/15/2025	1307 GOVERNOR CT	Commercial	Maintenance	SC
5/15/2025	2248 GIBSON RD	Residential - Single		SW
5/15/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
5/15/2025	100 THOMAS RUN RD			SC
5/15/2025	2503 S TOLLGATE RD	Commercial	Maintenance	SC
5/15/2025	5129 FAWN GROVE RD	Residential	Maintenance	SC
5/15/2025	805 THOMAS RUN RD	Residential	Maintenance	SC
5/15/2025	2248 GIBSON RD	Residential - Single		SW
5/15/2025	1924 PLEASANTVILLE RD	Subdivision	Maintenance	SC
5/15/2025	2300 & 2302 Grafton Shop Road	Institutional	Reinspection	SC
5/15/2025	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
5/15/2025	1373 TRAPPE RD	Residential - Single	Construction	SW
5/15/2025	1430 QUAKER CHURCH RD	Residential	As-Built Received	SW
5/15/2025	2613 WHITT RD	Residential		SC
5/15/2025	1657 Robin CIR	Commercial	Maintenance	SC
5/15/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
5/15/2025	2248 GIBSON RD	Residential - Single		SW
5/15/2025	1373 TRAPPE RD	Residential	Maintenance	SC
5/15/2025	2509 PORT LN	Subdivision	Maintenance	SC
5/16/2025	3314 THOMAS BRIDGE RD	Residential	Maintenance	SC
5/16/2025	301 WHEEL RD	Residential	Pre-Con	SW
5/16/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
5/16/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
5/16/2025	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
5/16/2025	401 THOMAS RUN RD	Institutional		SC
5/16/2025	Inspection Number: 023143-2025	Capital Project	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<b>Start Date</b>	<b>Address</b>	<b>Property Type</b>	<b>Purpose</b>	<b>Type</b>
5/16/2025	120 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
5/16/2025	2215 CRESWELL RD	Institutional	Final	SC
5/16/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
5/16/2025	1725 O'CONNER RD	Residential	Maintenance	SC
5/16/2025	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
5/16/2025	1603 BULLS LN	Residential		SC
5/16/2025	3663 CHURCHVILLE RD	Institutional	Installation	SC
5/16/2025	11 NEWPORT DR	Commercial	Maintenance	SC
5/16/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
5/16/2025	2800 E MEDICAL HALL RD	Residential	Maintenance	SC
5/16/2025	508 PULASKI HWY	Commercial	Maintenance	SC
5/16/2025	2215 CRESWELL RD	Institutional		SC
5/16/2025	2809 BELCAMP RD	Residential	Maintenance	SC
5/16/2025	1225 BUSH RD	Residential	Maintenance	SC
5/16/2025	1657B Robin CIR	Commercial	Maintenance	SC
5/16/2025	2205 JACK LN	Residential	As-Built	SW
5/16/2025	2203 JACK LN	Commercial	As-Built	SW
5/16/2025	100 KEARNEY DR	Capital Project	As-Built	SW
5/19/2025	2208 KALMIA RD	Residential	Maintenance	SC
5/19/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
5/19/2025	1430 QUAKER CHURCH RD	Residential	Maintenance	SC
5/19/2025	0 ARDEN DR	Subdivision	Reinspection	SC
5/19/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
5/19/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
5/19/2025	1416 & 1418 Philadelphia RD	Commercial	Reinspection	SC
5/19/2025	4144 WEBSTER LAPIDUM RD	Residential	Maintenance	SC
5/19/2025	781 PRIESTFORD RD	Residential	Maintenance	SC
5/19/2025	1222 TOLLGATE RD	Residential	Reinspection	SC
5/19/2025	1929 SUSQUEHANNA HALL RD	Institutional	Maintenance	SC
5/19/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
5/19/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
5/20/2025	2119-A ALLIBONE RD	Residential	Maintenance	SC
5/20/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/20/2025	0 MAGNOLIA RD		Maintenance	SC
5/20/2025	2600 TOBIN CROSSING	Commercial	Reinspection	SC
5/20/2025	3146 OLD YORK RD	Residential	Installation	SC
5/20/2025	3924 NORRISVILLE RD	Residential	Maintenance	SC
5/20/2025	2703 FALLSBROOKE MANOR DR	Residential	Final	SC
5/20/2025	1614 KINGS VIEW DR	Residential	Maintenance	SC
5/20/2025	1714 RIDGE RD	Residential	Maintenance	SC
5/20/2025	1714 RIDGE RD	Residential		SW
5/20/2025	711 PHILADELPHIA RD	Commercial	Maintenance	SC
5/20/2025	1301 GOVERNOR CT	Commercial	Reinspection	SC
5/20/2025	3144 OLD YORK RD	Residential	Maintenance	SC
5/20/2025	852 STANSBURY RD	Residential	Maintenance	SC
5/20/2025	4108 FEDERAL HILL RD	Residential	Maintenance	SC
5/20/2025	1111 VALE RD	Residential	Reinspection	SC
5/20/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
5/20/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
5/20/2025	300 PULASKI HWY		Maintenance	SC
5/20/2025	0 Whiteford and Rocks RD	Commercial	Maintenance	SC
5/20/2025	514 JOPPA FARM RD		Complaint	SC
5/21/2025	3205 SUDATH LN	Residential	Final	SC
5/21/2025	1300 BUSINESS CENTER WAY		Maintenance	SC
5/21/2025	2215 CHURCHVILLE RD	Commercial	Reinspection	SC
5/21/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
5/21/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
5/21/2025	1007 PROSPECT MILL RD	Residential	Maintenance	SC
5/21/2025	4024 PROSPECT RD	Residential	Construction	SW
5/21/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
5/21/2025	1827 BALDWIN MILL RD	Residential	Maintenance	SC
5/21/2025	1897 CHURCHVILLE RD	Residential	Maintenance	SC
5/21/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
5/21/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
5/21/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
5/21/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/21/2025	3616 ADY RD	Residential	Final	SC
5/21/2025	103 MATTE LN	Residential	Maintenance	SC
5/21/2025	1304 NORRIS RD		Maintenance	SC
5/21/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
5/21/2025	34 MC DERMOTT RD	Residential - Single	Construction	SW
5/21/2025	2248 GIBSON RD	Residential	Maintenance	SC
5/21/2025	417-A Calvary RD	Residential	Maintenance	SC
5/21/2025	0 HANSON RD	Subdivision	Maintenance	SC
5/22/2025	950 OLD JOPPA CT	Residential	Maintenance	SC
5/22/2025	3040 LEVEL RD		Construction	SW
5/22/2025	0 CHELSEA RD	Commercial	Final	SC
5/22/2025	11 NEWPORT DR	Commercial	Maintenance	SC
5/22/2025	10 YEARLING DR	Residential	Installation	SC
5/22/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
5/22/2025	913 FAWN CT		Maintenance	SC
5/22/2025	1212 CHELSEA RD	Capital Project	Maintenance	SC
5/22/2025	900-H Cedar Crest Ct		Complaint	SC
5/22/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
5/22/2025	1924 PLEASANTVILLE RD	Subdivision	Reinspection	SC
5/22/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
5/22/2025	3040 LEVEL RD	Residential	Maintenance	SC
5/22/2025	100 KEARNEY DR	Capital Project	As-Built	SW
5/23/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
5/23/2025	3505 BERKLEY RD	Residential	Maintenance	SC
5/23/2025	2110 BEL AIR RD	Commercial	Final	SC
5/23/2025	2626 TALL OAKS DR	Subdivision	Reinspection	SC
5/23/2025	5125 CAREA RD	Residential	Maintenance	SC
5/23/2025	2421 HARKINS RD	Residential - Single	Construction	SW
5/23/2025	2595 MEDICAL HALL RD	Residential - Single	Construction	SW
5/23/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
5/23/2025	121 HOPEWELL RD	Residential	Maintenance	SC
5/23/2025	3026 SNAKE LN	Residential	Maintenance	SC
5/23/2025	5640 LONG CORNER RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/23/2025	2595 MEDICAL HALL RD	Residential	Maintenance	SC
5/23/2025	2300 & 2302 Grafton Shop Road	Institutional	Reinspection	SC
5/23/2025	18 ROCKDALE AVE	Residential	Maintenance	SC
5/23/2025	2205 JACK LN	Residential		SC
5/23/2025	17 ROCKDALE AVE	Residential	Maintenance	SC
5/23/2025	3505 BERKLEY RD	Residential - Single	Construction	SW
5/23/2025	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
5/23/2025	4024 PROSPECT RD	Residential	Maintenance	SC
5/23/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
5/23/2025	3026 SNAKE LN	Residential - Single	Construction	SW
5/23/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
5/23/2025	119 HOPEWELL RD	Residential	Maintenance	SC
5/23/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
5/23/2025	2421 HARKINS RD	Residential	Maintenance	SC
5/26/2025	3808 SEWELL RD	Residential	Maintenance	SC
5/26/2025	2309 SNOW RD	Residential	Maintenance	SC
5/26/2025	1812 WALTON RD	Commercial	Maintenance	SC
5/26/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
5/26/2025	0 CEDAR DR	Commercial	Maintenance	SC
5/26/2025	103 KENNARD AVE		Maintenance	SC
5/27/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
5/27/2025	2014 PACKARD DR		Construction	SW
5/27/2025	2014 PACKARD DR	Residential	Maintenance	SC
5/27/2025	4624 MERCEDES DR	Commercial	Final	SC
5/27/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
5/27/2025	3333 JAMES RUN RD	Residential	Reinspection	SC
5/27/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
5/27/2025	2718 ADY RD	Residential	Maintenance	SC
5/27/2025	4024 PROSPECT RD	Residential		SC
5/27/2025	3935 PROSPECT RD	Residential	Installation	SC
5/27/2025	1516 JONES RD	Residential	Installation	SC
5/27/2025	2528 COOL SPRING RD		Maintenance	SC
5/27/2025	529 PRITT LN	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/27/2025	1111 VALE RD	Residential	Reinspection	SC
5/27/2025	2226 ROCK SPRING RD	Subdivision	Maintenance	SC
5/27/2025	2303 CARRS MILL RD	Capital Project	Maintenance	SC
5/27/2025	3632 PROSPECT RD	Residential	Maintenance	SC
5/27/2025	617 MAHAN RD	Residential	Maintenance	SC
5/27/2025	2013 PACKARD DR	Residential	Maintenance	SC
5/27/2025	1534 Jones RD	Residential	Maintenance	SC
5/27/2025	2035 CONNOLLY RD	Subdivision	Reinspection	SC
5/27/2025	354 OLD BAY LN	Commercial	Maintenance	SC
5/27/2025	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
5/27/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
5/27/2025	0 ARDEN DR	Subdivision	Reinspection	SC
5/27/2025	3632 PROSPECT RD	Residential	Construction	SW
5/27/2025	Route 40 Abingdon Rd & Route 40		Complaint	SC
5/27/2025	1614 KINGS VIEW DR	Residential	Reinspection	SC
5/27/2025	2704 ADY RD	Residential	As-Built	SW
5/28/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
5/28/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
5/28/2025	1702 MOONRIVER CT	Subdivision	Maintenance	SC
5/28/2025	1111 VALE RD	Residential	Construction	SW
5/28/2025	2014 EMMORTON RD	Commercial	Reinspection	SC
5/28/2025	2010 MOUNTAIN RD	Commercial	Complaint	SC
5/28/2025	508 PULASKI HWY	Commercial	Maintenance	SC
5/28/2025	2809 BELCAMP RD	Residential	Maintenance	SC
5/28/2025	800 W Jarrettsville RD	Residential	Maintenance	SC
5/28/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
5/28/2025	3727 Old Federal Hill Road	Residential	Maintenance	SC
5/28/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
5/28/2025	115 Magnolia Rd	Forested	Complaint	SC
5/28/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
5/28/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
5/28/2025	100 THOMAS RUN RD	Institutional	Reinspection	SC
5/28/2025	3532 MILLER RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/28/2025	0 HANSON RD	Subdivision	Maintenance	SC
5/29/2025	301 WHEEL RD	Subdivision	Maintenance	SC
5/29/2025	2509 PORT LN	Subdivision	Maintenance	SC
5/29/2025	805 THOMAS RUN RD	Residential	Maintenance	SC
5/29/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
5/29/2025	1373 TRAPPE RD	Residential	Maintenance	SC
5/29/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
5/29/2025	12 YEARLING DR	Residential	Pre-Inspection	SC
5/29/2025	1924 PLEASANTVILLE RD	Subdivision	Reinspection	SC
5/29/2025	11 NEWPORT DR	Commercial	Maintenance	SC
5/29/2025	331 MARINA AVE	Residential	Maintenance	SC
5/29/2025	2300 EDWARDS LN	Residential	Maintenance	SC
5/29/2025	0 MAGNOLIA RD		Maintenance	SC
5/29/2025	2503 S TOLLGATE RD	Commercial	Maintenance	SC
5/29/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
5/29/2025	0 PURPLE PL	Subdivision	Maintenance	SC
5/29/2025	12 YEARLING DR	Residential	Pre-Con	SW
5/29/2025	1989 MITCHELL DR	Residential	Maintenance	SC
5/29/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
5/29/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
5/30/2025	1657 Robin CIR	Commercial	Maintenance	SC
5/30/2025	18 ROCKDALE AVE	Residential - Single	Construction	SW
5/30/2025	2300 EDWARDS LN	Residential - Single		SW
5/30/2025	2034 CHAPEL RD	Residential - Single	Pre-Con	SW
5/30/2025	1657B Robin CIR	Commercial	Maintenance	SC
5/30/2025	0 CHELSEA RD	Commercial		SC
5/30/2025	2800 E MEDICAL HALL RD	Residential	Final	SC
5/30/2025	1725 O'CONNER RD	Residential	Construction	SW
5/30/2025	17 ROCKDALE AVE	Residential	Reinspection	SC
5/30/2025	3538 ALDINO RD	Commercial	Maintenance	SC
5/30/2025	1725 O'CONNER RD	Residential	Maintenance	SC
5/30/2025	2300 & 2302 Grafton Shop Road	Institutional	Reinspection	SC
5/30/2025	Inspection Number: 025950-2025	Capital Project	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
5/30/2025	18 ROCKDALE AVE	Residential	Reinspection	SC
5/30/2025	2034 CHAPEL RD	Residential	Pre-Inspection	SC
5/30/2025	0 VAN BIBBER RD	Residential	Reinspection	SC
5/30/2025	1615 INGLESIDE RD	Residential	Maintenance	SC
5/30/2025	1015 PULASKI HWY	Commercial	Maintenance	SC
5/30/2025	2703 FALLSBROOKE MANOR DR	Residential		SC
5/30/2025	1501 PERRYMAN RD	Commercial	Maintenance	SC
5/30/2025	3314 THOMAS BRIDGE RD	Residential - Single	Construction	SW
5/30/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
5/30/2025	3314 THOMAS BRIDGE RD	Residential	Maintenance	SC
5/30/2025	1225 BUSH RD	Residential	Maintenance	SC
5/30/2025	664 Trimble RD	Subdivision	Maintenance	SC
6/2/2025	2208 KALMIA RD	Residential	Maintenance	SC
6/2/2025	338 EARLTON RD	Residential	Maintenance	SC
6/2/2025	2822 CHARLES ST	Residential	Maintenance	SC
6/2/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
6/2/2025	5129 FAWN GROVE RD	Residential	Maintenance	SC
6/2/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
6/2/2025	1430 QUAKER CHURCH RD	Residential		SC
6/2/2025	4144 WEBSTER LAPIDUM RD	Residential	Maintenance	SC
6/2/2025	1215 BALTIMORE PIKE	Commercial		SC
6/2/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
6/2/2025	2822 CHARLES ST	Residential	Construction	SW
6/2/2025	903 OLD PYLESVILLE RD		Construction	SW
6/2/2025	120 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
6/2/2025	420 HIOB LN	Commercial	Maintenance	SC
6/2/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
6/2/2025	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
6/2/2025	20 FORT HOYLE RD	Residential - Single		SW
6/2/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
6/2/2025	0 NUTTAL AVE	Capital Project	Maintenance	SC
6/2/2025	12 YEARLING DR	Residential	Installation	SC
6/2/2025	672 ROCK SPRING CHURCH RD	Residential	Complaint	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/2/2025	0 HANSON RD	Subdivision	Complaint	SC
6/3/2025	1605 ALGONQUIN CT	Residential - Single	Construction	SW
6/3/2025	300 PULASKI HWY		Maintenance	SC
6/3/2025	1410 THOMAS RUN RD	Residential	Construction	SW
6/3/2025	514 JOPPA FARM RD		Complaint	SC
6/3/2025	0 WOODBRIDGE CENTER WAY		Pre-Inspection	SC
6/3/2025	1222 TOLLGATE RD	Residential	Maintenance	SC
6/3/2025	2119-A ALLIBONE RD	Residential	Maintenance	SC
6/3/2025	1373 TRAPPE RD	Residential - Single	Request As-Built	SW
6/3/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
6/3/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
6/3/2025	672 ROCK SPRING CHURCH RD	Residential - Single	Construction	SW
6/3/2025	0 Whiteford and Rocks RD	Commercial	Maintenance	SC
6/3/2025	852 STANSBURY RD	Residential	Maintenance	SC
6/3/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
6/3/2025	852 STANSBURY RD	Residential	Construction	SW
6/3/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
6/3/2025	1408 THOMAS RUN RD	Residential - Single	Construction	SW
6/3/2025	319 COOLEY MILL RD	Residential	Maintenance	SC
6/3/2025	0 WOODBRIDGE CENTER WAY		Pre-Con	SW
6/3/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
6/3/2025	2014 PACKARD DR	Residential	Reinspection	SC
6/3/2025	0 MAGNOLIA RD		Maintenance	SC
6/3/2025	4108 FEDERAL HILL RD	Residential	Maintenance	SC
6/3/2025	2303 CARRS MILL RD	Capital Project		SW
6/3/2025	3924 NORRISVILLE RD	Residential	Maintenance	SC
6/3/2025	3924 NORRISVILLE RD	Residential - Single	Construction	SW
6/3/2025	1714 RIDGE RD	Residential		SC
6/3/2025	711 PHILADELPHIA RD	Commercial	Complaint	SC
6/4/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
6/4/2025	3301 WILLOUGHBY BEACH RD		Pre-Con	SW
6/4/2025	1614 KINGS VIEW DR	Residential	Reinspection	SC
6/4/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/4/2025	1300 BUSINESS CENTER WAY		Maintenance	SC
6/4/2025	3146 OLD YORK RD	Residential - Single	Construction	SW
6/4/2025	1304 NORRIS RD		Maintenance	SC
6/4/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
6/4/2025	1527 WHITEFORD RD	Capital Project	Maintenance	SC
6/4/2025	0 MANTLEWOOD WAY	Residential	Reinspection	SC
6/4/2025	1827 BALDWIN MILL RD	Residential	Final	SC
6/4/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
6/4/2025	401 THOMAS RUN RD	Institutional	Reinspection	SC
6/4/2025	100 THOMAS RUN RD	Institutional	Reinspection	SC
6/4/2025	2000 CALVARY RD	Commercial	Maintenance	SC
6/4/2025	3146 OLD YORK RD	Residential	Maintenance	SC
6/4/2025	1007 PROSPECT MILL RD	Residential	Maintenance	SC
6/4/2025	2915 Laurel Bush Road	Subdivision	Maintenance	SC
6/4/2025	3144 OLD YORK RD	Residential	Maintenance	SC
6/4/2025	0 SILVERSIDE RD		Pre-Inspection	SC
6/4/2025	3205 SUDATH LN	Residential	Maintenance	SC
6/4/2025	0 HANSON RD	Subdivision	Maintenance	SC
6/5/2025	913 FAWN CT		Maintenance	SC
6/5/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
6/5/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
6/5/2025	5640 LONG CORNER RD	Residential	Maintenance	SC
6/5/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
6/5/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
6/5/2025	5640 LONG CORNER RD	Residential - Single	Construction	SW
6/5/2025	301 WHEEL RD	Subdivision	Maintenance	SC
6/5/2025	950 OLD JOPPA CT	Residential	Maintenance	SC
6/5/2025	510 RIVIERA DR	Commercial	Complaint	SC
6/5/2025	2421 HARKINS RD	Residential	Maintenance	SC
6/5/2025	3144 OLD YORK RD		Construction	SW
6/5/2025	1897 CHURCHVILLE RD	Residential	Maintenance	SC
6/5/2025	4998 JOLLY ACRES RD	Residential		SW
6/5/2025	4998 JOLLY ACRES RD	Residential		SW

# *Inspections By Date*

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/5/2025	1915 FOUNTAIN GREEN RD	Commercial	Reinspection	SC
6/5/2025	900-H Cedar Crest Ct		Complaint	SC
6/5/2025	904 EDGEWOOD RD	Commercial	Maintenance	SC
6/5/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
6/5/2025	3663 CHURCHVILLE RD	Government / Institutional	Pre-Con	SW
6/5/2025	2248 GIBSON RD	Residential	Maintenance	SC
6/5/2025	100 KEARNEY DR	Capital Project	Maintenance	SC
6/6/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
6/6/2025	5125 CAREA RD	Residential	Maintenance	SC
6/6/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision	Maintenance	SC
6/6/2025	1410 THOMAS RUN RD	Residential	Request As-Built	SW
6/6/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
6/6/2025	2697 COMPROMISE ST	Commercial	Construction	SW
6/6/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
6/6/2025	2110 BEL AIR RD	Commercial		SC
6/6/2025	508 PULASKI HWY	Commercial	Maintenance	SC
6/6/2025	North of Rt 7 West of Burnt Hill Road	Subdivision	Maintenance	SC
6/6/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
6/6/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
6/6/2025	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
6/6/2025	2626 TALL OAKS DR	Subdivision	Maintenance	SC
6/6/2025	2688 COMPROMISE ST	Commercial	Construction	SW
6/6/2025	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
6/6/2025	3505 BERKLEY RD	Residential	Maintenance	SC
6/6/2025	4624 MERCEDES DR	Commercial		SC
6/9/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
6/9/2025	2034 CHAPEL RD	Residential	Installation	SC
6/9/2025	2205 WILLOUGHBY BEACH RD	Residential	Complaint	SC
6/9/2025	2874 DUBLIN RD		Installation	SC
6/9/2025	34 MC DERMOTT RD	Residential - Single	Construction	SW
6/9/2025	0 CEDAR DR	Commercial	Maintenance	SC
6/9/2025	1657 Robin CIR	Commercial	Maintenance	SC
6/9/2025	2303 CARRS MILL RD	Capital Project	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/9/2025	103 KENNARD AVE		Maintenance	SC
6/9/2025	1812 WALTON RD	Commercial		SC
6/9/2025	2822 CHARLES ST	Residential	Maintenance	SC
6/9/2025	0 ARDEN DR	Subdivision	Reinspection	SC
6/9/2025	2013 PACKARD DR	Residential	Final	SC
6/9/2025	3663 CHURCHVILLE RD	Institutional	Maintenance	SC
6/9/2025	1929 SUSQUEHANNA HALL RD	Institutional	Maintenance	SC
6/9/2025	2035 CONNOLLY RD	Subdivision	Reinspection	SC
6/9/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
6/10/2025	417-A Calvary RD	Residential	Maintenance	SC
6/10/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
6/10/2025	3040 LEVEL RD	Residential	Maintenance	SC
6/10/2025	1516 JONES RD	Residential	Maintenance	SC
6/10/2025	1111 VALE RD	Residential	Maintenance	SC
6/10/2025	2915 Laurel Bush Road	Subdivision	Maintenance	SC
6/10/2025	2309 SNOW RD	Residential	Maintenance	SC
6/10/2025	781 PRIESTFORD RD	Residential	Maintenance	SC
6/10/2025	1121 DEER CREEK CHURCH RD	Residential - Single	Construction	SW
6/10/2025	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
6/10/2025	3935 PROSPECT RD	Residential	Installation	SC
6/10/2025	2718 ADY RD	Residential - Single	Construction	SW
6/10/2025	2718 ADY RD	Residential	Maintenance	SC
6/10/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
6/10/2025	1111 VALE RD	Residential	Request As-Built	SW
6/10/2025	11 NEWPORT DR	Commercial	Maintenance	SC
6/10/2025	3040 LEVEL RD		Construction	SW
6/10/2025	103 MATTE LN	Residential	Maintenance	SC
6/10/2025	529 PRITT LN	Residential	Maintenance	SC
6/10/2025	4024 PROSPECT RD	Residential	Maintenance	SC
6/10/2025	1534 Jones RD	Residential	Maintenance	SC
6/10/2025	3632 PROSPECT RD	Residential	Maintenance	SC
6/10/2025	3808 SEWELL RD	Residential	Maintenance	SC
6/11/2025	3532 MILLER RD	Residential - Single	Construction	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/11/2025	0 MANTLEWOOD WAY	Residential	Reinspection	SC
6/11/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
6/11/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
6/11/2025	2014 EMMORTON RD	Commercial	Reinspection	SC
6/11/2025	3144 OLD YORK RD	Residential	Maintenance	SC
6/11/2025	3146 OLD YORK RD	Residential	Complaint	SC
6/11/2025	3727 Old Federal Hill Road	Residential	Maintenance	SC
6/11/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
6/11/2025	508 PULASKI HWY	Commercial	Maintenance	SC
6/11/2025	1307 GOLDMEADOW - 1319 WAY	Residential	Complaint	SC
6/11/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
6/11/2025	3532 MILLER RD	Residential	Maintenance	SC
6/11/2025	2600 TOBIN CROSSING	Commercial	Construction	SW
6/11/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
6/11/2025	Inspection Number: 018562-2025		Maintenance	SW
6/11/2025	1307 GOLDMEADOW - 1319 WAY	Residential	Complaint	SC
6/11/2025	800 W Jarrettsville RD	Residential	Maintenance	SC
6/11/2025	1614 KINGS VIEW DR	Residential	Reinspection	SC
6/11/2025	2300 EDWARDS LN	Residential	Maintenance	SC
6/11/2025	10 YEARLING DR	Residential	Maintenance	SC
6/11/2025	0 HANSON RD	Subdivision	Maintenance	SC
6/12/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
6/12/2025	2503 S TOLLGATE RD	Commercial	Maintenance	SC
6/12/2025	2113 NUTTAL AVE	Residential	Maintenance	SW
6/12/2025	2595 MEDICAL HALL RD	Residential	Maintenance	SC
6/12/2025	805 THOMAS RUN RD	Residential - Single	Construction	SW
6/12/2025	2300 & 2302 Grafton Shop Road	Institutional	Reinspection	SC
6/12/2025	1373 TRAPPE RD	Residential	Maintenance	SC
6/12/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
6/12/2025	0 PURPLE PL	Subdivision	Maintenance	SC
6/12/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
6/12/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
6/12/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/12/2025	1212 CHELSEA RD	Capital Project	Maintenance	SC
6/12/2025	2226 ROCK SPRING RD	Subdivision	Pre-Inspection	SC
6/12/2025	2509 PORT LN	Subdivision	Maintenance	SC
6/12/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
6/12/2025	805 THOMAS RUN RD	Residential	Maintenance	SC
6/12/2025	1989 MITCHELL DR	Residential	Maintenance	SC
6/12/2025	331 MARINA AVE	Residential	Maintenance	SC
6/13/2025	3026 SNAKE LN	Residential	Maintenance	SC
6/13/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
6/13/2025	2915 Laurel Bush Road	Residential	Complaint	SC
6/13/2025	1373 TRAPPE RD	Residential - Single		SW
6/13/2025	301 WHEEL RD	Subdivision	Maintenance	SC
6/13/2025	1035 JOPPA RD	Commercial	Complaint	SC
6/13/2025	1725 O'CONNER RD	Residential	Maintenance	SC
6/13/2025	1924 PLEASANTVILLE RD	Subdivision	Reinspection	SC
6/13/2025	1501 PERRYMAN RD	Commercial	Final	SC
6/13/2025	Inspection Number: 028691-2025	Capital Project	Maintenance	SC
6/13/2025	2874 DUBLIN RD		Maintenance	SC
6/13/2025	121 HOPEWELL RD	Residential	Maintenance	SC
6/13/2025	17 ROCKDALE AVE	Residential	Reinspection	SC
6/13/2025	11 NEWPORT DR	Commercial	Reinspection	SC
6/13/2025	18 ROCKDALE AVE	Residential	Maintenance	SC
6/13/2025	119 HOPEWELL RD	Residential	Maintenance	SC
6/13/2025	3538 ALDINO RD	Commercial	Maintenance	SC
6/13/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
6/13/2025	1615 INGLESIDE RD	Residential	Maintenance	SC
6/13/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
6/13/2025	0 HANSON RD	Subdivision		SC
6/13/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
6/13/2025	3314 THOMAS BRIDGE RD	Residential	Maintenance	SC
6/13/2025	1225 BUSH RD	Residential	Maintenance	SC
6/13/2025	5129 FAWN GROVE RD	Residential	Maintenance	SC
6/13/2025	415 GLENWOOD RD		Maintenance	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/13/2025	2651 PEERY DR		Maintenance	SW
6/13/2025	2651 PEERY DR		Maintenance	SW
6/16/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
6/16/2025	1657B Robin CIR	Commercial	Maintenance	SC
6/16/2025	1657 Robin CIR	Commercial	Reinspection	SC
6/16/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
6/16/2025	2915 Laurel Bush Road	Residential		SC
6/16/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
6/16/2025	617 MAHAN RD	Residential	Final	SC
6/16/2025	4144 WEBSTER LAPIDUM RD	Residential	Maintenance	SC
6/16/2025	0 SHINGLE OAK CT	Residential	Maintenance	SC
6/16/2025	11 NEWPORT DR	Commercial	Reinspection	SC
6/16/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
6/16/2025	12 YEARLING DR	Residential	Maintenance	SC
6/16/2025	120 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
6/16/2025	0 MANTLEWOOD WAY	Residential	Maintenance	SC
6/17/2025	711 PHILADELPHIA RD	Commercial	Complaint	SC
6/17/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
6/17/2025	514 JOPPA FARM RD		Complaint	SC
6/17/2025	2300 PUTNAM RD		Sediment Phase	SW
6/17/2025	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
6/17/2025	2915 Laurel Bush Road	Subdivision	Reinspection	SC
6/17/2025	1222 TOLLGATE RD	Residential	Maintenance	SC
6/17/2025	4108 FEDERAL HILL RD	Residential - Single	Construction	SW
6/17/2025	2014 PACKARD DR	Residential	Maintenance	SC
6/17/2025	604 SUGAR HILL RD	Residential	Maintenance	SC
6/17/2025	319 COOLEY MILL RD	Residential	Maintenance	SC
6/17/2025	1527 WHITEFORD RD	Capital Project	Maintenance	SC
6/17/2025	2020 PACKARD DR	Subdivision	Maintenance	SC
6/17/2025	2809 BELCAMP RD	Residential	Maintenance	SC
6/17/2025	0 MAGNOLIA RD		Maintenance	SC
6/17/2025	2528 COOL SPRING RD		Maintenance	SC
6/17/2025	1906 SUSQUEHANNA HALL RD	Residential - Single	Pre-Con	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/17/2025	354 OLD BAY LN	Commercial	Maintenance	SC
6/17/2025	4108 FEDERAL HILL RD	Residential	Maintenance	SC
6/17/2025	300 PULASKI HWY		Maintenance	SC
6/17/2025	1906 SUSQUEHANNA HALL RD	Residential	Pre-Inspection	SC
6/17/2025	4501 SLATE RIDGE RD		Pre-Con	SW
6/17/2025	4501 SLATE RIDGE RD	Residential	Maintenance	SC
6/17/2025	2014 PACKARD DR		Construction	SW
6/18/2025	2029 CONNOLLY RD	Residential	Construction	SW
6/18/2025	2119-A ALLIBONE RD	Residential	Maintenance	SC
6/18/2025	1007 PROSPECT MILL RD	Residential	Maintenance	SC
6/18/2025	0 HARFORD SQUARE DR	Capital Project	Maintenance	SC
6/18/2025	2208 KALMIA RD	Residential	Maintenance	SC
6/18/2025	1215 BALTIMORE PIKE	Commercial	Maintenance	SC
6/18/2025	598 MOUNTAIN RD	Residential	Maintenance	SC
6/18/2025	Inspection Number: 031063-2025		Request As-Built	SW
6/18/2025	2035 CONNOLLY RD	Subdivision	Reinspection	SC
6/18/2025	1702 MOONRIVER CT	Subdivision	Maintenance	SC
6/18/2025	Inspection Number: 018817-2025		Request As-Built	SW
6/18/2025	0 INDIANSUMMER CT	Residential	Request As-Built	SW
6/18/2025	2201 OLD JOPPA RD	Residential	Maintenance	SC
6/18/2025	100 THOMAS RUN RD	Institutional	Maintenance	SC
6/18/2025	3144 OLD YORK RD	Residential	Maintenance	SC
6/18/2025	2915 Laurel Bush Road	Subdivision	Maintenance	SC
6/18/2025	3924 NORRISVILLE RD	Residential	Maintenance	SC
6/18/2025	1319 PERRYMAN RD	Commercial	Maintenance	SC
6/18/2025	1623 SHADY TREE CT	Subdivision	Maintenance	SC
6/18/2025	3205 SUDATH LN	Residential	Maintenance	SC
6/18/2025	1304 NORRIS RD		Maintenance	SC
6/18/2025	1924 PLEASANTVILLE RD	Subdivision	Reinspection	SC
6/18/2025	3146 OLD YORK RD	Residential	Maintenance	SC
6/18/2025	852 STANSBURY RD	Residential	Maintenance	SC
6/18/2025	401 THOMAS RUN RD	Institutional	Maintenance	SC
6/18/2025	510 RIVIERA DR	Commercial		SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/18/2025	950 OLD JOPPA CT	Residential	Maintenance	SC
6/18/2025	0 VAN BIBBER RD	Residential	Maintenance	SC
6/18/2025	0 Whiteford and Rocks Road	Commercial	Maintenance	SC
6/18/2025	2000 CALVARY RD	Commercial	Maintenance	SC
6/18/2025	913 FAWN CT		Maintenance	SC
6/18/2025	2874 DUBLIN RD		Construction	SW
6/18/2025	0 HYSOP CT	Subdivision	Maintenance	SC
6/19/2025	104 MOONLIGHT DR	Subdivision	Maintenance	SC
6/19/2025	10 MC GREGOR WAY	Residential	Maintenance	SC
6/19/2025	2300 & 2302 Grafton Shop Road	Institutional	Reinspection	SC
6/19/2025	0 Whiteford and Rocks RD	Commercial	Maintenance	SC
6/19/2025	1897 CHURCHVILLE RD	Residential	Maintenance	SC
6/19/2025	1915 FOUNTAIN GREEN RD	Commercial	Reinspection	SC
6/20/2025	2013 PACKARD DR	Residential		SC
6/20/2025	2421 HARKINS RD	Residential - Single	Construction	SW
6/20/2025	2309 ADY RD	Residential	Complaint	SC
6/20/2025	5125 CAREA RD	Residential	Maintenance	SC
6/20/2025	2421 HARKINS RD	Residential	Maintenance	SC
6/20/2025	3505 BERKLEY RD	Residential - Single	Construction	SW
6/20/2025	1300 BUSINESS CENTER WAY		Maintenance	SC
6/20/2025	0 NUTTAL AVE	Capital Project	Final	SC
6/20/2025	2626 TALL OAKS DR	Subdivision	Maintenance	SC
6/20/2025	812 OLD JOPPA RD	Residential	Maintenance	SC
6/20/2025	2208 CONNOLLY RD	Commercial	Maintenance	SC
6/20/2025	3505 BERKLEY RD	Residential	Maintenance	SC
6/20/2025	1915 FOUNTAIN GREEN RD	Commercial	Construction	SW
6/20/2025	0 CEDAR DR	Commercial	Maintenance	SW
6/20/2025	2611 CHESTNUT HILL RD	Residential	Maintenance	SC
6/20/2025	1127 Belcamp Garth	Capital Project	Maintenance	SC
6/20/2025	1307 GOVERNOR CT	Commercial	Maintenance	SC
6/20/2025	0 VAN BIBBER RD	Commercial	Maintenance	SC
6/20/2025	2248 GIBSON RD	Residential	Maintenance	SC
6/20/2025	1897 CHURCHVILLE RD	Residential	Maintenance	SC

# *Inspections By Date*

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/20/2025	North of MD Rt 7 West of Burnt Hill Trail	Subdivision		SC
6/20/2025	5640 LONG CORNER RD	Residential	Maintenance	SC
6/20/2025	2014 PACKARD DR		Request As-Built	SW
6/23/2025	2034 CHAPEL RD	Residential	Installation	SC
6/23/2025	2822 CHARLES ST	Residential	Final	SW
6/23/2025	301 WHEEL RD	Subdivision	Maintenance	SC
6/23/2025	0 ARDEN DR	Subdivision	Maintenance	SC
6/23/2025	1319 PERRYMAN RD	Commercial	Final	SC
6/23/2025	0 CEDAR DR	Commercial	Maintenance	SW
6/23/2025	0 CEDAR DR	Commercial	Maintenance	SC
6/23/2025	1605 ALGONQUIN CT	Residential	Maintenance	SC
6/23/2025	1905 ROCKSPRING RD	Commercial	Maintenance	SC
6/23/2025	34 MC DERMOTT RD	Residential	Maintenance	SC
6/23/2025	420 HIOB LN	Commercial	Maintenance	SC
6/23/2025	601 W JARRETTSVILLE RD		Construction	SW
6/23/2025	2303 CARRS MILL RD	Capital Project	Request As-Built	SW
6/23/2025	103 KENNARD AVE		Maintenance	SC
6/23/2025	2205 WILLOUGHBY BEACH RD	Residential	Maintenance	SC
6/23/2025	2822 CHARLES ST	Residential	Maintenance	SC
6/23/2025	Inspection Number: 033525-2025		Request As-Built	SW
6/24/2025	2915 Laurel Bush Road	Subdivision	Maintenance	SC
6/24/2025	4024 PROSPECT RD	Residential	Construction	SW
6/24/2025	1111 VALE RD	Residential	Maintenance	SC
6/24/2025	1516 JONES RD	Residential - Single	Construction	SW
6/24/2025	3935 PROSPECT RD	Residential	Installation	SC
6/24/2025	1121 DEER CREEK CHURCH RD	Residential	Maintenance	SC
6/24/2025	4024 PROSPECT RD	Residential	Maintenance	SC
6/24/2025	1416 & 1418 Philadelphia RD	Commercial	Maintenance	SC
6/24/2025	529 PRITT LN	Residential	Final	SC
6/24/2025	3808 SEWELL RD	Residential	Maintenance	SC
6/24/2025	1534 Jones RD	Residential - Single	Construction	SW
6/24/2025	100 KEARNEY DR	Capital Project	Final	SC
6/24/2025	319 COOLEY MILL RD	Residential - Single	Request As-Built	SW

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/24/2025	2874 DUBLIN RD		Maintenance	SC
6/24/2025	2309 SNOW RD	Residential	Maintenance	SC
6/24/2025	4501 SLATE RIDGE RD	Residential	Maintenance	SC
6/24/2025	3632 PROSPECT RD	Residential	Maintenance	SC
6/24/2025	1534 Jones RD	Residential	Maintenance	SC
6/24/2025	2020 PACKARD DR	Subdivision	Reinspection	SC
6/24/2025	2600 TOBIN CROSSING	Commercial	Maintenance	SC
6/24/2025	3632 PROSPECT RD	Residential	Construction	SW
6/24/2025	338 EARLTON RD	Residential	Maintenance	SC
6/24/2025	1516 JONES RD	Residential	Maintenance	SC
6/24/2025	3314 ABINGDON RD	Commercial	Maintenance	SC
6/24/2025	2718 ADY RD	Residential	Maintenance	SC
6/25/2025	3532 MILLER RD	Residential	Maintenance	SC
6/25/2025	0 GRAVEL HILL RD	Commercial		SC
6/25/2025	531 CHELSEA RD	Commercial	Complaint	SC
6/25/2025	1307 GOLDMEADOW - 1319 WAY	Residential		SC
6/25/2025	2215 CHURCHVILLE RD	Commercial	Maintenance	SC
6/25/2025	1614 KINGS VIEW DR	Residential	Maintenance	SC
6/25/2025	2300 EDWARDS LN	Residential	Maintenance	SC
6/25/2025	1301 GOVERNOR CT	Commercial	Maintenance	SC
6/25/2025	417-A Calvary RD	Residential	Maintenance	SC
6/25/2025	3727 Old Federal Hill Road	Residential	Maintenance	SC
6/25/2025	800 W Jarrettsville RD	Residential	Maintenance	SC
6/25/2025	531 CHELSEA RD			SC
6/25/2025	2509 MOUNTAIN RD	Residential	Maintenance	SC
6/25/2025	1623 SHADY TREE CT	Subdivision	Reinspection	SC
6/25/2025	781 PRIESTFORD RD	Residential	Maintenance	SC
6/25/2025	2315 BEL AIR RD	Commercial	Maintenance	SC
6/25/2025	0 GRAVEL HILL RD	Commercial	Maintenance	SC
6/25/2025	607-E DEMBYTOWN RD	Residential	Maintenance	SC
6/25/2025	2101 GLEN COVE RD	Residential	Maintenance	SC
6/25/2025	2647 HOOPES RD		Installation	SC
6/25/2025	1929 SUSQUEHANNA HALL RD	Institutional	Maintenance	SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/25/2025	2014 EMMORTON RD	Commercial	Reinspection	SC
6/25/2025	508 PULASKI HWY	Commercial	Maintenance	SC
6/25/2025	3801 PEACH ORCHARD RD	Institutional	Maintenance	SC
6/25/2025	0 HYSSOP CT	Subdivision	Maintenance	SC
6/26/2025	1408 THOMAS RUN RD	Residential	Maintenance	SC
6/26/2025	1112 MOORES MILL RD	Subdivision	Pre-Inspection	SC
6/26/2025	2595 MEDICAL HALL RD	Residential	Maintenance	SC
6/26/2025	North of Rt 7 West of Burnt Hill Road	Subdivision	Maintenance	SC
6/26/2025	1373 TRAPPE RD	Residential	Maintenance	SC
6/26/2025	2226 ROCK SPRING RD	Subdivision	Maintenance	SC
6/26/2025	2503 S TOLLGATE RD	Commercial	Maintenance	SC
6/26/2025	1410 THOMAS RUN RD	Residential	Maintenance	SC
6/26/2025	2113 NUTTAL AVE	Subdivision	Maintenance	SC
6/26/2025	1112 MOORES MILL RD	Residential	Pre-Con	SW
6/26/2025	1111 VALE RD	Residential		SW
6/26/2025	330 ENFIELD RD	Subdivision	Maintenance	SC
6/26/2025	103 MATTE LN	Residential	Maintenance	SC
6/26/2025	2509 PORT LN	Subdivision	Maintenance	SC
6/26/2025	805 THOMAS RUN RD	Residential	Maintenance	SC
6/26/2025	1924 PLEASANTVILLE RD	Subdivision	Reinspection	SC
6/26/2025	1897 CHURCHVILLE RD	Residential	Reinspection	SC
6/26/2025	0 PURPLE PL	Subdivision	Maintenance	SC
6/26/2025	4800 OLD PHILADELPHIA RD	Subdivision	Maintenance	SC
6/27/2025	3538 ALDINO RD	Commercial	Maintenance	SC
6/27/2025	115 Magnolia Rd	Forested	Maintenance	SC
6/27/2025	18 ROCKDALE AVE	Residential	Maintenance	SC
6/27/2025	1725 O'CONNER RD	Residential	Maintenance	SC
6/27/2025	300 PULASKI HWY			SC
6/27/2025	3314 THOMAS BRIDGE RD	Residential - Single	Construction	SW
6/27/2025	1225 BUSH RD	Residential	Maintenance	SC
6/27/2025	1725 O'CONNER RD	Residential	Construction	SW
6/27/2025	4144 WEBSTER LAPIDUM RD	Residential	Maintenance	SC
6/27/2025	0 HARFORD SQUARE DR	Capital Project		SC

# Inspections By Date

From 7/ 1/2024 to 6/30/2025

<i>Start Date</i>	<i>Address</i>	<i>Property Type</i>	<i>Purpose</i>	<i>Type</i>
6/27/2025	Inspection Number: 031768-2025	Capital Project	Maintenance	SC
6/27/2025	10 YEARLING DR	Residential	Maintenance	SC
6/27/2025	16 ROCKDALE AVE	Residential	Maintenance	SC
6/27/2025	12 YEARLING DR	Residential	Maintenance	SC
6/27/2025	0 Surf Scoter LA	Subdivision	Maintenance	SC
6/27/2025	1915 FOUNTAIN GREEN RD	Commercial	Construction	SW
6/27/2025	3663 CHURCHVILLE RD	Institutional	Maintenance	SC
6/27/2025	1915 FOUNTAIN GREEN RD	Commercial	Maintenance	SC
6/27/2025	1203 TECHNOLOGY DR	Commercial	Maintenance	SC
6/27/2025	17 ROCKDALE AVE	Residential	Maintenance	SC
6/27/2025	0 Whiteford and Rocks RD	Commercial		SC
6/27/2025	301 WHEEL RD	Subdivision	Maintenance	SC
6/27/2025	3314 THOMAS BRIDGE RD	Residential	Maintenance	SC
6/27/2025	510 RIVIERA DR		Maintenance	SC
6/27/2025	1615 INGLESIDE RD	Residential	Maintenance	SC
6/30/2025	672 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
6/30/2025	608 PHILADELPHIA RD	Commercial	Maintenance	SC
6/30/2025	5129 FAWN GROVE RD	Residential	Final	SC
6/30/2025	903 OLD PYLESVILLE RD	Residential	Maintenance	SC
6/30/2025	40 FORT HOYLE RD	Commercial	Maintenance	SC
6/30/2025	2010 MOUNTAIN RD	Commercial	Complaint	SC
6/30/2025	20 FORT HOYLE RD	Residential	Maintenance	SC
6/30/2025	11 NEWPORT DR	Commercial	Maintenance	SC
6/30/2025	120 ROCK SPRING CHURCH RD	Residential	Maintenance	SC
6/30/2025	1657B Robin CIR	Commercial	Maintenance	SC
6/30/2025	903 OLD PYLESVILLE RD		Construction	SW
6/30/2025	2208 KALMIA RD	Residential	Maintenance	SC
6/30/2025	1657 Robin CIR	Commercial	Maintenance	SC

Number of SC Inspections           **3,840**  
Number of SW Inspections       **676**  
Number of Inspections           **4,516**

# Harford County Department of Public Works Stormwater Management Inspection Manual

*Prepared for*



**BOB CASSILLY**  
COUNTY EXECUTIVE

Harford County Department of Public Works  
212 S Bond Street  
3rd Floor  
Bel Air, MD 21014  
*Prepared by*



EA Engineering, Science, and Technology, Inc., PBC  
225 Schilling Circle, Suite 400  
Hunt Valley, Maryland 21031  
410-584-7000

December 2023  
Version: FINAL

*This page intentionally left blank*

**CONTENTS**

	<u>Page</u>
LIST OF TABLES.....	iv
LIST OF APPENDIXES AND FIGURES .....	v
LIST OF ACRONYMS AND ABBREVIATIONS .....	xi
TERMS AND DEFINITIONS .....	xii
1. INTRODUCTION/PURPOSE .....	1
1.1 RESPONSIBLE PARTIES.....	1
1.2 REGULATORY REQUIREMENTS.....	1
1.2.1 Harford County Code 214 Article II Stormwater Quantity and Quality Management .....	1
1.2.2 COMAR 26.17.02.11 Maintenance Inspection .....	1
1.2.3 Municipal Separate Storm Sewer System Discharge Permit.....	2
2. GENERAL PROCEDURES.....	3
2.1 INSPECTION FREQUENCY .....	3
2.1.1 Notifications .....	3
2.1.2 Deficiency Notification .....	3
2.1.2 Danger to Public Health and Safety.....	4
2.1.3 Enforcement (Harford County Code Section 214-43.44).....	4
2.2 ASSESSMENT PROCEDURES .....	4
3. SYSTEM INSPECTION PARAMETERS.....	7
3.1 Initial Significant Failure Observed.....	7
3.2 INFLOW .....	8
3.2.1 Debris/Blockage .....	8
3.2.2 Inflow Sedimentation.....	8
3.2.3 Inflow Stability/Erosion.....	9
3.2.4 Inflow Condition.....	9
3.3 PRETREATMENT .....	10
3.3.1 Forebay .....	10
3.3.2 Gravel Diaphragm – Transition Strip .....	12
3.3.3 Proprietary Structure.....	12
3.4 STORMWATER MANAGEMENT FACILITY .....	12

3.4.1	Ponding .....	13
3.4.2	Embankment .....	13
3.4.3	Conveyance.....	14
3.4.4	Sediment .....	15
3.4.5	Facility Landscaping/Vegetation .....	15
3.4.6	Contamination.....	16
3.4.7	Fencing/Security/Access.....	16
3.5	PRINCIPAL OUTLET CONTROL STRUCTURE/SPILLWAY .....	16
3.5.1	Riser – Control Structure/Yard Inlet.....	16
3.5.2	Weir .....	17
3.5.3	Trash Rack .....	17
3.5.4	Valve.....	18
3.5.5	Low Flow Control.....	18
3.5.6	Outfall Pipe .....	19
3.5.7	Outfall Area .....	19
3.5.8	Riprap – Weir and Outfall Pipe .....	20
3.5.9	Emergency Spillway .....	20
3.6	MISCELLANEOUS FACILITY COMPONENTS .....	21
3.6.1	Observation Wells .....	21
3.6.2	Underdrain Cleanouts .....	21
4.	FIELD INSPECTION PROCEDURES.....	23
4.1	PREPARATION .....	23
4.1.1	Pre-Field Inspection Preparation .....	23
4.1.2	Pre-Field BMP History/Inspection Review .....	24
4.1.3	Pre-Inspection Health and Safety .....	24
4.1.4	Pre-Inspection Equipment Requirements .....	25
4.1.5	Pre-Inspection Site Access .....	25
4.1.6	Pre-Inspection Owner Confirmation.....	25
4.1.7	Pre-Inspection Owner Notification.....	26
4.2	IN-FIELD INSPECTION .....	26
4.2.1	Constituent Engagement.....	26
4.2.2	Order of Inspection .....	26
4.2.3	Access Inspection Survey .....	26
4.2.4	Missing BMPs on Inspection Field Map .....	31
5.	REPORTING, CORRECTIVE ACTIONS, AND CLOSEOUT .....	32
5.1	INSPECTION REPORT.....	32

5.2 INSPECTION Results RANKING .....35

5.3 CORRECTIVE ACTIONS AND TRACKING .....36

5.4 REINSPECTION AND CLOSEOUT.....36

6. REFERENCES .....37

Appendix A. Description and Schematic Drawings of BMPs .....A-1

Appendix B. Example Photographs of BMP Components and BMP Corrective Action Ranks.B-1

Appendix C. Common Proprietary Stormwater Treatment Systems.....C-1

**LIST OF TABLES**

Table 4-1. Stormwater Management Facility Inspection Equipment List .....25

Table 4-2. How to Access and Complete Survey123 .....27

Table 5-1. How to Generate Inspection Reports .....32

**LIST OF APPENDIXES AND FIGURES****Appendix A. Description and Schematic Drawings of BMPs**

Figure A-1-1: Sediment Forebay .....	A-0
Figure A-1.1-1: Micropool Extended Detention Pond .....	A-1
Figure A-1.1-2: Micropool Extended Detention Pond .....	A-2
Figure A-1.2-1: Wet Pond .....	A-3
Figure A-1.2-2: Wet Pond .....	A-3
Figure A-1.3-1: Wet Extended Detention Pond .....	A-4
Figure A-1.3-2: Wet Extended Detention Pond .....	A-5
Figure A-1.4-1: Multiple Pond System .....	A-6
Figure A-1.5-1: Pocket Pond .....	A-7
Figure A-1.5-2: Pocket Pond .....	A-7
Figure A-1.6-1: Dry Pond.....	A-8
Figure A-2.1-1: Shallow WetlandA- .....	A-9
Figure A-2.1-2: Shallow Wetland .....	A-10
Figure A-2.2-1: Extended Detention Shallow Wetland .....	A-11
Figure A-2.2-2: Extended Detention Shallow Wetland .....	A-11
Figure A-2.3-1: Pond/Wetland System .....	A-12
Figure A-2.3-2: Pond/Wetland System .....	A-13
Figure A-2.4-1: Pocket Wetland.....	A-14
Figure A-2.4-2: Pocket Wetland.....	A-14
Figure A-2.5-1: Submerged Gravel Wetland .....	A-15
Figure A-3.1-1: Infiltration Trench .....	A-16
Figure A-3.1-2: Infiltration Trench .....	A-16
Figure A-3.2-1: Infiltration Basin.....	A-17

Figure A-3.2-2: Infiltration Basin.....	A-18
Figure A-3.3-1: Landscape Infiltration.....	A-18
Figure A-3.4-1: Infiltration Berm.....	A-19
Figure A-3.4-2: Infiltration Berm.....	A-19
Figure A-3.5-1: Dry Well .....	A-20
Figure A-3.5-2: Dry Well .....	A-20
Figure A-3.6-1: Rain Garden.....	A-21
Figure A-3.6-2: Rain Garden.....	A-21
Figure A-4.1-1: Surface Sand Filter .....	A-23
Figure A-4.1-2: Surface Sand Filter .....	A-23
Figure A-4.2-1: Underground Sand Filter .....	A-24
Figure A-4.2-2: Underground Sand Filter – Commercial Location .....	A-25
Figure A-4.3-1: Perimeter Sand Filter.....	A-26
Figure A-4.3-2: Perimeter Sand Filter.....	A-26
Figure A-4.4-1: Organic Filter .....	A-27
Figure A-4.5-1: Pocket Sand Filter .....	A-28
Figure A-4.6-1: Bioretention .....	A-29
Figure A-4.6-2: Bioretention .....	A-29
Figure A-4.7-1: Micro-Bioretention.....	A-30
Figure A-4.7-2: Micro-Bioretention.....	A-30
Figure A-5.1-1: Disconnection of Rooftop Runoff .....	A-31
Figure A-5.1-2: Disconnection of Rooftop Runoff .....	A-32
Figure A-5.2-1: Disconnection of Non-rooftop Runoff .....	A-32
Figure A-5.2-2: Disconnection of Non-rooftop Runoff .....	A-33
Figure A-5.2-3: Disconnection of Non-rooftop Runoff – Gravel Diaphragm/Transition Strip	A-33

Figure A-5.3-1: Sheetflow to Conservation Areas .....	A-34
Figure A-5.3-2: Sheetflow to Conservation Areas .....	A-34
Figure A-5.4.1-1: Dry Swale .....	A-35
Figure A-5.4.1-2: Dry Swale .....	A-36
Figure A-5.4.2-1: Wet Swale.....	A-36
Figure A-5.4.2-2: Wet Swale.....	A-37
Figure A-5.4.2-3: Wet Swale with Check Dams .....	A-37
Figure A-5.4.3-1: Bio-Swale .....	A-38
Figure A-5.4.3-2: Bio-Swale .....	A-38
Figure A-6.1-1: Green Roof .....	A-39
Figure A-6.2-1: Permeable Pavements.....	A-40
Figure A-6.2-2: Porous Bituminous Asphalt.....	A-41
Figure A-6.2-3: Porous Cement Concrete .....	A-41
Figure A-6.2-4: Permeable Interlocking Concrete Pavers .....	A-41
Figure A-6.3-1: Synthetic Turf / Grass.....	A-42
Figure A-7.1-1: Rain Barrel .....	A-43
Figure A-7.1-2: Rain Barrel .....	A-43
Figure A-7.2-1: Stormceptor .....	A-44
Figure A-7.2-2A: Stormfilter.....	A-45
Figure A-7.2-2B: Stormfilter.....	A-45
Figure A-7.2-2C: Stormfilter.....	A-46
<b>Appendix B. Example Photos of BMP Components &amp; BMP Corrective Action Ranks</b>	
Figure B-1.1-1: Significant Failure Pond Embankment .....	B-0
Figure B-1.3-1: Significant Failure Outfall Pipe .....	B-0
Figure B-1.3-2: Significant Failure Outfall Pipe .....	B-1

Figure B-1.4-1: Unable to Inspect – Overgrown Access.....B-1

Figure B-1.4-2: Unable to Inspect – Access Road Blocked .....B-2

Figure B-2.1-1: Inflow Debris/Blockage .....B-2

Figure B-2.2-1: Inflow Sedimentation.....B-3

Figure B-2.3-1: Inflow Slope Stability .....B-3

Figure B-2.3-2: Swale Erosion .....B-4

Figure B-2.3-3: Inflow Pipe End Structure Separated.....B-4

Figure B-2.4-1: Inlet Headwall.....B-5

Figure B-2.4-2: Inlet Pipe Blockage .....B-5

Figure B-3.3.1-1: Sediment Accumulation in Forebay (Sediment Marker Present) .....B-6

Figure B-3.3.1-2: Major Sediment Accumulation in Forebay.....B-6

Figure B-3.1.2-1: Forebay Flooded .....B-7

Figure B-3.1.3-1:Forebay Obstructed by Vegetation .....B-7

Figure B-3.1.4-1: Forebay Control Structure .....B-8

Figure B-3.2-1: Gravel Diaphragm – Transition Strip .....B-8

Figure B-4.1-1: Surface Standing Water .....B-9

Figure B-4.1-2: Surface Standing Water .....B-9

Figure B-4.1-3: Surface Sand Filter Ponding – Not Draining.....B-10

Figure B-4.2-1: Embankment .....B-10

Figure B-4.2-2: Embankment .....B-11

Figure B-4.2-3: Embankment Animal Burrows .....B-11

Figure B-4.3-1: Flow Path/Pilot Channel .....B-11

Figure B-4.4-1: Sediment in Pond/Facility.....B-12

Figure B-4.5-1: Vegetation Observed in Facility .....B-12

Figure B-4.5-2: Small Area of Bare Soil in Grass Swale .....B-13

Figure B-4.5-3: Large Area of Bare Soil on Pond Bottom.....	B-13
Figure B-4.5-4: Overgrown Vegetation.....	B-14
Figure B-4. 6-1: Contamination.....	B-14
Figure B-4. 7-1: Gate Repairs Needed .....	B-15
Figure B-4. 7-2: Remove Vegetation from Fence .....	B-15
Figure B-5.1-1: Riser-Control Structure.....	B-16
Figure B-5.1-2: Riser-Control Structure.....	B-16
Figure B-5.2-1: Weir Wall.....	B-17
Figure B-5.2-2: Weir Wall - Vegetation.....	B-17
Figure B-5.3-1: Trash Racks on Riser .....	B-18
Figure B-5.3-2: Trash Racks Partially Blocked with Vegetation .....	B-18
Figure B-5.3-3: Trash Racks Blocked with Debris .....	B-19
Figure B-5.4-1: Valve.....	B-19
Figure B-5.4-2: Valve.....	B-20
Figure B-5.5-1: Low Flow Stone Clogged .....	B-20
Figure B-5.6-1: Outfall Pipe.....	B-21
Figure B-5.7-1: Outfall Area Sedimentation .....	B-21
Figure B-5.8-1: Outfall Riprap .....	B-22
Figure B-5.8-2: Outfall Riprap and Weeds, etc.....	B-22
Figure B-5.9-1: Emergency Spillway .....	B-23
Figure B-6.1-1: Observation Well .....	B-23
Figure B-6.1-2: Observation Well – Top Damaged .....	B-24
Figure B-6.2-1: Underdrain Cleanout – Cap Missing .....	B-24

**Appendix C. Common Proprietary Stormwater Treatment Systems**

Figure C.1-1: Storm Filter Cartridges.....C-0

Figure C-2-1: Stormceptor – Accumulated Debris.....C-0

**LIST OF ACRONYMS AND ABBREVIATIONS**

%	Percent
BMP	Best Management Practice
Bureau	Bureau of Stormwater Management
COMAR	Code of Maryland Regulations
Department	Harford County Department of Public Works
ESD	Environmental Site Design
ESDv	Environmental Site Design Volume
ft	Foot (feet)
GIS	Geographic information system
HDPE	High-density polyethylene
in.	Inch(es)
MDE	Maryland Department of the Environment
MS4	Municipal Separate Storm Sewer System
SGW	Submerged gravel wetland

## TERMS AND DEFINITIONS

**Abrasion** – The wearing or grinding away of material by water laden with sand, gravel, or stones.

**Aggradation** – The general and progressive rising of the streambed due to deposition of sediment.

**Aggregate** – Stone or gravel material used to fill in an infiltration Best Management Practice (BMP), such as a trench or porous pavement.

**Anti-Seep Collar** – A square plate larger than the diameter of the barrel made of steel, concrete, or polyethylene that is attached to the barrel running through an embankment of a pond that prevents seepage of water along the pipe.

**Backfill** – Material consisting of soil or stone given the appropriate application used to reestablish an excavated area.

**Backwater** – The water upstream from an obstruction in which the free surface is elevated above the normal water surface profile.

**Barrel** – Pipe that conveys flow through an embankment to the pond's outfall (Also known as Principle Spillway).

**Baseflow** – Stream flow during dry weather that is not due to storm runoff.

**Beneficial Users** – The owner(s) of a lot or parcel, the runoff from which was considered in designing a stormwater management facility to satisfy the requirements of this chapter for developing land.

**Best Management Practice (BMP)** – A structural device or nonstructural practice designed to temporarily store or treat stormwater runoff in order to mitigate flooding, reduce pollution, and provide other amenities.

**Bioretention** – A water quality practice that utilizes landscaping and soils to treat urban stormwater runoff by collecting it in shallow depressions before filtering through a fabricated planting soil media.

**Bituminous (Coating)** – Asphalt or tar material used to coat exposed metal surfaces containing bitumen; as asphalt or tar.

**Buckling** – Failure by an inelastic change in alignment (usually as a result of compression).

**Capacity** – Maximum flow rate that a channel, conduit, or structure is hydraulically capable of carrying. The units are usually cubic feet per second or gallons per minute.

**Capped Inlet** – An inlet that is covered or sealed.

**Channel Erosion** – The widening, deepening, and headward cutting of small channels and waterways, due to erosion caused by moderate to large floods.

**Check Dam** – A log or gabion structure placed perpendicular to a stream to enhance aquatic habitat and/or an earthen or log structure used in grass swales to reduce water velocities, promote sediment deposition, and enhance infiltration.

**Closed Storm Drain System** – Any system of storm drain that has an inlet, manhole, riser, or other closed structure associated with it. Inlets that flow into a driveway culvert are considered a closed system.

**Coating** – Any material used to protect the integrity of the structural elements of a pipe from the environment and add service life to the pipe.

**Compaction** – The process by which a sufficient amount of energy is applied to soil to achieve a specific density.

**Conduit** – Usually a pipe, designed to flow according to open channel equations.

**Corrosion** – Deterioration or dissolution of a material by chemical or electrochemical reaction with its environment.

**Cover** – The depth of backfill over a structure.

**Culvert** – A pipe constructed within an embankment that conveys flow from an intermittent or perennial stream.

**Debris** – Any material including floating woody materials and other trash, suspended sediment.

**Degradation** – General progressive lowering of the stream channel by erosion.

**Detention** – The temporary storage of storm runoff in a BMP, which is used to control the peak discharge rates, and which provides gravity settling of pollutants.

**Design Manual** – The 2000 Maryland Stormwater Design Manual, Volumes I and II, and all subsequent revisions, which serves as the official guide for stormwater management principles, methods and practices (Maryland Department of the Environment 2000).

**Detention Structure** – A permanent structure for the temporary storage of stormwater runoff, which is designed so as not to create a permanent pool of water.

**Ditch Intersection** – Point feature placed at the intersection of multiple ditches, beginning of a ditch if structures are not directly attached to the ditch, at the end of a ditch for the purposes of defining a ditch, or in the middle of ditches if the ditch changes type.

**Drawdown** – The gradual reduction in water level in a pond BMP.

**Dry Well** – A dry well is an underground structure that disposes of unwanted water, most commonly surface runoff and stormwater and in some cases greywater. It is a gravity-fed, vertical underground system that captures surface water from impervious surfaces, then stores and gradually infiltrates the water into the groundwater aquifer.

**Embankment** – A bank of earth, rock or material constructed above the natural ground surface over a pipe.

**Emergency Spillway** – Channel designed to convey pond overflow in a controlled manner. May also allow for a controlled breach of the embankment.

**Emergent Plants** – A rooted herbaceous plant species that has parts extending at or above the water surface. These wetland plants often have high habitat value for wildlife and waterfowl, and can aid in pollutant uptake.

**End Section** – A concrete, steel, or high-density polyethylene (HDPE) appurtenance attached to the end of a culvert for the purpose of hydraulic efficiency and anchorage. Water can flow into or out of an end section.

**Endwall** – A concrete structure placed at the outlet of a culvert or storm drain system to protect the embankment slopes, anchor the culvert, and prevent undercutting.

**Exfiltration** – The downward movement of runoff through the bottom of an infiltration BMP into the soil layer.

**Extended Detention** – A stormwater design feature that provides gradual release of a volume of water in order to increase settling of pollutants and protect downstream channels from frequent storm events.

**Flexible Pipe** – A pipe with relatively little resistance to bending. May consist of HDPE or other plastic material. Mainly used to transfer surface water runoff down a steep slope.

**Flood Frequency** – The average time interval in years in which a flow of a given magnitude, taken from an infinite series, will recur.

**Foundation** – The in-place material beneath a structure.

**Forebay** – An extra storage area provided near an inlet of a BMP to trap incoming sediments before they accumulate in a pond BMP.

**Freeboard** – The space from the top of an embankment to the highest water elevation expected for the largest design storm stored. This is required as a safety margin in a pond or basin.

**Grade/Gradient** – The longitudinal slope of the channel or pipe as a ratio of the drop in elevation to the distance.

**Grass Channel** – An open vegetated channel used to convey runoff and to provide treatment by filtering pollutants and sediments.

**Gravel Diaphragm** – A stone trench filled with small aggregate used as pretreatment and inflow regulation in stormwater filtering systems.

**Groundwater** – Water contained in the subsoil that is free to move either vertically or horizontally.

**Head Loss** – The loss of energy reported in feet of head.

**Headwall** – A concrete structure placed at the inlet of a culvert to protect the embankment slopes, anchor the culvert, and prevent undercutting.

**Headwater** – The distance between the flowline elevation at the inlet of a culvert and the water surface at the inlet.

**Hydraulics** – The mechanics of fluids, primarily water.

**Hydrology** – The science of water related to its properties and distribution in the atmosphere, on the land surface, and beneath the surface of the land.

**Hydrodynamic Structure** – An engineered structure to separate sediments and oils from stormwater runoff using gravitational separation and/or hydraulic flow.

**Infiltration** – The downward movement of water from the surface to the subsoil.

**Inlet** – A type of structure, either with or without a grate, which collects storm drain runoff.

**Inlet Control** – A pipe operates with inlet control when the flow capacity is controlled at the entrance by the depth of headwater and the entrance geometry, including the barrel shape, cross-sectional area and the inlet edge.

**Invert** – Bottom or lowest point of the internal surface of the transverse cross section of a pipe.

**Joint** – Connection between two pipe sections, made either with or without additional parts.

**Junction Box** – Box structure, usually buried, acts as a connection between pipes where invert elevations for pipes change dramatically.

**Level Spreader** – A device for distributing stormwater uniformly over the ground surface as sheet flow to prevent concentrated, erosive flows and promote infiltration.

**Low Flow Channel** – An incised or paved channel from inlet to outlet in a dry basin to carry low runoff flows and/or baseflow, directly to the outlet without detention.

**Manhole** – A structure that allows access into a stormwater drainage system and conveys water through a storm drain system.

**Metal Corrosion** – An electrical process involving an electrolyte (moisture), an anode (the metallic surface where oxidation occurs), a cathode (the metallic surface that accepts electrons and does not corrode), and a conductor (the metal pipe itself).

**Micropool** – A smaller permanent pool which is incorporated into the design of larger stormwater ponds to avoid resuspension of particles and minimize impacts to adjacent natural features.

**Minor Head Losses** – Energy lost through transitions in pipe flow such as contraction, expansion, outlets, obstructions, and bends.

**Observation Well** – A perforated pipe that is hydrologically disconnected from a BMP's hydraulic pipe system that is used to obtain subsurface water surface elevation readings.

**Open Storm Drain System** – Storm drain systems only made up of driveways and cross culverts; no closed structures such as inlets, manholes, etc. are associated with the system.

**Outfall** – In hydraulics, the discharge end of pond spillways, storm drains or sewers.

**Outlet** – A general term that indicates the discharge point from a BMP, may be similar to Outfall.

**Permeable Surface** – Permeable paving surfaces are made of either a porous material that enables stormwater to flow through it or nonporous blocks spaced so that water can flow between the gaps.

**pH Value** - The log of the reciprocal of the hydrogen ion concentration of a solution. A pH value of 7.0 is neutral; values of less than 7.0 are acid; values of more than 7.0 are alkaline.

**Pilot Channel** – See Low Flow Channel. A riprap or paved channel that routes runoff through a BMP to prevent erosion of the surface.

**Pipe Bend** – Bend in a stormwater pipe that changes direction of flow through the pipe.

**Pipe Diameter** – The inside diameter of a pipe.

**Pipe Connection** – Connection of multiple pipes, usually a smaller diameter pipe connecting to the wall of a large pipe.

**Piping** – A process of subsurface erosion in which surface runoff flows along the outside of a culvert with sufficient hydraulic gradient that erodes and carries away soil around or beneath the pipe. Piping can occur through a vegetative root system through an earth embankment.

**Ponding** – Water backed up in a channel or ditch as the result of a culvert of inadequate capacity or design to permit the water to flow unrestricted. Also, water stored within a BMP due to a control structure.

**Pre-Stressed Concrete** – In pre-tensioned concrete, the steel bars, wires, or cables are held in a stretched condition during placing of the concrete and until the concrete has hardened; then the pull on the reinforcing steel is released.

**Projecting Pipe** – Pipe that daylights with no end structure associated with the pipe.

**Pump Station** – Mechanical pump that pumps or "lifts" stormwater uphill to a high point where gravity can once again take over the process.

**Rain Garden** – A garden that lies below the level of its surroundings, designed to absorb rainwater that runs off of a surface such as a patio or roof.

**Reinforced Concrete Pipe** – Concrete pipe designed with reinforcement as a composite structure.

**Retention** – The holding of runoff in a basin without release except by means of evaporation, infiltration, emergency bypass, or a control structure that maintains a permanent pool,

**Retention Structure** – A permanent structure designed to provide storage of runoff by means of a permanent pool of water.

**Retrofit** – The modification of an existing BMP facility in order to improve the overall function. Modifications may include but are not limited to micro-topography, providing additional storage volume, additional vegetative plantings, and altering the riser structure.

**Ring Gasket** – A solid gasket of circular cross section.

**Riprap** – A combination of large stone, cobbles and boulders used to line channels, stabilize banks, and reduce runoff velocities.

**Riser** – A vertical structure extending from the bottom of a pond BMP that is used to control the discharge rate from a BMP for a specified design storm. Riser material normally consists of concrete or corrugated metal.

**Roughness Coefficient “n”** – A factor in the Manning’s equation, and other flow formulas representing the effect of channel or conduit roughness in energy losses in flowing water.

**Runoff** – That part of precipitation carried off from the area upon which it falls.

**Scour (Outlet)** – Degradation of the channel at the pipe outlet as a result of erosive velocities.

**Seepage** – The escape of water through the soil or water flowing from a fairly large area of soil instead of from one spot, as in the case of a spring. The discharge of water at a concentrated area through soil or embankment or an area of soil that is saturated to the surface.

**Sheet Flow** – Runoff that flows over the ground surface as a thin, even layer, not concentrated in a channel.

**Skew (Skew Angle)** – The acute angle formed by the intersection of the line normal to the centerline of the road with the centerline of a culvert or other structure.

**Slide** – Movement of a part of the earth (embankment) under the force of gravity that moves parallel to the slope of the embankment.

**Slump** – Movement of a part of the earth (embankment) under the force of gravity, in which the bottom of the soil mass protrudes out from the slope and the upper portion of the mass sinks down slope.

**Spalling** – The separation of surface concrete due to fractures in the concrete parallel or slightly inclined to the surface of the concrete.

**Springhead** – An inlet structure that captures flow from a natural spring and conveys water elsewhere. Seeps without a structure component are not springheads.

**Stormflow** – The portion of flow that reaches the stream shortly after a storm event.

**Stormwater Management System** – Includes natural areas, Environmental Site Design practices, stormwater management measures, and any other structure through which stormwater flows, infiltrates, or discharges from a site.

**Subgrade** – A layer of placed stone or soil used as the underlying base for a BMP.

**Substrate** – The natural soil base underlying a BMP.

**Suspended Load** – Sediment that is supported by the upward components of the turbulent currents in a streambed that stays for an appreciable length of time.

**Swale** – Natural depression or wide shallow ditch used to temporarily store, route, or filter runoff.

SWM – Storm Water Management

**Tailwater Depth** – The depth of water just downstream from a structure.

**Underdrain** - Perforated plastic pipes surrounded by stone, installed on the bottom of an infiltration BMP, bioretention, micro-bioretention, submerged gravel wetland, or sand filter, which are used to collect and remove filtered runoff.

**Watershed** – Region or area contributing stormwater runoff and groundwater discharge to the supply of a stream or waterbodies, drainage area, drainage basin, catchment area.

**Water Table** – The upper surface or top of the saturated portion of the soil layer, indicates the uppermost extent of groundwater.

**WYE-Connection** – Connection of two pipes to one pipe forming a “Y.”

*This page intentionally left blank*

## 1. INTRODUCTION/PURPOSE

The purpose of the Stormwater Management Inspection Manual is to provide Harford County personnel and their subcontractors with a comprehensive set of guidelines and procedures, based on the latest regulatory requirements, for performing stormwater management facility inspections, including documenting, and reporting the inspections, as well as subsequent inspections for those facilities that require maintenance and/or repairs.

### 1.1 RESPONSIBLE PARTIES

Harford County Bureau of Stormwater Management in the Department of Public Works (Department) is responsible for inspecting over 3,500 post-construction stormwater management facilities, both privately owned, and County owned, within the jurisdiction of the County.

### 1.2 REGULATORY REQUIREMENTS

The regulatory compliance requirements for the inspection of stormwater management facilities are based on the following:

- Harford County Code 214 Article II Stormwater Quantity and Quality Management
- Code of Maryland Regulations (COMAR) 26.17.02.11 Maintenance Inspection
- Municipal Separate Storm Sewer System (MS4) Discharge Permit

#### 1.2.1 Harford County Code 214 Article II Stormwater Quantity and Quality Management

In the Harford County Code 214 §214-24, the Department is responsible for the coordination and enforcement of the provisions of this Article. Note that under §214-39, the construction §214-42 inspections continue for a 12-month minimum time period (first year of operation) beyond the approval of the as-built plan. At the end of that 12-month period and once the construction inspection determines that the facility is in good working order, the facility is added to the Maintenance Inspection list managed by the Bureau of Stormwater Management (Bureau).

Per §214-43.A.(1) the Department shall ensure that preventative maintenance is performed by inspecting all Environmental Site Design (ESD) treatment systems and structural stormwater management measures. As noted above, inspection occurs during the first year of operation. After the first year of operation inspection, inspections are performed at least once every 3 years.

#### 1.2.2 COMAR 26.17.02.11 Maintenance Inspection

COMAR 26.17.02.11 A. “The responsible agency of the County shall ensure that preventative maintenance through inspection of all stormwater management systems.” The inspection shall occur during the first year of operation and then at least once every 3 years thereafter.

### **1.2.3 Municipal Separate Storm Sewer System Discharge Permit**

The latest Maryland Department of the Environment (MDE) MS4 Permit, issued under the National Pollutant Discharge Elimination System, became effective on 30 December 2022, and expires 29 December 2027.

The MS4 Permit under Part IV Standard Permit Conditions, Section D Management Programs, Item 1.d. (Stormwater Management) requires the County to conduct preventative maintenance inspections in accordance with COMAR 26.17.02.11 on all ESD treatment systems, structural stormwater management facilities, and stable stormwater conveyance and capacity to receiving waters, at least on a triennial basis.

## 2. GENERAL PROCEDURES

Chapter 2 provides an overview of the general procedures for performing the triennial stormwater management inspections including the inspection frequency, notification of corrective actions, and the County's assessment procedures should repairs not be performed by the beneficial users in a timely manner.

### 2.1 INSPECTION FREQUENCY

In the Harford County Code Chapter 214 §214-43, the Department is responsible for the coordination and enforcement of the provisions of this Article including performing triennial inspections.

As previously noted, the construction inspections continue for a minimum of 12 months (first year of operation) beyond the approval of the as-built plan. At the end of that 12-month period and once the construction inspection determines that the facility is in good working order and repair, the facility is added to the Bureau Maintenance Inspection list by the Bureau. Every facility has a unique BMP ID number assigned when it is added to the geographic information system (GIS) database. Once added to the list, the facility inspection is performed by the Bureau, at least once every 3 years.

#### 2.1.1 Notifications

Upon completion of the stormwater management facility inspection, a copy of the inspection report is provided to the Owner. The inspection status is tracked in the Inspection Database for use by the Office of Watershed Protection and Restoration for MS4 reporting purposes.

#### 2.1.2 Deficiency Notification

If during the inspection any deficiencies (from minor to major) are observed, the Bureau prepares and sends the inspection report to the Owner. The notification letter identifies the deficiency items to be corrected along with a clearly stated time frame for completion. Harford County requires the deficiencies to be addressed within 30-calendar days or a reasonable time frame that is mutually agreed between the Department and the Owner. The notification letter includes instructions for the Owner to coordinate follow-up inspections with the Bureau to ensure satisfactory completion of the maintenance and/or repairs. Depending on deficiency observed, the Bureau may indicate that inspection is needed during repair and that will be identified in the letter. If the deficiency observed is minor, the Bureau accepts notification and photographs of the repair as record of the work. If the deficiency observed is major, the Bureau performs a re-inspection of the facility:

- The Bureau will continue to perform inspections on a 30- to 90-day frequency until the deficiencies are addressed.
- Significant failure of a facility will automatically be 30 days for re-inspection.

- Failed will default to 90 days for re-inspection.
- Facilities that pass will be default to 3 years for re-inspection.

### **2.1.2 Danger to Public Health and Safety**

Should the result of the inspection determine that the condition of the stormwater management facility presents an immediate danger to the public health and safety, because of an unsafe condition or improper maintenance, the Department shall take such action as may be necessary to protect the public and make the facility safe. Any costs incurred by the County shall be assessed against the beneficial users (Section 2.3, Assessment Procedures provides additional information).

### **2.1.3 Enforcement (Harford County Code Section 214-43.44)**

If the deficiency items and maintenance/repairs are not undertaken, not completed, or found to have not been properly completed, then enforcement steps will proceed.

The Owner of the ESD/stormwater management facility shall receive an enforcement notification from the County that includes a copy of the inspection report outlining the deficiency items to be corrected along with a clearly stated time frame for satisfactory completion (30-calendar days or as specified by the Department). The enforcement notification letter will also include instructions for the Owner to coordinate subsequent inspections by the Department to ensure satisfactory completion of the maintenance and/or repairs.

If the required maintenance/repairs are not satisfactorily completed by the Owner(s) within the specified time frame, any of the following actions or combination of actions shall be implemented by the County:

1. Revocation of all existing permits issued to the Owner of the ESD/stormwater management facility in Harford County, until noted problem has been corrected.
2. Denial of all future Harford County permits to the Owner of the ESD/stormwater management facility, until noted problem has been corrected.
3. Completion of such required work by the County (Section 2.2, Assessment Procedures).

## **2.2 ASSESSMENT PROCEDURES**

When the County determines the condition of the stormwater management facility presents an immediate danger to the public health and safety and the County performs an emergency repair, OR when the required maintenance/repairs are not satisfactorily completed by the Owner under an enforcement notice and the County completes such required work, then the cost of such work shall be paid to the County by the Owner or the beneficial users who failed to take corrective action.

The County shall either place a lien on the property or a pro-rated lien against the beneficial users of the property, and the lien may be placed on the property tax bill(s) and collected in ordinary taxes by the County.

*This page intentionally left blank*

### 3. SYSTEM INSPECTION PARAMETERS

While stormwater management facilities have specific design criteria, they also have common features that define associated system inspection parameters. For each parameter, a rating table was created with proposed corrective action. If a rating value is selected where a corrective action is needed, the inspection application automatically triggers follow-up questions and comments to assist the Owner knowing the location and what corrective action is needed. The Stormwater Inspection Application (Survey 123) prompts the inspector with a corrective action identified in the normal text and the inspector will enter the *italic text* information.

**Reminder:** For every inspection parameter a photograph or multiple photographs need to be taken. The Stormwater Inspection Application requires a photograph attachment in order to continue with the inspection.

While not a component of a facility, maintenance access is an important feature for those facilities that are not located close to a roadway, etc. Obstructed and/or compromised access, while not an inspection parameter, still needs to be reported as part of the inspection.

The parameters for inspections are divided into the following groups:

- Inflow – To inspect the component/condition of the path for the water entering the stormwater management facility.
- Forebay – if a stormwater management facility has a forebay this grouping is specific to the forebay. Stormwater management facilities with forebays will have a different overall ranking scale.
- Stormwater Management Facility – This grouping is for all the components within the stormwater management facility, including miscellaneous features.
- Control Structure – the grouping is for all the components that are part of the outlet to the stormwater management facility.

#### 3.1 INITIAL SIGNIFICANT FAILURE OBSERVED

The inspector will be prompted to identify if the facility can be accessed and/or if there is a significant failure observed. If the inspector answers *Yes* to these questions, the inspection will end, and a report will be created in Environmental Systems Research Institute (ESRI) Report Builder. The report will include the following:

- *Harford County did not perform a comprehensive inspection of the facility. The facility owner is responsible to contract the service for a comprehensive list of all other maintenance and address them during remediation to significant failure.*

Option	Description	Corrective Action
None	Maintenance access available and No significant failure observed and continue with remaining inspections	<i>None</i>
Yes – Embankment	Significant failure observed in the embankment.	<i>Inspector freeform response on corrective action needed</i>
Yes – Control Structure	Significant failure observed in the control structure.	<i>Inspector freeform response on corrective action needed</i>
Yes – Outfall	Significant failure observed in the outfall pipe/area.	<i>Inspector freeform response on corrective action needed</i>
Yes – Unable to Inspect/Access Blocked	Unable to Inspect and/or Access Blocked.	<i>Inspector freeform response on corrective action needed</i>

## 3.2 INFLOW

The collected stormwater runoff has various design options for directing stormwater to a stormwater management facility. The following parameters will be inspected and rated in whole for all inflows, inclusive of pipes, swales, and sheet flow into the stormwater management facility.

### 3.2.1 Debris/Blockage

Inspection is required to determine the overall condition of the inlet and inflow related to the physical presence of unwanted woody/leafy material, garbage/trash/floatable item accumulations, or other non-sediment-type that possibly can build up in the stormwater management facility and potentially block the outlet structure. This parameter should be evaluated based on the existing debris build-up, potential sources of debris, and potential blockage that could enter the facility through the inflow during future precipitation events. Ratings applied are as follows and should be applied in summation for all inflows into the stormwater management facility.

Rating	Description	Corrective Action
1	No debris (woody/leafy, garbage/trash/floatable) is observed in the inflow	No action needed
2	Minor debris is observed	Debris needs to be removed from the <i>inspector to indicate where</i>
3	Significant debris is observed	Debris needs to be removed from the <i>inspector to indicate where</i>

### 3.2.2 Inflow Sedimentation

Inspection is required to determine the overall condition of the inlet and inflow locations related to the physical presence of sedimentation that possibly can block the inflow of stormwater into the stormwater management facility and otherwise compromise the storage volume of the forebay or performance of the facility.

Rating	Description	Corrective Action
1	No sedimentation blocking inflows to the stormwater facility	No action needed
2	One or more inflow is obstructed by sediment at less than 20% of the flow depth	Sediment needs to be removed from <i>inspector to indicate where</i>
3	One or more inflow is obstructed by sediment at greater than 20% of the flow depth	Sediment needs to be removed from <i>inspector to indicate where</i>

### 3.2.3 Inflow Stability/Erosion

Inspection is required to determine the overall condition of the inflow (pipes, channels/swales, and sheet flow) related to the presence of exposed areas without adequate vegetative cover and eroded conditions that could cause sedimentation and/or comprise the inflow infrastructure. This includes the undermining of upstream storm drain infrastructure (headwalls, pipe end sections, etc.) by erosion and/or rills/gullies caused by surface and concentrated flow into the stormwater management facility.

Rating	Description	Corrective Action
1	No erosion is observed around the swales/channels/pipes flowing into the facility	No action needed
2	Lack of vegetative cover and minor erosion is observed on the swales/channels/slopes to the stormwater facility	<i>Inspector freeform response on corrective action needed</i>
3	Erosion observed in the swales/channels/outfalls and from surface water is causing rills and gullies deeper than 6 in.	<i>Inspector freeform response on corrective action needed</i>
4	Pipes/headwall flowing to the stormwater facility are being undermined and will fail to convey the flow into the practice	<i>Inspector freeform response on corrective action needed</i>

### 3.2.4 Inflow Condition

Inspection is required to determine the overall condition of inflow points to the facility. This focuses on the condition of the pipe end section, pipe endwall, and the visible section of the pipe closest to the end (alignment/settlement), as well as the condition of any structural ditches or swales into the facility.

Rating	Description	Corrective Action
1	Good condition with no or minimal wear	No action needed
2	Inflow shows signs of wear, degradation, material loss, etc.	Noted for evaluation at the next inspection. No action needed at this time.
3	Inflow shows moderate wear degradation, material loss, such as concrete endwall spalling, outlet pipe damage, moderate loss of riprap stone material, pipe rusting above invert	<i>Inspector freeform response on corrective action needed</i>
4	Inflow shows majority signs of wear, degradation, material loss, such as rebar showing in concrete endwall and is rusted, severe outlet pipe damage, riprap stone inflow protection not present, pipe rusted through/cracked	<i>Inspector freeform response on corrective action needed</i>

### 3.3 PRETREATMENT

Pre-treatment of runoff using a forebay, gravel diaphragm (also known as a transition strip), or proprietary structure prior to entering a stormwater management facility has the following common system inspection parameters. This parameter will only be an inspection trigger if a forebay or pretreatment device is identified as part of the design or shown/noted on the as-built plans. The inspector will be required to confirm the presence of the forebay or pretreatment device by reviewing the as-built plans. Pretreatment is part of the stormwater facility and has the same BMP ID as the facility downstream.

Inspection Question	Response
Is a forebay or pretreatment device part of the design?	<ul style="list-style-type: none"> <li>• Yes – Forebay (application continues to sedimentation forebay parameters)</li> <li>• No (application programming to go to stormwater facility specific parameters)</li> </ul>
Is a pretreatment gravel diaphragm (transition strip) part of the design?	<ul style="list-style-type: none"> <li>• Yes – Gravel diaphragm (transition strip) (application continues to gravel diaphragm parameter)</li> <li>• No (application programming to go to stormwater facility specific parameters)</li> </ul>
Is a proprietary device part of the design?	<ul style="list-style-type: none"> <li>• Yes (application continues to proprietary devices parameter)</li> <li>• No (application programming to go to stormwater facility specific parameters)</li> </ul>

#### 3.3.1 Forebay

##### 3.3.1.1 Forebay Sedimentation

Inspection is required to determine the overall condition of a forebay relating to its capacity to trap incoming sediment. Sediment marker is required to view the operating condition. If the sediment marker is missing, it must be replaced.

Rating	Description	Corrective Action
1	Forebay matched design depth.	No action needed.
3	Forebay is obstructed by sediment at less than 50% of the storage capacity or sediment marker is missing or damaged.	Noted for evaluation at the next inspection. Sediment marker needs to be immediately installed/replaced. No action needed.
5	Forebay is obstructed by sediment at greater than 50% of the storage capacity. Sediment marker missing or damaged.	Sediment needs to be immediately removed from <i>inspector to indicate where</i> . Sediment Marker needs to be immediately installed/replaced.

##### 3.3.1.2 Forebay Water Surface Elevation

Forebays should have adequate freeboard (distance below the overflow to the water or surface of the forebay) to capture and retain sediment as defined in the design and/or as-built plans. If a freeboard dimension is not noted, use the distance from the design floor of the forebay to the overflow elevation. If as-built/designed freeboard is absent, then sediment removal is warranted.

Rating	Description	Corrective Action
1	Freeboard matched design depth.	No action needed.
3	Freeboard is obstructed by sediment at less than 50% of the design depth.	Noted for evaluation at the next inspection. No action needed.
5	Freeboard is obstructed by sediment at greater than 50% of the design depth.	Sediment needs to be immediately removed from <i>inspector to indicate where</i> .

### 3.3.1.3 Forebay Vegetation

Forebay capacity should not be compromised by vegetation, woody/leafy debris, and/or trash.

Rating	Description	Corrective Action
1	Forebay has minor or no vegetation, woody/leafy debris, and/or trash.	No action needed.
2	Forebay is obstructed by vegetation, woody/leafy debris, and/or trash at less than 25% of the surface area.	Vegetation needs to be monitored and removed prior to the next inspection from <i>inspector to indicate where</i> .
3	Forebay is obstructed by vegetation, woody/leafy debris, and/or trash at more than 25% of the surface area.	Vegetation needs to be immediately removed from <i>inspector to indicate where</i> .

### 3.3.1.4 Forebay Control Structure

Stormwater entering the forebay is detained and retained before entering the stormwater facility. These control devices vary and typically use any or a combination of the following designs:

- Earthen berm with a depressed section/overflow weir.
- Solid berm with a depressed stone section to filter flow through the berm and provide an overflow.
- Solid berm with a forebay dewatering filtering inlet device (piped through the berm) and a depressed section/overflow weir.
- Stone-filled berm (or gabion structure) to filter flow through the berm to the facility.

The ability of the berm to detain runoff, filter the sediment/debris, and pass the flow to the stormwater facility should not be compromised by sedimentation/blockage, berm/overflow erosion, or berm failure.

Rating	Description	Corrective Action
1	Forebay control structure (berm and/or dewatering device) has little to very minor sedimentation, vegetation, woody/leafy debris, and/or erosion. function is not compromised.	No action needed.
2	Forebay control structure (berm and/or dewatering device) is partially obstructed by sedimentation, vegetation, woody/leafy debris, and/or minor berm/overflow weir erosion.	<i>Inspector freeform response on corrective action needed.</i>
3	Forebay control structure (berm) is obstructed by sedimentation, vegetation, woody/leafy debris, and/or substantial berm/overflow weir erosion.	<i>Inspector freeform response on corrective action needed.</i>
3	Forebay control structure (dewatering device) is obstructed by sedimentation, vegetation, woody/leafy debris.	<i>Inspector freeform response on corrective action needed.</i>

### 3.3.2 Gravel Diaphragm – Transition Strip

Gravel diaphragm, also called a transition strip is a pretreatment device typically provided along the edge of the impervious area (roadway, driveway, parking lot, etc.) to trap sediment/debris, slow down the runoff, and to maintain a sheet flow condition for the runoff to flow into the adjacent stormwater management facility or vegetated treatment area (non-rooftop disconnect).

Note: The transition strip along driveways may be vegetated at the surface with the gravel section below. Design and as-built plans should be previewed prior to inspection.

Rating	Description	Corrective Action
1	Gravel diaphragm – transition strip is functioning as designed and is not clogged with sediment or damaged.	No action needed.
3	Significant sedimentation, settlement, damage, and or erosion observed in gravel diaphragm – transition strip.	Diaphragm – transition strip to be repaired to design plan. <i>Inspector freeform response on corrective action needed and location</i>
4	Gravel diaphragm – transition strip missing.	Diaphragm – transition strip to be immediately installed per the design plan. <i>Inspector freeform response on corrective action needed and location</i>

### 3.3.3 Proprietary Structure

These are structures such as hydrodynamic devices, vortex inlet, or other commercially available stormwater water quality structures.

Rating	Description	Corrective Action
1	Structure functioning as designed.	No action needed.
3	Significant sedimentation/floatables observed in structures.	Schedule maintenance to remove accumulated debris.

## 3.4 STORMWATER MANAGEMENT FACILITY

This grouping of components is for overall stormwater management facilities.

### 3.4.1 Ponding

Inspection is required to determine whether the stormwater facility is dewatering at an operating rate. For infiltration practices, inspections should be performed no less than 48 hours after a storm event to allow facilities adequate time to dewater. As part of this parameter, measurement of standing water depth above the design elevation (from construction plans) will be taken.

**Inspectors shall not put themselves in an unsafe condition relative to deep water.**

Inspection Question	Response
Please record the measured water depth above the design elevation in inches.	<i>Freeform number field.</i>

When an observation well is present (e.g., infiltration trenches, micro-bioretenion facilities, etc.), the standing water depth below the facility surface is measured within the observation well with these measurements recorded as part of the reporting requirements.

**Inspectors shall not put themselves in an unsafe condition relative to deep water defined at +2 feet (ft).**

Rating	Description	Corrective Action
1	No standing water or water level is at the design depth/elevation.	No action needed.
3	Minor pooling/standing water in dry basin facilities OR water level slightly (less than 2 inches [in.]) above the design depth/elevation in wet basin facilities with overflow from the low-level control opening. For infiltration trenches or micro-bioretenion system, the water level within the media is less than 6 in. above the bottom.	<i>Inspector freeform response on corrective action needed.</i>
8	Standing water in dry basin facilities OR water level greater than 2 in. above the design depth/elevation in wet basin facilities with overflow from the control structure openings. For infiltration trenches or micro-bioretenion system the surface standing water or water level within the media is greater than 6 in. above the bottom.	<i>Inspector freeform response on corrective action needed.</i>

### 3.4.2 Embankment

Embankments are the structured slopes that impound stormwater for retention or infiltration into the practice. Erosion along the perimeter edge of the embankment can compromise the embankment, create a safety issue, and impact the operational capacity of the facility. The embankment may have an upstream slope within the practice and a downstream slope outside of the ponding area. This parameter is for observing erosion and condition on all parts of the embankment.

Stormwater management facilities that use the surface to store stormwater for treatment require an embankment to contain the stored stormwater. The design of the embankment varies; however, the embankment is typically high enough to provide capacity above the design water

level (freeboard) and an emergency spillway that is used during an extreme rainfall event (see Section 4.1.12 for additional information).

Stormwater facilities typically will have embankments/side slopes, etc. that are to be stabilized with a grassed surface that can be mowed/maintained (Section 4.1.16 provides additional information). The inspection of the facility area is required to determine the general condition of the vegetative cover including the loss of grass cover (bare spots and weeds), presence of animal burrows, surface rutting/erosion, large weeds, brush, woody vegetation, woody/leafy debris, and/or trash.

Note: No woody vegetation is allowed within 15 ft from the toe of a pond embankment or within 25 ft of the riser structure. Tree diameter is measured 4.5 ft above the ground.

Multiple choice answers may be selected as the corrective action needed may vary based on the observed condition.

Rating	Description	Corrective Action
1	No erosion or settling along the perimeter edge.	No action needed.
3	Embankment is showing minor signs of bare spots, weeds, and surface rutting/erosion	Conditions need to be repaired prior to the next inspection for <i>inspector to indicate where</i> .
3	Embankment has large weeds, brush, woody vegetation/trees with a diameter less than 2 in., woody/leafy debris, and/or trash	Trees need to be cut flush with the ground and treated within 30 days.
3	Trees with a diameter of less than 6 in. observed.	Trees need to be cut flush with the ground and treated within 30 days.
4	Substantial bare spots, surface rutting/burrows/erosion and/or settling, and large weeds/brush along the perimeter edge and the embankment is less than 3 ft tall.	<i>Inspector freeform response on corrective action needed.</i>
8	Trees with a 6 in. diameter or greater along the perimeter edge and the embankment is greater than 3 ft tall.	Remove tree, root ball, and all roots greater than 0.5 in. diameter and restore embankment.

If the inspector selects a rating of 8, the inspections will be automatic failure.

### 3.4.3 Conveyance

Stormwater management facilities may have a defined conveyance flow paths through the facility from the inlet to the outlet device.

Rating	Description	Corrective Action
0	Flow path channel not part of design or in stable/good condition.	No action needed.
1	Flow path channel has little to minor sedimentation, vegetation, woody/leafy debris, and/or erosion.	No action needed.
4	Flow path is partially obstructed by sedimentation, vegetation, woody/leafy debris, and/or eroded.	Remove sediment/debris from the <i>inspector to indicate where</i> .
6	Flow path is obstructed by sedimentation, vegetation, woody/leafy debris, and/or eroded.	Remove sediment/debris from the <i>inspector to indicate where</i> .

### 3.4.4 Sediment

The sediment parameter should be evaluated based on the depth relative to the design of the pond or facility bottom, which can be roughly gauged by measuring it relative to the water surface (low flow opening) or an opening on the control structure which is a known height above the bottom. The inspector should also note the relative percent coverage of this depth of excess sediment on the bottom, which may require measurements in three to four spots if it appears uneven in nature.

**Inspectors shall not put themselves in an unsafe condition relative to deep water.**

For a dry pond, the measurement(s) may be taken on foot with a lock level or line level, and survey rod or 6-ft ruler. Wet ponds may require probing to determine the depth below the surface of the sediment. For large wet ponds where boots/waders are not sufficient for this effort and significant sedimentation is apparent, no further estimation is to be performed.

Pond/facility capacity should not be compromised by sediment.

Rating	Description	Corrective Action
1	Pond/facility has minor or no sediment.	No action needed.
4	Pond/facility is partially obstructed by sediment at less than 25% of the surface area or storage capacity.	Sedimentation needs to be monitored and may need to be removed prior to the next inspection from <i>inspector to indicate where</i> .
6	Pond/facility is obstructed by sediment at more than 25% of the surface area or storage capacity.	Sediment needs to be immediately removed from <i>inspector to indicate where</i> .

### 3.4.5 Facility Landscaping/Vegetation

There are several types of stormwater management facilities (micropool and pocket ponds, stormwater wetlands, micro-bioretenion, bioretention, etc.) that require the installation of specific species of grasses, plants, and shrubs trees within the facility. These landscaped/vegetated areas have the following common inspection parameters.

Rating	Description	Corrective Action
0	Facility does not have a specific landscape plan as part of treatment.	No action needed.
1	Facility landscaping and vegetation cover matches the as-builts.	No action needed.
2	Minor accumulation of invasive species, woody vegetation, or dead plants is observed. Small area of bare soil observed.	Facility needs removal of invasive species/woody vegetation and replanting in accordance with as-built plan
3	Large area of bare soil is observed.	Facility needs to have vegetated surface restored per the design plan.
4	Facility is overrun with invasive species, woody vegetation or/and original planting plan is not obvious.	Facility needs removal of invasive species/woody vegetation and replanting in accordance with as-built plan.

### 3.4.6 Contamination

Stormwater management facilities that use sediment forebays and the surface to store stormwater for treatment have the possibility of being contaminated, with the following common system inspection parameters. The following could be considered indicators of contamination:

- Surface sheen
- Algae growth
- Foam
- Odors
- Suspended soils

Rating	Description	Corrective Action
1	No contamination observed.	No action needed.
2	Contamination is observed.	Notify Office of Watershed Protection and Restoration for possible illicit discharge detection and elimination inspection.

### 3.4.7 Fencing/Security/Access

Unless adjacent to a road, driveway or paved area, access to the stormwater facility is needed. Some facilities have designated maintenance access driveways. Stormwater basins with interior slopes greater than 4:1 and inundated by the 100-year frequency storm require fencing. There are several types of stormwater management facilities that require the installation of signs and security fencing with access gates to surround the facility. The security fencing has the following common inspection parameters.

Rating	Description	Corrective Action
0	Fence not required for site and/or maintenance access driveway not required for site and/or fence is good working order.	No action needed.
1	Maintenance access driveway requires mowing or minor erosion/stabilization repair.	Mow the access driveway and/or repair access driveway at the <i>inspector to indicate where</i> .
2	Fence requires repair and/or maintenance access driveway requires repair.	Repair fence or access at the <i>inspector to indicate where</i> .

## 3.5 PRINCIPAL OUTLET CONTROL STRUCTURE/SPILLWAY

Stormwater management facilities that use the surface to store stormwater for treatment have principal outlet control riser structures/headwall/spillways, which have the following common system inspection parameters.

### 3.5.1 Riser – Control Structure/Yard Inlet

Inspection is required to determine the overall physical condition of the riser – control structure and the ability to allow for proper flow through the openings and spillway. Evaluate the

structural condition and the presence of vegetation, woody debris, sediment, and garbage/trash blocking the orifice or other spillway/openings including the pipe leaving the structure.

Rating	Description	Corrective Action
0	Control structure/yard inlet is not part of the design.	No action needed.
1	Control structure/yard inlet condition is good. Openings are free from sedimentation, vegetation, woody/leafy debris, and/or trash.	No action needed.
4	Control structure/yard inlet showing signs of deterioration. Openings are partially obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.	<i>Inspector freeform response on corrective action needed.</i>
6*	Control structure/yard inlet deteriorated. Openings are obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.	<i>Inspector freeform response on corrective action needed.</i>

Note:

\*If the inspector selects a Rating of 6, the inspection will automatically fail.

### 3.5.2 Weir

Inspection is required to determine the overall physical condition of the outlet weir structure and the overall condition of the weir to allow for proper flow through the openings in the weir wall and over the spillway. Evaluate structural condition and the presence of vegetation, woody debris, sediment, and garbage/trash blocking the openings.

Rating	Description	Corrective Action
0	Weir is not part of the design.	No action needed.
1	Weir wall condition good. Openings are free from sedimentation, vegetation, woody/leafy debris, and/or trash.	No action needed.
3	Weir wall showing signs of deterioration. Openings are partially obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.	<i>Inspector freeform response on corrective action needed.</i>
4	Water is bypassing the weir walls.	<i>Inspector freeform response on corrective action needed.</i>
6	Weir wall deteriorated. Openings are obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.	<i>Inspector freeform response on corrective action needed.</i>

### 3.5.3 Trash Rack

Inspection is required to determine the overall structural condition of the trash rack on the riser structure or weir wall structure. This parameter evaluates any damage, corrosion, presence of vegetation, woody debris, sediment, and/or garbage/trash in and around the riser/weir wall trash rack.

Rating*	Description	Corrective Action
0	Trash rack is not part of the design.	No action needed.
1	Trash rack condition good. Openings are free from sedimentation, vegetation, woody/leafy debris, and/or trash.	No action needed.
2	Trash rack showing signs of deterioration.	Trash rack maintenance needs to be performed on <i>inspector to indicate where</i> .
2	Openings are partially obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.	Obstructions to be corrected on <i>inspector to indicate where</i> .
3	Trash rack deteriorated or missing.	Trash rack needs to be repaired/replaced.
4	Openings are obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.	Obstructions need to be immediately cleared for <i>inspector to indicate where</i> .

Notes:

\*Allow for multiple selected responses.

### 3.5.4 Valve

Stormwater management facilities with a permanent wet pool may be provided with a dewatering system that is isolated by a valve. If the valve end is visible within the riser structure from outside the riser structure, inspection is required to determine the condition of the valve.

Rating	Description	Corrective Action
0	Valve is not part of the design.	No action needed.
1	Valve is part of the design and/or unable to be visually inspected.	Owner responsible for verifying the valve is operational.
3	Pond/facility has a valve that is showing exterior corrosion	Valve is recommended to be exercised and should be serviced prior to the next inspection.
4	Pond/facility has a valve that is showing exterior corrosion, leaking and/or aligned in off centered.	Valve needs to be immediately repaired.

### 3.5.5 Low Flow Control

Stormwater management facilities with a permanent wet pool and detention ponds may be provided with a low flow controlled dewatering system that could include a stone protected perforated dewatering device/pipe to a structure/outfall that may also be regulated by an orifice or restricted opening. Unless the dewatering pipe/stone is below the pinging water or the orifice/discharge pipe is not accessible, the inspection is required to determine the condition of the dewatering pipe/stone, discharge pipe/orifice.

Rating	Description	Corrective Action
0	Dewatering device and/or low flow control is clear and working properly and/or not part of the design.	No action needed.
2	Low flow/dewatering device showing minor sediment and/or debris blockage. Low flow control/pipe has a free discharge and only showing minor opening erosion/corrosion.	Dewatering device and/or low flow control needs to be monitored and may need to be serviced prior to the next inspection.
4	Dewatering device and/or low flow control/pipe is blocked, and/or has an obstructed discharge, and/or leakage at the orifice pipe/plate, and/or showing opening erosion/corrosion.	Dewatering device and/or low flow control needs immediate repair – <i>inspector to indicate where.</i>
5	Dewatering device is submerged and/or low flow control/pipe is not accessible.	Dewatering device needs immediate repair and/or low flow control/pipe needs to be made accessible – <i>inspector to indicate where</i>

### 3.5.6 Outfall Pipe

Stormwater management facilities with a riser or other outlet control structure (not weir wall) will have an outfall pipe from the structure through the embankment to a discharge location. The inspection of this pipe at the riser/structure and at the discharge location is required to determine the condition of the outfall pipe.

Rating*	Description	Corrective Action
0	Outfall pipe is not showing any signs of deterioration/damage, settling, blockage and/or not part of design.	No action needed.
2	Outfall pipe is showing minor signs of deterioration/damage, and/or indications of settling	Pipe needs to be monitored for settling and may need to be repaired/serviced prior to the next inspection.
4	Outfall pipe has minor debris within the pipe.	Pipe needs to be cleaned of debris prior to the next inspection for <i>inspector to indicate where</i>
6	Outfall pipe is showing signs of deterioration/damage/failure, and/or settling, and/or debris/ blockage within the pipe	<i>Inspector freeform response on corrective action needed</i>

Note:

\*Allow for multiple selections.

### 3.5.7 Outfall Area

Stormwater management facilities with a riser or other outlet control structure including a weir wall will have an outfall area near or through the embankment or to a discharge location that can be near or away from the embankment. The inspection of the outfall area is required to determine the general condition of the outfall area including the presence of animal burrows, surface rutting/erosion, large weeds, brush, woody vegetation, woody/leafy debris, and/or trash. (This inspection is not including the outlet structure/pipe or riprap erosion protection, which are performed under other inspection items.)

Rating	Description	Corrective Action
1	Outfall area is not showing any signs of deterioration/damage/vegetation intrusion, etc.	No action needed.
3	Outfall area is showing minor signs of surface rutting/erosion, large weeds, brush, woody vegetation, woody/leafy debris, and/or trash	<i>Inspector freeform response on corrective action needed.</i>
4	Outfall area is showing signs of animal burrows, surface rutting/erosion, large weeds, brush, woody vegetation, woody/leafy debris, and/or trash	<i>Inspector freeform response on corrective action needed.</i>

### 3.5.8 Riprap – Weir and Outfall Pipe

Ponds and facilities that are designed with overflow control weir structure or have outlet control structure with an outfall pipe will, the majority of design, include stone riprap to dissipate energy and minimize erosion, including damage to the embankment and outfall area. The inspection of the riprap is required to determine the general condition, including settlement, stone displacement/migration, erosion/sediment, vegetation intrusion, and trash/debris and to ensure the continued performance of the riprap.

Rating	Description	Corrective Action
0	No riprap, outfall discharges into storm drain/not accessible.	No action needed.
1	Riprap is not showing any signs of settlement/stone displacement/sediment/vegetation intrusion, trash/debris, etc.	No action needed.
3	Riprap is showing minor signs of settlement, stone displacement/migration and/or sediment.	Riprap stone needs to be maintained prior to the next inspection.
3	Riprap is showing minor signs of large weeds, brush, woody vegetation, woody/leafy debris, and/or trash.	Riprap needs to have the vegetation/debris removed prior to the next inspection.
4	Riprap has settlement, stone displacement/migration and/or sediment.	<i>Inspector freeform response on corrective action needed</i>
4	Riprap has large weeds, brush, woody vegetation, woody/leafy debris, and/or trash.	Riprap needs to be restored immediately by removing the vegetation/debris.

### 3.5.9 Emergency Spillway

Stormwater management facilities that use the surface to store stormwater for treatment may also have an emergency spillway (grassed or riprap stone-lined depression in the top of the embankment or some form of fixed surface weir) to provide a means of safely overtopping the embankment during an extreme rainfall event, which have the following common system inspection parameters.

The inspection of the spillway is required to determine the general condition, including settlement, riprap stone displacement/migration, bare spots in grass surface, erosion/rutting, damage to the weir device, vegetation intrusion, and trash/debris to ensure the continued performance of the emergency spillway.

Rating	Description	Corrective Action
0	Emergency spillway is not part of the design.	No action needed.
1	Spillway is not showing any signs of settlement, stone displacement, loss of grass cover, erosion, vegetation intrusion, trash/debris, etc.	No action needed.
3	Spillway is showing minor signs of settlement, minimal stone displacement, minor deterioration of the weir structure.	Spillway needs to be maintained and the County notified in the next 30 days.
4	Spillway is showing minor loss of grass cover, minor signs of large weeds, brush, woody vegetation, woody/leafy debris, and/or trash.	Spillway needs to have the grass surface restored; vegetation/debris removed within the next 30 days.
6	Spillway has settlement, stone displacement, deterioration of the weir structure.	Spillway needs to be immediately restored to design elevation.
6	Spillway has loss of grass cover, large weeds, brush, woody vegetation, woody/leafy debris, and/or trash.	Spillway needs cover to be immediately restored and debris removed.

### 3.6 MISCELLANEOUS FACILITY COMPONENTS

Stormwater management facilities that use underdrains or below-grade media (filtration/infiltration) for treatment have additional components, which have the following common system inspection parameters.

#### 3.6.1 Observation Wells

Stormwater management facilities, such as drywells, micro-bioretenion, infiltration swales and trenches, and submerged gravel wetlands (SGWs), are provided with an observation well or wells that are used to monitor the presence and/or depth of standing water within the facility.

The inspection of the observation well is required to determine the condition of the observation well in order for it to be used to monitor the facility.

Rating	Description	Corrective Action
0	Observation well is not part of the design.	No action needed.
1	Observation well condition good. Cap easily removed, no blockage/sediment/debris in well pipe.	No action needed.
2	Observation well showing signs of deterioration. Cap cracked/damaged/hard to open, Cap is not 6 in. above the environmental site design volume (ESDv) ponding level. Minor sediment/debris at bottom of the well pipe.	<i>Inspector freeform response on corrective action needed.</i>
3	Observation well deteriorated. Cap missing/cracked/damaged. Well pipe obstructed/blocked by sediment/debris.	<i>Inspector freeform response on corrective action needed.</i>

#### 3.6.2 Underdrain Cleanouts

Stormwater management facilities such as micro-bioretenion, infiltration swales and trenches, and SGWs that are provided with an underdrain system require maintenance access through the use of cleanout piping that is extended above the surface of the facility at various locations.

Inspection of the underdrain cleanouts is required to determine the condition of the cleanout for it to be used for maintenance of the facility as well as monitoring the condition of the underdrain.

<b>Rating</b>	<b>Description</b>	<b>Corrective Action</b>
0	Clean outs are not part of the design.	No action needed.
1	Underdrain cleanout condition good. Cap easily removed, no observed blockage/sediment/debris in cleanout/underdrain pipes.	No action needed.
2	Underdrain cleanout showing signs of deterioration. Cap cracked/damaged/hard to open. Cap is not 6 in. above the ESDv ponding level. Minor sediment/debris observed in the cleanout/underdrain pipes.	<i>Inspector freeform response on corrective action needed.</i>
3	Underdrain cleanout deteriorated. Cap missing/cracked/damaged. Cleanout/underdrain pipe obstructed/blocked by sediment/debris.	<i>Inspector freeform response on corrective action needed.</i>

## 4. FIELD INSPECTION PROCEDURES

Chapter 4 provides a description of activities performed by the inspector or inspection team consisting of both in-office pre-inspection preparation work and in-field inspection procedures.

### 4.1 PREPARATION

Preparation is critical to the process of field inspection of stormwater management facilities. Organizing the facilities to be inspected into small geographic areas/clusters or within a development project will minimize pre-field preparation and travel time, and maximize field inspection time.

#### 4.1.1 Pre-Field Inspection Preparation

Prior to performing the field inspection, the inspection team should be familiar with all available source information for the site(s) such as:

- Stormwater management construction plans (grading, details, and profile sheets)
- As-built plans
- Stormwater management reports
- Modifications/maintenance performed since initial construction
- Prior inspection reports
- Existing GIS/database information

The inspection team should review the information, along with the base mapping, to gain a thorough understanding of the facility and the surrounding area.

A critical pre-field preparation item is the weather. Not only should the weather forecast be checked for the inspection date, but the preceding historical weather data must be obtained to document (National Oceanic and Atmospheric Administration, Weather Underground, U.S. Geological Survey), depending on the closest weather station. Harford County Weather Center (<https://www.harfordcountymd.gov/168/Weather-Center>) provides sources to review when the last rainfall event at the facility occurred.

Digital or paper field maps should be prepared for reference during the inspection. If during the facility inspection it is determined that the existing stormwater management facility is inconsistent with the plan and/or GIS data, the discrepancies must be clearly noted for use in updating this information.

The field mapping package in either digital or paper form should include the following:

- A field map (100 or 200 scale mapping) with features located including (where available) roads, ramps, interchanges, stormwater management facilities identified by number, property boundaries, and easements for access to the facility. It is helpful to have contours and topographic features on this mapping to orient the field personnel.

- Plan sheets with grading, embankment/dam/spillway profile and planting where applicable.
- Field forms for data collection and inspection.

#### **4.1.2 Pre-Field BMP History/Inspection Review**

Prior to performing the field inspection, the inspection team should be familiar with all previous inspections and maintenance history. It is especially important to note previous inspection items for areas that were noted as needing attention.

#### **4.1.3 Pre-Inspection Health and Safety**

The pre-field investigation should identify potential safety issues such as road access, water safety, traffic hazards, and remote site conditions. Based on potential safety issues, the inspection crew can prepare appropriately for the field investigation, including the designation of job responsibility.

Two-person (minimum) crew is to perform the stormwater management inspections. Staff will not enter confined space as part of the inspections.

Safety precautions should always be used while locating and inspecting stormwater facilities along roadsides. Inspectors should plan for and be aware of vehicular traffic and road conditions during field investigations as well as the proper placement of warning cones and signs.

Field personnel must wear reflective safety vests and carry work identification, driver's license, and a County field inspection authorization letter at all times during the field investigation.

Until the County develops a formal Health and Safety Plan for personnel performing stormwater management inspections, the following list of items should be addressed and included with the field inspection equipment:

- All personnel must wear steel-toe boots
- Hard hats
- Work gloves
- Manhole opening equipment
- High-visibility vest/jacket
- First aid kit
- Insect repellent
- Insect spray (for spiders, ticks, and bees)
- Wasp killer spray
- Traffic safety devices (cones, signs, etc.)

#### 4.1.4 Pre-Inspection Equipment Requirements

As part of planning for the field inspection, the proper equipment must be on hand to ensure the collection of data and ability to complete the inspection task. Table 4-1 presents a list of the required as well as optional equipment that may be used during stormwater management facility inspections. The equipment list includes both field inspection equipment as well as health and safety equipment. Tablets and cell phones should be fully charged.

**Table 4-1. Stormwater Management Facility Inspection Equipment List**

Required	Optional
Stormwater Management Inspector Manual	Small sledgehammer
Field logbook	Probing rod
Tablet with vehicle charger	Personal cleaning materials (soap, water, paper towels, etc.)
Field attire and high-visibility vest/jacket	Supplemental field attire (change of clothing)
Traffic cones (minimum 6)	Hat and sunscreen
Harford County identification and authorization letter	Bottled water
High-power flashlight and spare batteries	
Measuring tape (20-ft minimum)	
Folding 6-ft ruler	
Knife/machete	
Manhole lifting equipment	
Bolt cutter (new locks and keys)	
Pipe wrench and WD-40	
Health and Safety equipment (Section 4.1.3)	

#### 4.1.5 Pre-Inspection Site Access

Prior to performing the field inspection, the inspection team should be familiar with access to the site, including maintenance driveways, parking areas, and access easements.

Reminder: Field personnel should always carry a letter stating that the Department has given permission to those individuals to inspect the stormwater management facilities. This letter should be presented to anyone who requires proof that no one is trespassing.

Prior to performing the field inspection, the inspection team should determine if the facilities that are fenced are secured by locks and obtain/coordinate access. Field personnel should carry a bolt cutter should a lock need to be removed for access and heavy duty 18-in. zip ties as a replacement upon departure. If a lock has to be cut, then the inspector shall notify the owner to replace the locking device.

#### 4.1.6 Pre-Inspection Owner Confirmation

Prior to performing the field inspection, a review of the stormwater management facility owner data (name, contact name, site address and mailing address, phone numbers, email address, etc.) should be performed and updated/amended, as needed.

Since property management firms could change since the last inspection, the pre-inspection confirmation process is very important for facilities under the control of a Homeowners Association. Property management firms currently listed should be contacted as a first step in the confirmation process.

Facilities owned by commercial/industrial entities also need to be confirmed, especially for out-of-state owners.

#### **4.1.7 Pre-Inspection Owner Notification**

Prior to performing the field inspection, a formal notification of the anticipated inspection and inspection schedule needs to be provided to the following:

- Baltimore Gas and Electric
- Exelon/Constellation
- Harford Board of Education

In addition, the inspector should review the GIS database to determine if a marker/attribute is present that indicates a formal notification is required prior to inspecting the facility.

## **4.2 IN-FIELD INSPECTION**

During field inspection, staff should evaluate the parameters of the stormwater management facility in accordance with Section 3. This evaluation will be performed using a tablet or a phone to access a County-maintained ESRI Survey123 application.

### **4.2.1 Constituent Engagement**

If inspectors are approached by the general public while performing the inspection, they are to show the County issued ID. The inspectors should direct any questions to the Bureau.

### **4.2.2 Order of Inspection**


Upon arrival to the stormwater management facility, the inspectors are to park their vehicle in an appropriate and legal parking area and secure their vehicle. Inspectors are required to assess all parameters identified in the stormwater manual. Inspectors are encouraged to walk the entire facility to gauge the overall condition of the facility before commencing with the inspection parameters. Inspectors should complete the inspection parameters while on-site and take photographs of noted deficiencies. The County Survey123 Inspection Application includes recommended corrective actions and freeform fields for the inspector to populate recommended corrective actions.

### **4.2.3 Access Inspection Survey**



To access the Inspection Survey, inspectors must have an ArcGIS Online account. The inspector will then be added to the Storm Water Management (SWM) BMP Inspections group via the

owner of the group. Once added to the group, the inspector will have access to the Harford County Inspection Field Map. The steps to access the Inspection Survey are below.



**Table 4-2. How to Access and Complete Survey123**

Step Number	Description
1	Navigate to "ArcGIS Online"
Photo	 <p>The screenshot shows a Google search interface with the search term 'arcgis online'. Below the search bar, there are filters for 'Login', 'Free', 'Subscription', 'Videos', 'App', 'Certification', 'Images', and 'Course'. The search results show 'About 54,700,000 results (0.25 seconds)'. The top result is for 'ArcGIS Online' with the URL 'https://www.arcgis.com'. Below the result is a 'Sign In' button and a link to 'An introduction to ArcGIS Online'.</p>
2	Sign In with your AGOL account


**Table 4-2. How to Access and Complete Survey123**

Step Number	Description
<p><b>Photo</b></p>	
<p><b>3</b></p>	<p><b>Click "Groups"</b></p>
<p><b>Photo</b></p>	



**Table 4-2. How to Access and Complete Survey123**

Step Number	Description
4	Click the "SWM BMP Inspections" group
Photo	 <p>A screenshot of the ArcGIS Groups web interface. The browser address bar shows 'harfordgis.maps.arcgis.com/home/groups.html?sortField=title&amp;sortOrder=asc&amp;my'. The left sidebar shows navigation options like 'Current members are from', 'Group membership setting', 'Special groups', and 'Date created'. The main content area lists several groups. The 'SWM BMP Inspections' group is highlighted with a blue border. It is described as 'All content related to the inspection of BMPs including surveys' and was last updated on May 24, 2023. Other groups listed include 'Summer Adventure', 'SWM Maintenance Inspections', and 'Test SWM Inspections'.</p>
5	Click "Harford County Inspection Field Map"
Photo	 <p>A screenshot of the ArcGIS Search results page. It shows a grid of search results. The central result is 'Harford County Inspection Field Map', which is highlighted with a blue border. It is a 'Web Map' created on May 24, 2023, and updated on October 6, 2023, with a view count of 329. A blue 'Open in Map Viewer' button is overlaid on the map thumbnail. Other results include 'Harford Inspection Survey Ho...' and 'HCBMPs'.</p>
6	Open the map by clicking the thumbnail or by clicking the blue "Open in Map Viewer" button

**Table 4-2. How to Access and Complete Survey123**

Step Number	Description
<p><b>Photo</b></p>	
<p>7</p>	<p><b>Click on a BMP polygon</b></p>
<p><b>Photo</b></p>	
<p>8</p>	<p><b>Click the "Inspection Survey" hyperlink via the polygon pop-up</b></p>

**Table 4-2. How to Access and Complete Survey123**

Step Number	Description
<p><b>Photo</b></p>	
<p><b>9</b></p>	<p>The Survey will open in the Survey123 application. Fill out all necessary questions and click the check mark in the bottom right corner to submit the survey.</p>
<p><b>Photo</b></p>	

#### 4.2.4 Missing BMPs on Inspection Field Map

There is the possibility of missing polygons in the Harford County Inspection Field Map. BMPs are added on a yearly basis and there may be discrepancies with polygons. If an inspector notices at any point that they cannot find a specific BMP polygon on the map, they are to do the following:

- Note the project number and name, this will be useful to describe what information is missing.
- Optional: Take a screenshot or picture of the area on the map that is missing a polygon.
- Create a survey from scratch for the missing BMP. Name the BMP, the address and/or type. When the survey is submitted, it will create a point that will be used to locate the necessary area.
- Contact the Watershed Restoration Group with the necessary information, the missing polygons will be added to the database.


## 5. REPORTING, CORRECTIVE ACTIONS, AND CLOSEOUT



### 5.1 INSPECTION REPORT



The application has a pre-formatted report that is populated with the information from the inspection for the streamlined distribution of the inspection report. All inspection reports are reviewed by Bureau staff before being sent to the appropriate representative of the stormwater management facility for corrective actions. Review by Bureau staff will include:

- Formatting matches Harford County standard
- Report includes clear and precise corrective actions

**Table 5-1. How to Generate Inspection Reports**

Step Number	Description
1	Navigate to " <a href="https://survey123.arcgis.com/">https://survey123.arcgis.com/</a> " and sign in with your Harford AGOL account.
Photo	
2	Click the survey named "Inspection SWM"
Photo	

Step Number	Description
3	On the top row, click on the “Data” tab, this will pull up a table with all surveys.
Photo	
4	At the top of the table, there will be a new row, select the “Report” button to open a side panel.
Photo	

Step Number	Description
5	<p>Select one, or multiple reports, from the table that you would like to generate a report for. With these reports selected, check that the “SWM_Inspections_Report” template is selected. Then at the bottom of the side panel, click the “Generate” button.</p>
<p><b>Photo</b></p>	
6	<p>This will take you to a new page in the side panel that will display recently generated reports. When the report has been generated it will pop up in the top right of your browser. If you miss the pop up it will be in your downloads.</p>
<p><b>Photo</b></p>	
7	<p>Most of the information should be automatically populated. If there is any information missing that is necessary from the as-built plans, inspectors can edit the Word Document that generates.</p>

Step Number	Description
Photo	<p style="text-align: center;"><b>Inspectors to double check Rating and dates throughout the report.</b></p> <p style="text-align: center;">Harford County Government DEPARTMENT OF PUBLIC WORKS STORM WATER MANAGEMENT REPORT 212 SOUTH BOND STREET BEL AIR, MARYLAND 21014 PHONE: 410-638-3563/3127/3128 FAX: 410-638-4815</p> <p style="text-align: right;">Purpose: Maintenance SWM: Billing Number: 91493 TaxID: 04050649</p> <p style="text-align: center;"><b>STORM WATER MANAGEMENT INSPECTION REPORT</b></p> <p>Overall Rating: <u>Pass</u> Code:</p> <p>The Harford County Bureau of Stormwater Management is committed to keeping its excellence in providing the best available maintenance information for your stormwater facility. Brochures have been created for various types of stormwater management facilities to provide basic and seasonal information, as well as reminders of what not to do within your facility. Please visit <a href="https://www.harfordcountymd.gov/946/Brochures">https://www.harfordcountymd.gov/946/Brochures</a></p> <p>Facility Type: Dry Well BMPID: SWM111257</p> <p>Site Location: Description:</p> <p>Project Name: Harris Lands Of Lot 2 Only 1337 Rock Ridge Road Project Number: 91493 Owner Name: Thomas &amp; Paula Harris Owner Address:</p> <p><u>Site Address: 1337 Rock Ridge Rd</u> Management Company: Address:</p> <p>General Comments: The facility is in accordance with Harford County's Stormwater management regulations. Please continue to perform regularly scheduled maintenance.</p> <p>It is requested that the described actions be performed within 3 Years days of this notification to bring this facility in compliance with Harford County's Storm Water Management Regulations. Please contact our office at 410-638-3545, ext. 2440, or email at <a href="mailto:debutler@harfordcountymd.gov">debutler@harfordcountymd.gov</a> or <a href="mailto:eimbierowicz@harfordcountymd.gov">eimbierowicz@harfordcountymd.gov</a> if there are any questions and to schedule a reinspection once the work has been completed.</p>

## 5.2 INSPECTION RESULTS RANKING

As the inspector selects the condition of the parameter observed in the Stormwater Inspection Application a numeric value is assigned to the parameter. The Stormwater Inspection Application summarizes the numeric value and will assign if a stormwater management facility is passing or failing based on the sum. The following table is the result of those sums and how that will be used for the overall condition if the SWM is passing or failing for MS4 permit reporting.

Type	Pass	Fail
Stormwater Management Facility without a Forebay	11–30	>30
Stormwater Management Facility with a Forebay	24–50	>50

Despite the ranking received all owners will receive a report with identified corrective actions for their facility.

## 5.3 CORRECTIVE ACTIONS AND TRACKING

During the inspection, the inspectors are identifying deficiencies and corresponding corrective actions in the stormwater management facility. These corrective actions identify what is to be done, but do not specify how the work is to be performed. Each report identifies a timeline for

the corrective action to address deficiencies. If during the inspection any deficiencies (from minor to major) are observed, the Bureau prepares and sends the inspection report to the owner. The notification letter identifies the deficiency items to be corrected along with a clearly stated time frame for completion. Harford County requires the deficiency to be address within 30-calendar days or a reasonable time frame that is mutually agreed between the Department and the owner. The Bureau will continue to perform inspections on 30- to 90-day frequency until the deficiencies are addressed.

#### **5.4 REINSPECTION AND CLOSEOUT**

The notification letter includes instructions for the owner to coordinate follow-up inspections with the Bureau to ensure satisfactory completion of the maintenance and/or repairs. If the deficiency observed is minor, the Bureau accepts notification and photographs of the repair as record of the work. If the deficiency observed is major, the Bureau performs a reinspection of the facility.

## 6. REFERENCES

- Maryland Department of the Environment (MDE). 2000. *2000 Maryland Stormwater Design Manual. Volume I: Stormwater Management Criteria. Volume II: Stormwater Design Appendices*. MDE Water Management Administration, Baltimore, Maryland. Revised May 2009.
- . 1992. Sediment, Stormwater and Dam Safety. National Pollutant Discharge Elimination System (NPDES) Permit Application Guidance for Operators of Municipal Separate Storm Sewer Systems (MS4). Part 2. July.
- . 1996. *Maryland Dam Safety Manual*.
- Maryland Department of the Environment Water Management Administration. 2011. 2011 Maryland Standards and Specifications for Soil Erosion and Sediment Control
- Soil Conservation Service. 2000. Maryland Standard and Specifications: Pond – Code 378. Revised January.

*This page intentionally left blank*

# **Appendix A. Description and Schematic Drawings of BMPs**

*This page intentionally left blank*

## A. STORMWATER MANAGEMENT FACILITY TYPES AND DESCRIPTIONS

Appendix A provides detailed information for the common stormwater management facility types found within Harford County. These facilities may be similar to one another, but not all components are present within each facility. This chapter has been prepared to provide detailed information on various components and features found in individual types of structural and non-structural facilities. Additional information for each of these types of facilities may be found within the Maryland Department of the Environment (MDE) Water Management Administration's 2000 Maryland Stormwater Design Manual Volumes I and II (Design Manual). The latest version of the Design Manual forms the basis for all stormwater management facility design (Environmental Site Design [ESD] practices and structural practices).

### A.1 PONDS

Stormwater ponds are structural practices that have a permanent pool, or a combination of extended detention or shallow wetland with a permanent pool. Prior to Code revisions, dry extended detention ponds were also utilized. The Design Manual lists the following ponds:

- P-1: Micropool Extended Detention Pond
- P-2: Wet Pond
- P-3: Wet Extended Detention Pond
- P-4: Multiple Pond System
- P-5: Pocket Pond
- P-6: Dry Extended Detention Pond

Pond practices typically include a sediment forebay to pre-treat the flow from the inlet prior to entering the pond.




**Figure A-1-1: Sediment Forebay**

It is important to note that any stormwater management pond that uses an embankment for impounding water is required to follow the latest version of the NRCS-MD 378 Pond Code Standards and Specification for Small Pond Design (378 Pond).

### A.1.1 P-1 MICROPOL Extended DETENTION POND

A micropool extended detention facility includes a smaller permanent pool, which is incorporated into the design of a larger stormwater pond. The facility will have an embankment to create the pond (the pond will have interior side slopes as well as an outside side slope on the embankment). The facility will have an inflow pipe and sediment forebay (or multiple inflow pipes and forebays), a pilot channel through the facility to the micropool, an outlet control structure (riser) with a low flow controlling feature, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Micropool extended detention facilities have landscaping/plantings within the facility.



**Figure A-1.1-1: Micropool Extended Detention Pond**


Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-1.1-2: Micropool Extended Detention Pond**  
Source: Harford County Stormwater Management Inspection Reports

### **A.1.2 P-2 WET POND**

A wet pond facility has a large permanent wet pool with an aquatic bench. The facility will have an embankment to create the pond (the pond will have interior side slopes as well as an outside side slope on the embankment). The facility will have an inflow pipe and sediment forebay (or multiple inflow pipes and forebays), an outlet control structure (riser) with a pond drain, a low flow controlling feature, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Wet pond facilities do not have landscaping/plantings within the facility.



**Figure A-1.2-1: Wet Pond**


Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-1.2-2: Wet Pond**

### A.1.3 P-3 WET EXTENDED DETENTION POND

A wet extended detention pond facility is similar to a wet pond and has a large permanent wet pool with an aquatic bench, except the pond is designed to provide additional temporary ponding storage. The facility will have an embankment to create the pond (the pond will have interior side slopes as well as an outside side slope on the embankment). The facility will have an inflow pipe and sediment forebay (or multiple inflow pipes and forebays), an outlet control structure (riser) with a pond drain, low flow/extended detention controlling features, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Wet extended detention pond facilities do not have landscaping/plantings within the facility.



**Figure A-1.3-1: Wet Extended Detention Pond**


Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-1.3-2: Wet Extended Detention Pond**  
Source: Harford County Stormwater Management Inspection Reports

#### **A-1.4 P-4 MULTIPLE POND SYSTEM**

A multiple pond facility has a series of connected permanent wet pools with associated aquatic benches. The facility will have a perimeter embankment to create the pond (the pond will have interior side slopes as well as an outside side slope on the embankment) and interior embankments to define the multiple ponds. The facility will have an inflow pipe and sediment forebay (or multiple inflow pipes and forebays), a series of internal overflow systems to provide longer flow pathways, an outlet control structure (riser) with a pond drain, a low flow controlling feature, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Multiple pond facilities do not have landscaping/plantings within the facility.




**Figure A-1.4-1: Multiple Pond System**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009

### A.1.5 P-5 POCKET POND

A pocket pond is a wet pond or wetland facility. The contributing drainage area is small and does not provide sufficient base flow and the permanent wet pool is influenced by high groundwater. These ponds have an aquatic safety bench. The facility will have an embankment to create the pond (the pond will have interior side slopes as well as an outside side slope on the embankment). The facility will have an inflow pipe and sediment forebay (or multiple inflow pipes and forebays), an outlet control structure (riser), a low flow controlling feature, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Pocket pond facilities that are created wetlands will have wetland plantings within the facility.



**Figure A-1.5-1: Pocket Pond**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-1.5-2: Pocket Pond**

Source: Maryland Department of the Environment – Facts About: Wet Ponds

### A.1.6 DRY EXTENDED DETENTION POND

A dry extended detention pond facility has a large temporary wet pool. The facility will have an embankment to create the pond (the pond will have interior side slopes as well as an outside side slope on the embankment). The facility will have an inflow pipe and sediment forebay (or multiple inflow pipes and forebays), an outlet control structure (riser) with a pond draining a low flow controlling feature, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Dry extended detention pond facilities are grassed and do not have landscaping/plantings within the facility.



**Figure A-1.6-1: Dry Pond**

### A.2. STORMWATER WETLANDS

Stormwater wetlands are structural practices that create a shallow wetland treatment area and can be combined with small permanent pools and/or extended detention storage. The Design Manual lists the following stormwater wetlands (MDE 2000):


- W-1: Shallow Wetland
- W-2: Extended Detention Shallow Wetland
- W-3: Pond/Wetland System
- W-4: Pocket Wetland
- M-2: Submerged Gravel Wetland (SGW)

Stormwater wetland practices typically include a sediment forebay to pre-treat the flow from the inlet prior to entering the wetland.

It is important to note that any stormwater management ponding practice that uses an embankment for impounding water is required to follow the latest version of the NRCS-MD 378 Pond Code Standards and Specification for Small Pond Design (378 Pond).

### A.2.1 W-1 SHALLOW WETLAND

A shallow wetland is similar to a micropool extended detention facility and includes a smaller low marsh permanent pool, which is incorporated into the design that includes high marsh areas that can also pond water. The facility will have an embankment to create the ponding area (the pond will have interior side slopes as well as an outside side slope on the embankment). The facility will have an inflow pipe and sediment forebay (or multiple inflow pipes and forebays), a low marsh flow/path channel through the facility, an outlet control structure (riser) with a low flow controlling feature, a pond drain, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Shallow wetland facilities have wetland plantings within the facility.



**Figure A-2.1-1: Shallow Wetland**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009




**Figure A-2.1-2: Shallow Wetland**

Source: Maryland Department of the Environment – Facts About: Wetlands

### **A.2.2 W-2 EXTENDED DETENTION SHALLOW WETLAND**

An extended detention shallow wetland is similar to a wet extended detention facility and is designed to provide additional temporary ponding storage. It includes a smaller low marsh permanent pool, which is incorporated into the design that includes high marsh areas that can also pond water. The facility will have an embankment to create the ponding area (the pond will have interior side slopes as well as an outside side slope on the embankment). The facility will have an inflow pipe and sediment forebay (or multiple inflow pipes and forebays), a low marsh flow/path channel through the facility, an outlet control structure (riser) with a low flow controlling feature, a pond drain, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Extended detention shallow wetland facilities have wetland plantings within the facility.



**Figure A-2.2-1: Extended Detention Shallow Wetland**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009




**Figure A-2.2-2: Extended Detention Shallow Wetland**

Source: Maryland Department of the Environment – Facts About: Wetlands

### A.2.3 W-3 POND/WETLAND SYSTEM

A pond/wetland system has a deep permanent pool at the inlet pipe before entering a combination forebay/low marsh permanent pool. The wetland segment is similar to a shallow wetland, which includes high marsh areas that can also pond water. The facility will have an embankment to create the ponding area, an interior embankment with overflow to the low marsh/forebay and interior embankments/side slopes within the wetland area as well as an outside side slope on the embankment. The facility will have an inflow pipe to the wet pond, a low marsh flow/path channel through the facility, an outlet control structure (riser) with a low flow controlling feature, a pond drain, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Pond/wetland facilities only have wetland plantings within the wetland side of the facility.



**Figure A-2.3-1: Pond/Wetland System**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009




**Figure A-2.3-2: Pond/Wetland System**

Source: Harford County Stormwater Management Inspection Reports

#### **A.2.4 W-4 POCKET WETLAND**

A pocket wetland system has a forebay at the inlet pipe before entering a combination of unconnected high marsh and low marsh areas ending at a permanent pool. The wetland segment is similar to a shallow wetland, which includes high marsh areas that can also pond water. The facility will have interior grading to create the low marsh and high marsh areas as well as interior side slopes within the overall area as well as an outside side slope on the embankment. The facility will have an inflow pipe to the forebay, an outlet control structure (riser) with a flow controlling feature to maintain the pool elevation, a pond drain, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Pocket wetland facilities only have wetland plantings within the wetland portion of the facility.



**Figure A-2.4-1: Pocket Wetland**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-2.4-2: Pocket Wetland**

Source: Harford County Stormwater Management Inspection Reports

### A.2.5 M-2: SUBMERGED GRAVEL WETLAND

An SGW is a small-scale filtering system using wetland plants and rock media to provide water quality treatment. The SGW will have interior side slopes as well as an embankment to contain the surface ponding. Depending on the contributing watershed area, an SGW may not require a pretreatment sediment forebay. Runoff leaving the sediment forebay is distributed across the width of the SGW and flows down the length. Distributed flow from the surface is also passed

into the rock media, which is saturated (submerged water level controlled) within 4 inches (in.) of the surface. The surface is provided with select wetland plantings. The facility includes an underdrain system at the bottom with a means of discharging this flow below the surface with a control device (orifice) capable of discharging the surface ponding over a 36-hour time period. Observation wells are provided to monitor the water level. The surface ponding is limited to 2 feet (ft) and is controlled by a riser or weir capable of passing larger storm events. The underdrain system is provided with maintenance cleanouts. When a riser is used, a pipe from this outlet control structure is directed to an outfall location, and erosion protection at the outfall. Some designs have another pipe outfall for the underdrain discharge pipe. SGW facilities may also have an emergency overflow feature on the embankment.



**Figure A-2.5-1: Submerged Gravel Wetland**

Source: Maryland Department of the Environment – Facts About: Submerged Gravel Wetlands

### **A.3. STORMWATER INFILTRATION PRACTICES**


Stormwater infiltration facilities are structural practices that capture and temporarily store stormwater runoff while allowing the capture runoff to seep (infiltrate) into the soil over a defined time period. The Design Manual lists the following Stormwater Infiltration practices (MDE 2000):

- I-1: Infiltration Trench
- I-2: Infiltration Basin
- M-3: Landscape Infiltration
- M-4: Infiltration Berm
- M-5: Dry Well
- M-7: Rain Garden

#### **A.3.1 I-1 INFILTRATION TRENCH**

An infiltration trench system has two components. Stormwater runoff is captured and filtered/pre-treated through a sediment forebay or grass channel prior to entering the stone/gravel media in the infiltration section of the trench. The infiltration section has a slight embankment or other means for creating a small surface pool to allow the runoff to flow through the media and into

the soil below the facility. The end of the trench is provided with an overflow device to allow excessive runoff to safely overtop the trench. Except for the grass channel, an infiltration trench does not have any landscape plantings.



**Figure A-3.1-1: Infiltration Trench**


Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-3.1-2: Infiltration Trench**

### A.3.2 I-2 INFILTRATION BASIN

An infiltration basin, while like an infiltration trench, is larger and has multiple components. Stormwater runoff is captured and filtered/pre-treated through a sediment forebay or grass channel prior to entering the basin area (this is where the stone/gravel media for the infiltration component is located). The facility will have interior side slopes within the overall area as well as an outside side slope on the basin embankment. The facility will have a backup underdrain pipe connected to the riser, an outlet control structure (riser) with a flow controlling feature to create the pooling elevation, a pipe from the outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. Except for the grass in the channel, embankments, and basin surface, an infiltration basin does not have any landscape plantings.



**Figure A-3.2-1: Infiltration Basin**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009




**Figure A-3.2-2: Infiltration Basin**

Source: Maryland Department of the Environment – Facts About: Infiltration Systems

### A.3.3 M-3: LANDSCAPE INFILTRATION

Landscape infiltration uses on-site vegetative planting areas that are depressed to capture, store, and treat stormwater runoff by filtering through the planting soil and media before infiltrating into native soils. Typically used in residential and commercial land uses, these facilities are required to have observation wells and the surface landscaped with a variety of plants.




**Figure A-3.3-1: Landscape Infiltration**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009

### A.3.4 M-3: INFILTRATION BERM

An infiltration berm is a mound of soil and stone placed along the contour to provide runoff storage behind the berm that allows the runoff storage to filter through the berm. When located in areas to be mowed, turf grass is used. Native meadow vegetation and shrubs are used at other locations.



**Figure A-3.4-1: Infiltration Berm**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009




**Figure A-3.4-2: Infiltration Berm**

Source: Maryland Department of the Environment – Facts About: Micro-Bioretenion and Similar Micro-Scale Practices

### A.3.5 M-5: DRY WELL

A dry well is an excavated area or a structural chamber device that is filled with gravel/stone to provide temporary storage of stormwater runoff (typically from roofs) and infiltration prior to the next storm event. Rooftop downspouts are discharged directly into the dry well and underground distribution piping used. Each dry well is required to have an observation well (cap set at ground level).



**Figure A-3.5-1: Dry Well**


Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-3.5-2: Dry Well**

### A.3.6 M-7: RAIN GARDEN

A rain garden is similar to landscape infiltration, except it has a much smaller drainage area and uses a saucer-shaped depression to capture and temporarily store runoff. Stormwater runoff is filtered through an absorbent-planted soil bed with a mulch layer and landscaped with a variety of shrubs, grasses, and flowers. The filtering process is between 24 and 48 hours.



**Figure A-3.6-1: Rain Garden**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-3.6-2: Rain Garden**


## **A.4. STORMWATER FILTERING PRACTICES**

Stormwater filtering practices include both structural practices and small-scale best management practices (BMPs) as described within this section. Stormwater filtering practices capture and temporarily store stormwater runoff while allowing the captured runoff to filter through a media bed prior to discharging to a conveyance system or allowed to partially infiltrate into the soil. The Design Manual lists the following structural Stormwater Filtering Systems (MDE 2000):

- F-1: Surface Sand Filter
- F-2: Underground Sand Filter
- F-3: Perimeter Sand Filter
- F-4: Organic Filter
- F-5: Pocket Sand Filter
- F-6: Bioretention
- M-6: Micro-Bioretention

### **A.4.1 F-1: SURFACE SAND FILTER**

Surface sand filters will have an inflow pipe or other means for directing captured runoff to a pretreatment sediment forebay, a device to distribute the pretreated runoff to the surface of the filter bed, a filter bed with an underdrain collection system, an outlet control structure (riser or overflow spillway), a pipe from the underdrain/outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. The facility will have an embankment to create the forebay and the filter bed (interior side slopes as well as an outside side slope on the embankment). Surface sand filter facilities have landscaping/plantings only within the filter bed.



**Figure A-4.1-1: Surface Sand Filter**


Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-4.1-2: Surface Sand Filter**

### A.4.2 F-2: UNDERGROUND SAND FILTER

Underground sand filters are below-grade structures. They will have an inflow pipe directing captured runoff to a pretreatment sedimentation chamber and pretreated runoff is then sent to the filter bed chamber. The filter bed chamber will have an underdrain collection system, as well as an overflow control structure and a dewatering pipe/system. The overflow chamber is connected to the outlet pipe. Underground sand filter facilities do not have any vegetation within the filter bed.



**Figure A-4.2-1: Underground Sand Filter**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009




**Figure A-4.2-2: Underground Sand Filter – Commercial Location**

Source: Harford County Stormwater Management Inspection Reports

#### **A.4.3 F-3: PERIMETER SAND FILTER**

Perimeter sand filters are below-grade underground sand filter structures. Instead of an inflow pipe, surface runoff is captured by inlet grates into the pretreatment sedimentation chamber and pretreated runoff is then sent to the filter bed chamber. The filter bed chamber will have an underdrain collection system, as well as an overflow control structure and a dewatering pipe/system. The overflow chamber is connected to the outlet pipe. Perimeter sand filter facilities do not have any vegetation within the filter bed.



**Figure A-4.3-1: Perimeter Sand Filter**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009




**Figure A-4.3-2: Perimeter Sand Filter**

Source: Maryland Department of the Environment – Facts About: Sand Filters

### A.4.4 F-4: ORGANIC FILTER

An organic filter is a surface sand filter having a special blend of organic filter media. Like a surface sand filter, the organic filter will have an inflow pipe or other means for directing captured runoff to a pretreatment sediment forebay, a device to distribute the pretreated runoff to the surface of the filter bed, a special organic filter bed with an underdrain collection system, an outlet control structure (riser or overflow spillway), a pipe from the underdrain/outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. The facility will have an embankment to create the forebay and the filter bed (interior side slopes as well as an outside side slope on the embankment). Organic sand filter facilities have landscaping/plantings only within the filter bed.




**Figure A-4.4-1: Organic Filter**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009

### A.4.5 F-5: POCKET SAND FILTER

A pocket sand filter is like a sand filter, except it is used at small sites where sediment loads are expected to be moderate or low. Runoff from an inflow pipe is directed to a pea gravel window prior to a pretreatment sediment forebay, and a filtering embankment is used to distribute the pretreated runoff from the forebay to the surface of the filter bed. The filter bed will also have a pea gravel window, a filter bed with an underdrain collection system, an outlet control structure (riser or overflow spillway), a pipe from the underdrain/outlet control structure to an outfall location, and erosion protection at the outfall. These facilities may also have an emergency overflow feature on the embankment. The facility will have an embankment to create the forebay and the filter bed (interior side slopes as well as an outside side slope on the embankment). Pocket sand filter facilities have landscaping/plantings only within the filter bed.




**Figure A-4.5-1: Pocket Sand Filter**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009

### A.4.6 F-6: BIORETENTION

Bioretention facilities capture surface runoff and pass this flow over a pretreatment stone diaphragm, then over a grass filter strip, before entering the bioretention basin. This basin has an underdrain, special filtering media and curtain drains, surface mulch/pea stone, surface ponding controlled by a weir or outlet control structure, and an outlet pipe. Bioretention facilities have landscaping/plantings.



**Figure A-4.6-1: Bioretention**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009




**Figure A-4.6-2: Bioretention**

Source: Maryland Department of the Environment – Facts About: Bioretention

### A.4.7 M-6: MICRO-BIORETENTION

Micro-bioretention facilities capture surface runoff from a discrete impervious area (drainage area less than 20,000 square ft) and pass this flow through a filter bed (mixture of sand, soil, and organic matter). These facilities have internal side slopes and could have an embankment to create storage. Surface storage depth is limited. Filtered stormwater is either returned to the conveyance system (uses an underdrain) and/or partially infiltrated. Surface ponding is controlled by a weir or outlet control structure, and an outlet pipe. Micro-bioretention facilities have independent observation wells, underdrain cleanouts, and landscaping/plantings.



**Figure A-4.7-1: Micro-Bioretention**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-4.7-2: Micro-Bioretention**

Source: Maryland Department of the Environment – Facts About: Micro-Bioretention and Similar Micro-Scale Practices

## A.5. CHANNELS AND NON-STRUCTURAL


Nonstructural practices are simplistic features primarily focusing on soft grading, and lush landscaping or ground cover to divert runoff away from storm drain systems. Runoff flows over these areas slowly, which allows vegetation to filter the water and infiltrate into the ground.

Nonstructural practices include:

- N-1: Disconnection of Rooftop Runoff
- N-2: Disconnection of Non-Rooftop Runoff
- N-3: Sheetflow to Conservation Areas
- M-8: Swales

### A.5.1 N-1: DISCONNECTION OF ROOFTOP RUNOFF

Rooftop disconnection involves the directing of flow from a roof downspout onto a vegetated area where the runoff can soak into the ground or filter over the vegetated surface.



**Figure A-5.1-1: Disconnection of Rooftop Runoff**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009


To properly function, the contributing roof area is limited to each downspout and the disconnect flow path must be vegetated, gently sloped (less than 5%), and have a defined vegetated flow path.



**Figure A-5.1-2: Disconnection of Rooftop Runoff**

#### A.5.2 N-2: DISCONNECTION OF NON-ROOFTOP RUNOFF

Non-rooftop disconnection involves the directing of flow from an impervious surface onto a vegetated area where the runoff can soak into the ground or filter over the vegetated surface. Commonly applied to small narrow impervious areas like driveways.



**Figure A-5.2-1: Disconnection of Non-rooftop Runoff**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009

To properly function, the impervious area is disconnected onto an adjacent vegetated area with equal flow lengths, gently sloped (less than 5%), and must have a defined vegetated flow path that is not obstructed or flows onto another impervious area.



**Figure A-5.2-2: Disconnection of Non-rooftop Runoff**

Source: Maryland Department of the Environment – Facts About: Nonstructural Environmental Site Design Practices




**Figure A-5.2-3: Disconnection of Non-rooftop Runoff – Gravel Diaphragm/Transition Strip**

Source: Harford County Stormwater Management Inspection Reports

### **A.5.3 N-3: SHEETFLOW TO CONVERSATION AREAS**

Stormwater runoff is directed to a natural area as sheet flow, where it can soak into or filter over the ground. This practice has several design requirements, including the overland slope of 5% or less. To distribute the flow as sheet flow, some form of level spreading device is utilized.



**Figure A-5.3-1: Sheetflow to Conservation Areas**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-5.3-2: Sheetflow to Conservation Areas**

Source: Maryland Department of the Environment – Facts About: Nonstructural Environmental Site Design Practices


## A.5.4 M-8: SWALES

Swales are flow conveyance channels that also provide water quality treatment and flow attenuation of stormwater runoff for linear applications. There are three design variants, which are dependent upon site soils, topography, and drainage characteristics. All swales have a flat bottom (width from 2 to 8 ft), gentle slope (less than 4%), and channel side slopes 3:1 or flatter. The swales also have a thick vegetative cover. These variants are:

- Dry Swale
- Wet Swale
- Bio-swale

### A.5.4.1 Dry Swale

Also known as grass swales, these swales are dry between rainfall events and treatment is limited to no greater than a flow depth of 4 in. There are no plantings within the swale except for the thick grass cover.



**Figure A-5.4.1-1: Dry Swale**


Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-5.4.1-2: Dry Swale**

**A.5.4.2 M-8: Wet Swale**

These swales are designed to store runoff for treatment. Structures such as check dams or weirs are used to create the storage. The wet swale is dry between rainfall events. Typically, there are no plantings within the wet swale except for the thick grass cover.




**Figure A-5.4.2-1: Wet Swale**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-5.4.2-2: Wet Swale**

Source: Maryland Department of the Environment – Facts About: Swales




**Figure A-5.4.2-3: Wet Swale with Check Dams**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11  
July 2019

### **A. 5.4.3 M-8: Bio-Swale**

These swales are also designed to store runoff for treatment. They have a 2 ft to 4 ft deep layer of filtering media in the swale bottom. Underdrains are required in hydrologic soil group C and D soils. Observation wells are required. Outlet control structures/weirs or other structures are used to create the storage. The bio-swale is dry between rainfall events. Typically, there are plantings within the bio-swale as well as the thick grass cover.



**Figure A-5.4.3-1: Bio-Swale**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009



**Figure A-5.4.3-2: Bio-Swale**

Source: Maryland Department of the Environment – Facts About: Swales


## A.6. ALTERNATIVE SURFACES

Alternative surfaces are methods to reduce impervious surface coverage by utilizing more permeable materials to allow for greater rainfall infiltration. Alternative surface categories include:

- A-1: Green Roofs
- A-2: Permeable Pavements
- A-3: Reinforced Turf/Synthetic Grass

### A.6.1 A-1: GREEN ROOFS

Also known as vegetated roofs, a conventional flat or pitched roof is designed to provide a roof garden surface to reduce impervious cover. The two basic green roof designs (distinguished by the media thickness) are “extensive” (a lightweight system using low-growing hardy herbaceous plantings) and “intensive” (thicker soil layers that allow additional planting of shrubs and trees).



**Figure A-6.1-1: Green Roof**


Source: Maryland Department of the Environment – Stormwater Design Manual May 2009

## A.6.2 A-2: PERMEABLE PAVEMENTS

Permeable pavements are used to reduce impervious areas. The commercially available products are classified under three basic types:

- Porous bituminous asphalt
- Pervious/porous cement concrete
- Permeable interlocking concrete pavement (blocks)

These permeable pavements typically consist of a porous surface course above an open graded stone base/subbase or sand (drainage system).



**Figure A-6.2-1: Permeable Pavements**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009

Stormwater runoff drains through the surface into the drainage system and infiltrates into the surrounding soils.



**Figure A-6.2-2: Porous Bituminous Asphalt**



**Figure A-6.2-3: Porous Cement Concrete**



**Figure A-6.2-4: Permeable Interlocking Concrete Pavers**

### **A.6.3 A-3: REINFORCED TURF/SYNTHETIC GRASS**

Reinforced turf systems are used to reduce impervious areas. Typically, these systems consist of an interlocking structural grid with the interstitial areas filled with gravel or suitable soils to sustain a grass surface. Applications for using a reinforced turf system are typically for light traffic areas, such as emergency access and overflow parking.

Synthetic grass systems also reduce the impervious area similar to permeable pavements. Typical application is for the replacement of grass athletic fields with a sustainable surface.



**Figure A-6.3-1: Synthetic Turf/Grass**


Source: Harford County Stormwater Management Inspection Reports

## **A.7. UNDERGROUND STORAGE AND PROPRIETARY SYSTEMS**

Structural underground storage facilities typically provide for the control of stormwater quantity (not stormwater quality). Underground systems are used instead of open basins in commercial/industrial applications in conjunction with the stormwater management treatment systems.

### **A.7.1 M-1 RAINWATER HARVESTING SYSTEMS**

Similar to the capturing of runoff and treating with an M-5 dry well, rainwater harvesting systems divert the runoff to a storage device for future use. Typical residential devices would be rain barrels where large cisterns/storage chambers are used in commercial/industrial applications (e.g., irrigation system supply).



**Figure A-7.1-1: Rain Barrel**

Source: Maryland Department of the Environment – Stormwater Design Manual May 2009

The use of this system for stormwater management is limited due to seasonal demands during winter months.



**Figure A-7.1-2: Rain Barrel**

## A.7.2 PROPRIETARY STRUCTURAL SYSTEMS

MDE maintains a listing of approved practices for alternative/innovative technology. The devices are approved as:

- ESD practice
- Structural practice
- Pretreatment practice
- Erosion and sediment control practice
- System components

Each practice has specific design and maintenance requirements determined by MDE as part of their approval.

### Pretreatment Practice: Stormceptor

CONTECH Stormceptor units are hydro-dynamic treatment devices designed to remove fine to large solids (total suspended solids removal).




Figure A-7.2-1: Stormceptor

### Structural Practice: Stormfilter


CONTECH stormwater management stormfilter is an underground stormwater treatment device that has rechargeable media filled cartridges that trap particulates and adsorb pollutants.



Figure A-7.2-2A: Stormfilter



Figure A-7.2-2B: Stormfilter



**Figure A-7.2-2C: Stormfilter**

*This page intentionally left blank*

**Appendix B. Example Photographs of BMP  
Components and BMP Corrective Action Ranks**

*This page intentionally left blank*

## **B. STORMWATER MANAGEMENT FACILITY EXAMPLE BMP COMPONENT PHOTOGRAPHS AND BMP CORRECTIVE ACTION RANKS**

Appendix B provides example photographs for best management practice components. This Appendix is organized to follow the format used in Section 3: System Inspection Parameters.

### **B.1. INITIAL SIGNIFICANT FAILURE OBSERVED**

**Rating Yes-Embankment:** Significant failure observed in the embankment.



**Figure B-1.1-1: Significant Failure Pond Embankment**

Source: Maryland Department of the Transportation – Stormwater Management Facility Routine Maintenance Manual Version 1.1

**Rating Yes-Outfall:** Significant failure observed in the outfall pipe/area.



**Figure B-1.3-1: Significant Failure Outfall Pipe**

Source: Harford County Stormwater Management Inspection Reports



**Figure B-1.3-2: Significant Failure Outfall Pipe**  
Source: Harford County Stormwater Management Inspection Reports

**Rating Yes-Unable to Inspect/Access Blocked:** Unable to inspect.



**Figure B-1.4-1: Unable to Inspect – Overgrown Access**  
Source: Harford County Stormwater Management Inspection Reports



**Figure B-1.4-2: Unable to Inspect – Access Road Blocked**  
Source: Harford County Stormwater Management Inspection Reports

## B.2. INFLOW

The collected stormwater runoff has various design options for directing stormwater to a stormwater management facility. Example photographs for the following parameters are provided for various types of inflow methods, such as, pipes, swales, and sheet flow, etc. into the stormwater management facility.

### B.2.1 DEBRIS/BLOCKAGE

**Rating 3 – Debris/Blockage:** Significant debris is observed.



**Figure B-2.1-1: Inflow Debris/Blockage**  
Source: Harford County Stormwater Management Inspection Reports

## B.2.2 INFLOW SEDIMENTATION

**Rating 3 – Inflow Sedimentation:** One or more inflow is obstructed by sediment at greater than 20% of the flow depth.



**Figure B-2.2-1: Inflow Sedimentation**

Source: Harford County Stormwater Management Inspection Reports

## B.2.3 INFLOW STABILITY/EROSION

**Rating 2:** Lack of vegetative cover and minor erosion is observed on the swales/channels/slopes to the stormwater facility.



**Figure B-2.3-1: Inflow Slope Stability**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11  
July 2019

**Rating 3:** Erosion observed in the swales/channels/outfalls and from surface water is causing rills and gullies deeper than 6 in.



**Figure B-2.3-2: Swale Erosion**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11 July 2019

**Rating 4:** Pipes/headwall flowing to the stormwater facility are being undermined and will fail to convey the flow into the practice.



**Figure B-2.3-3: Inflow Pipe End Structure Separated**

Source: Maryland Department of the Transportation – Stormwater Management Facility Routine Maintenance Manual Version 1.1

## B.2.4 INFLOW CONDITION

**Rating 2:** Inflow shows signs of wear, degradation, material loss, etc.



**Figure B-2.4-1: Inlet Headwall**

Source: Harford County Stormwater Management Inspection Reports

**Rating 4:** Inflow shows majority signs of wear, degradation, material loss, such as rebar showing in concrete endwall and is rusted, severe outlet pipe damage, riprap stone inflow protection not present, pipe rusted through/cracked.



**Figure B-2.4-2: Inlet Pipe Blockage**

Source: Harford County Stormwater Management Inspection Reports

## B.3. PRETREATMENT

### B.3.1 FOREBAY

#### B.3.1.1 Forebay Sedimentation

**Rating 2:** Forebay is obstructed by sediment at less than 50% of the storage capacity.



**Figure B-3.3.1-1: Sediment Accumulation in Forebay (Sediment Marker Present)**

Source: Harford County Stormwater Management Inspection Reports

**Rating 5:** Forebay is obstructed by sediment at greater than 50% of the storage capacity.



**Figure B-3.3.1-2: Major Sediment Accumulation in Forebay**

Source: Maryland Department of the Transportation – Stormwater Management Facility Routine Maintenance Manual Version 1.1

### B.3.1.2 Forebay Water Surface Elevation



**Figure B-3.1.2-1: Forebay Flooded**

Source: Harford County Stormwater Management Inspection Reports

### B.3.1.3 Forebay Vegetation

**Rating 3:** Forebay is obstructed by vegetation, woody/leafy debris, and/or trash at more than 25% of the surface area.



**Figure B-3.1.3-1: Forebay Obstructed by Vegetation**

Source: Harford County Stormwater Management Inspection Reports

### B.3.1.4 Forebay Control Structure

**Rating 2:** Forebay control structure (berm and/or dewatering device) is partially obstructed by sedimentation, vegetation, woody/leafy debris, and/or minor berm/overflow weir erosion.



**Figure B-3.1.4-1: Forebay Control Structure**

Source: Harford County Stormwater Management Inspection Reports

### B.3.2 GRAVEL DIAPHRAGM

**Rating 1:** Gravel diaphragm – transition strip is functioning as designed and is not clogged with sediment or damaged.



**Figure B-3.2-1: Gravel Diaphragm – Transition Strip**

Source: Harford County Stormwater Management Inspection Reports

## B.4. STORMWATER MANAGEMENT FACILITY

### B.4.1 PONDING

**Rating 3:** Minor pooling/standing water in dry basin facilities OR water level slightly (less than 2 in.) above the design depth/elevation in wet basin facilities with overflow from the low-level control opening. For infiltration trenches or micro-bioretenion system, the water level within the media is less than 6 in. above the bottom.



**Figure B-4.1-1: Surface Standing Water**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11  
July 2019

**Rating 3:** Minor pooling/standing water in dry basin facilities OR water level slightly (less than 2 in.) above the design depth/elevation in wet basin facilities with overflow from the low-level control opening. For infiltration trenches or micro-bioretention system, the water level within the media is less than 6 in. above the bottom.



**Figure B-4.1-2: Surface Standing Water**

Source: Harford County Stormwater Management Inspection Reports

**Rating 8:** Standing water in dry basin facilities OR water level greater than 2 in. above the design depth/elevation in wet basin facilities with overflow from the control structure openings. For infiltration trenches or micro-bioretention system the surface standing water or water level within the media is greater than 6 in. above the bottom.



**Figure B-4.1-3: Surface Sand Filter Ponding – Not Draining**

Source: Maryland Department of the Transportation – Stormwater Management Facility Routine Maintenance Manual Version 1.1

#### **B.4.2 EMBANKMENT**

**Rating 4:** Substantial bare spots, surface rutting/burrows/erosion and/or settling, and large weeds/brush along the perimeter edge and the embankment is less than 3 ft tall.



**Figure B-4.2-1: Embankment**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11 July 2019

**Rating 4:** Substantial bare spots, surface rutting/burrows/erosion and/or settling, and large weeds/brush along the perimeter edge and the embankment is less than 3 ft tall.



**Figure B-4.2-2: Embankment**

Source: Harford County Stormwater Management Inspection Reports



**Figure B-4.2-3: Embankment Animal Burrows**

Source: Harford County Stormwater Management Inspection Reports

### B.4.3 CONVEYANCE

**Rating 6:** Flow path is obstructed by sedimentation, vegetation, woody/leafy debris, and/or eroded.



**Figure B-4.3-1: Flow Path/Pilot Channel**

Source: Harford County Stormwater Management Inspection Reports

#### B.4.4 SEDIMENT

**Rating 4:** Pond/facility is partially obstructed by sediment at less than 25% of the surface area or storage capacity.




**Figure B-4.4-1: Sediment in Pond/Facility**

Source: Harford County Stormwater Management Inspection Reports

#### B.4.5 FACILITY LANDSCAPING/VEGETATION

**Rating 2:** Minor accumulation of invasive species, woody vegetation, or dead plants is observed. Small area of bare soil observed.



**Figure B-4.5-1: Vegetation Observed in Facility**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11  
July 2019

**Rating 2:** Minor accumulation of invasive species, woody vegetation, or dead plants is observed. Small area of bare soil observed.



**Figure B-4.5-2: Small Area of Bare Soil in Grass Swale**

Source: Maryland Department of the Transportation – Stormwater Management Facility Routine Maintenance Manual Version 1.1

**Rating 3:** Large area of bare soil is observed.



**Figure B-4.5-3: Large Area of Bare Soil on Pond Bottom**

Source: Maryland Department of the Transportation – Stormwater Management Facility Routine Maintenance Manual Version 1.1

**Rating 4:** Facility is overrun with invasive species, woody vegetation and/or original planting plan is not obvious.



**Figure B-4.5-4: Overgrown Vegetation**

Source: Harford County Stormwater Management Inspection Reports

#### B.4.6 CONTAMINATION

**Rating 2:** Contamination is observed.



**Figure B-4. 6-1: Contamination**

Source: Harford County Stormwater Management Inspection Reports

## B.4.7 FENCING/SECURITY

**Rating 2:** Fence requires repair.



**Figure B-4. 7-1: Gate Repairs Needed**

Source: Harford County Stormwater Management Inspection Reports



**Figure B-4. 7-2: Remove Vegetation from Fence**

Source: Harford County Stormwater Management Inspection Reports

## B.5. PRINCIPAL OUTLET CONTROL STRUCTURE/SPILLWAY

### B.5.1 RISER – CONTROL STRUCTURE/YARD INLET

**Rating 4:** Riser – Control structure showing signs of deterioration. Openings are partially obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.



**Figure B-5.1-1: Riser-Control Structure**

Source: Harford County Stormwater Management Inspection Reports

**Rating 4:** Riser – Control Structure showing signs of deterioration. Openings are partially obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.



**Figure B-5.1-2: Riser-Control Structure**

Source: Harford County Stormwater Management Inspection Reports

## B.5.2 WEIR

**Rating 1:** Weir wall condition good. Openings are free from sedimentation, vegetation, woody/leafy debris, and/or trash.



**Figure B-5.2-1: Weir Wall**

Source: Harford County Stormwater Management Inspection Reports

**Rating 3:** Weir wall showing signs of deterioration. Openings are partially obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.



**Figure B-5.2-2: Weir Wall - Vegetation**

Source: Harford County Stormwater Management Inspection Reports

### B.5.3 TRASH RACK

**Rating 1:** Trash rack condition good. Openings are free from sedimentation, vegetation, woody/leafy debris, and/or trash.



**Figure B-5.3-1: Trash Racks on Riser**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow  
11 July 2019

**Rating 2:** Openings are partially obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.



**Figure B-5.3-2: Trash Racks Partially Blocked with Vegetation**

Source: Harford County Stormwater Management Inspection Reports

**Rating 4:** Openings are obstructed by sedimentation, vegetation, woody/leafy debris, and/or trash.



**Figure B-5.3-3: Trash Racks Blocked with Debris**  
Source: Harford County Stormwater Management Inspection Reports

#### B.5.4 VALVE

**Rating 1:** Valve is part of the design.



**Figure B-5.4-1: Valve**  
Source: Harford County Stormwater Management Inspection Reports



**Figure B-5.4-2: Valve**

Source: Harford County Stormwater Management Inspection Reports

### **B.5.5 LOW FLOW CONTROL**

**Rating 2:** Low flow/dewatering device showing minor sediment and/or debris blockage.



**Figure B-5.5-1: Low Flow Stone Clogged**

Source: Harford County Stormwater Management Inspection Reports

### B.5.6 OUTFALL PIPE



**Figure B-5.6-1: Outfall Pipe**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11 July 2019

### B.5.7 OUTFALL AREA

**Rating 4:** Outfall area is showing signs of animal burrows, surface rutting/erosion, large weeds, brush, woody vegetation, woody/leafy debris, and/or trash.



**Figure B-5.7-1: Outfall Area Sedimentation**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11 July 2019

## B.5.8 RIPRAP: WEIR AND OUTFALL PIPE

**Rating 4:** Riprap has settlement, stone displacement/migration and/or sediment.



**Figure B-5.8-1: Outfall Riprap**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11  
July 2019

**Rating 4:** Riprap has large weeds, brush, woody vegetation, woody/leafy debris, and/or trash.



**Figure B-5.8-2: Outfall Riprap and Weeds, etc.**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11  
July 2019

### B.5.9 EMERGENCY SPILLWAY

**Rating 1:** Spillway is not showing any signs of settlement, stone displacement, loss of grass cover, erosion, vegetation intrusion, trash/debris, etc.



**Figure B-5.9-1: Emergency Spillway**

Source: Harford County Stormwater Management Inspection Reports

### B.6. MISCELLANEOUS FACILITY COMPONENTS

#### B.6.1 OBSERVATION WELLS



**Figure B-6.1-1: Observation Well**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11  
July 2019

**Rating 3:** Observation well deteriorated. Cap missing/cracked/damaged. Well pipe obstructed/  
blocked by sediment/debris.



**Figure B-6.1-2: Observation Well – Top Damaged**

Source: Maryland Department of the Transportation – Drainage and SWM Maintenance of Today and Tomorrow 11 July 2019

## **B.6.2 UNDERDRAIN CLEANOUTS**

**Rating 2:** Underdrain cleanout showing signs of deterioration. Cap cracked/damaged/hard to open. Cap is not 6 in. above the environmental site design volume (ESDv) ponding level. Minor sediment/debris observed in the cleanout/underdrain pipes.



**Figure B-6.2-1: Underdrain Cleanout – Cap Missing**

Source: Harford County Stormwater Management Inspection Reports

*This page intentionally left blank*

## **Appendix C. Common Proprietary Stormwater Treatment Systems**

*This page intentionally left blank*

## C. COMMON PROPRIETARY STORMWATER TREATMENT SYSTEMS EXAMPLE PHOTOGRAPHS

Appendix C provides example photographs for common proprietary stormwater treatment systems.

### C.1. STORM FILTER



**Figure C.1-1: Storm Filter Cartridges**

Source: Harford County Stormwater Management Inspection Reports

### C.2. STORMCEPTOR



**Figure C-2-1: Stormceptor – Accumulated Debris**

Source: Harford County Stormwater Management Inspection Reports

*This page intentionally left blank*









## FY25 Stormwater BMP Inspections

parcelname	maptype	mapid	mapdates	mapurl	recordingdate	inspdate	lat/long	significant/insurable	pastinspdate	pastinspdate	comments	inspnext	inspnext1	inspnext2	inspnext3	inspnext4	inspnext5	inspector	
Forest Hill Business Center Lot 4 Microbus 2	Micro-Betterment	SWM1125143		NEWPORT DRIVE	02/17/20	11/12/2024	71.17024	14/2/2024			The contractor removed sediment basins at intake and throughout pond bottom. The Contractor repaired principal spillway/replace principle spillway pipe/slopes with disturbed areas have straw and seed applied. Monitoring	3 Years						7/12/2025	emiller@barhordcountyny.gov
Forest Hill Center Sec 2	ROED				3/19/2023	3/19/2023		3/7/2023	Pass									3/9/2024	edolter@barhordcountyny.gov
Forest Hill Industrial Regional Facility	Extended Detention Structure, Dry	SWM1111338		OFF COMMERCE ROAD	03/34/22	8/2/2024		7/31/2024			the overgrown. Repair embankment upstream slopes, remove stand pipe to correct low flow pipe on east side.	30 Days	30 Days				10/31/2024	edolter@barhordcountyny.gov	
Forest Lakes Elementary School	Detention Structure (Dry Pond)	0389664		200 OBERONE PARKWAY	8/5/2004	8/5/2024	84/2004	84/2004	yes curfall		Cut the vegetation throughout the facility. Restore silt channel. Replace the principal spillway pipe.	30 Days		8/4/2024				8/4/2024	emiller@barhordcountyny.gov
Forest Lakes Section 3 Phase 2	ROED			Beck Creek Drive, Forest Hill, MD 12024	02/26/81	11/8/2024		7/48/2024	yes embankment									8/4/2024	emiller@barhordcountyny.gov
Forestville One Section 2 Phase 2	ROED			Southam Drive Drive	03/31/86	10/29/2024		10/29/2024		Pass								1/28/2025	emiller@barhordcountyny.gov
Four Seasons Park	Bar Filter	SWM114335		14633 EASTON ROAD	04/7/77	12/27/2024		12/27/2024		Pass								12/27/2024	emiller@barhordcountyny.gov
Four Seasons Park	Sand Filter	SWM1135640		OFF FRENCH COURT	03/7/80	11/22/2024		11/22/2024		Pass								11/22/2024	emiller@barhordcountyny.gov
Furniture Farm Sec 3 Phase 2	MNR	SWM112377			11/22/2024	11/22/2024		11/22/2024		Pass								11/22/2024	emiller@barhordcountyny.gov
Furniture Equine Rehabilitation Center Microdetention 1	MNR	SWM113774			1/29/2023	1/29/2023		1/13/2023		Pass								1/29/2023	emiller@barhordcountyny.gov
Furniture Equine Rehabilitation Center Microdetention 2	MNR	SWM113774			1/29/2023	1/29/2023		1/13/2023		Pass								1/29/2023	emiller@barhordcountyny.gov
Furniture Equine Rehabilitation Center Microdetention 3	MNR	SWM113774			1/29/2023	1/29/2023		1/13/2023		Pass								1/29/2023	emiller@barhordcountyny.gov
Furniture Equine Rehabilitation Center Microdetention 4	MNR	SWM113774			1/29/2023	1/29/2023		1/13/2023		Pass								1/29/2023	emiller@barhordcountyny.gov
Francis Court	Other	SWM112372		1409-15 15 FRANCIS RD	03/04/20	10/22/2024		10/22/2024		Pass								10/22/2024	emiller@barhordcountyny.gov
Francis Court Phase 2 Aka Auto Assisted Living Bk At Air	Micro-Betterment	SWM112419		1409-15 15 FRANCIS RD	7/3/2024	7/3/2024		7/3/2024		Pass								7/3/2024	emiller@barhordcountyny.gov
Francis Court Phase 2 Aka Auto Assisted Living Bk Air Facility 2	Micro-Betterment	SWM112372		1409-15 15 FRANCIS RD	03/04/20	7/23/2024		7/23/2024		Pass								7/23/2024	emiller@barhordcountyny.gov
Francis Court Phase 2 Aka Auto Assisted Living Bk Air Facility 2	Other	SWM112361		1123/2024	11/23/2024	11/23/2024		11/23/2024		Pass	Address the punch list items. Continue to follow the regular scheduled maintenance schedules.	3 Years						11/23/2024	emiller@barhordcountyny.gov
Francis Park	Rock Pond	SWM111998		35 E JARRETTVILLE ROAD	03/07/88	11/22/2024		11/22/2024	yes usable									11/22/2024	emiller@barhordcountyny.gov
Francis Park Pond Rest	ROED				02/13/80	11/22/2024		11/21/2024		Pass								11/22/2024	emiller@barhordcountyny.gov
Frisco Lay Commercial Vehicle Storage Area	Sumerged Drive Wetlands	SWM111160		N S ROUTE 40	02/13/80	2/26/2023		2/26/2023		Pass								2/26/2023	emiller@barhordcountyny.gov
Frisco Lay Commercial Vehicle Storage Area	Micro-Betterment	SWM1124935		N S ROUTE 40	02/13/80	2/26/2023		2/26/2023		Pass								2/26/2023	emiller@barhordcountyny.gov
Frisco Lay Commercial Vehicle Storage Area	Micro-Betterment	SWM1124935		N S ROUTE 40	02/13/80	2/26/2023		2/26/2023		Pass								2/26/2023	emiller@barhordcountyny.gov
Frisco Lay Commercial Vehicle Storage Area	Micro-Betterment	SWM1124935		N S ROUTE 40	02/13/80	2/26/2023		2/26/2023		Pass								2/26/2023	emiller@barhordcountyny.gov
Gablers Shore Lot 26	Disconnection of Non-Runoff Runoff	SWM1139726		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Lot 27	Disconnection of Non-Runoff Runoff	SWM1139726		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Lot 28	Disconnection of Non-Runoff Runoff	SWM1139726		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 1	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 10	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 11	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 12	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 13	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 14	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 15	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 16	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 17	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 18	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 19	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 20	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 21	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 22	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 23	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 24	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 25	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 26	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 27	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 28	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 29	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 30	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 31	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 32	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 33	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 34	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 35	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 36	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 37	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 38	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 39	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 40	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 41	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot 42	Disconnection of Non-Runoff Runoff	SWM1123597		2108 GABLERS SHORE COURT	01/40/83	5/7/2023		5/8/2023		Pass	The dry wells are functioning as normal	3 Years						5/8/2023	edolter@barhordcountyny.gov
Gablers Shore Multiple Lots - Lot																			









### STORM WATER MANAGEMENT INSPECTION REPORT

Overall Rating: **Fail**

Code: **FAILED MAINTENANCE INSPECTION UNDER HARFORD COUNTY CODE CHAPTER 214-43.44**

The Harford County Bureau of Stormwater Management is committed to keeping its excellence in providing the best available maintenance information for your stormwater facility. Brochures have been created for various types of stormwater management facilities to provide basic and seasonal information, as well as reminders of what not to do within your facility.

Please visit <https://www.harfordcountymd.gov/946/Brochures/>

Facility Type: Extended Detention Structure, Wet  
BMPID: [REDACTED]

Site Location: [REDACTED]  
Description: [REDACTED]

Project Name: [REDACTED]  
Project Number: [REDACTED]  
Site Address: [REDACTED]

Owner Name: [REDACTED]  
Management Company: [REDACTED]  
Address: [REDACTED]  
Email Address: [REDACTED]

General Comments: **Replace the lowflow pipe. Repair the fence throughout the facility. Repair the slope failures throughout the entire facility. Repair the sparse vegetation throughout the facility. Remove the vegetation from the riprap spillways. Replace the principal.**

It is requested that the owner(s) or their engineer submit to the County SWM Dpt. a schedule of work; plan to remediate the necessary repairs within 30 Days of this notification, a direction to bring this facility into compliance with Harford County's Storm Water Management Regulations. Please contact our office at 410-638-3545, ext. 2440, or email [debutler@harfordcountymd.gov](mailto:debutler@harfordcountymd.gov) or if there are any questions and to schedule a reinspection once the work has been completed.

Overview Photo of Practice:



<i>Inspection Parameter</i>	<i>Description</i>	<i>Corrective Action/s</i>
-----------------------------	--------------------	----------------------------

<b>Significant Failure: Outfall</b>	Significant failure observed in the outfall pipe/area.	Replace the principal spillway pipe.
-------------------------------------	--	--------------------------------------

**Photo:**



Inspection Date: November 20, 2024      Reinspection Date: 12/20/2024      Mailed: Yes

Last Storm Event: November 19, 2024

Inspected: [REDACTED]

## Stormwater Pond Spillway Repair

### Plan Review and Approval Process

1. The property owner or HOA hires a Maryland licensed professional engineer to submit repair plans to the Department of Public Works, Bureau of Stormwater Management for review and approval by the Senior Stormwater Engineer, Robert E. Anderson.
2. Engineer/owner/representative can obtain transmittal forms from the Bonding and Permit Administration Office website at <https://www.harfordcountymd.gov/397/Stormwater-Management-Permits>. Please make sure to use Stormwater Transmittal Part 3. The submission is to be marked as "Pond Repair 1<sup>st</sup> Review". To ensure the submission is accepted please ensure the required package is complete.
3. The engineer shall submit updated breach analysis and hydrology & hydraulic computations using the latest NOAA Atlas 14 24-hr rainfall data. The engineer will redline the drawings to reflect current material specifications, construction sequence, as-built, repair certifications, and any sediment controls that may be needed.
4. Upon plan approval, the owner/HOA or his engineer must obtain services from a geotechnical company for soil analysis and compaction of the dam. During construction Geotech will monitor and record the compaction and materials during construction.
5. The owner/HOA will hire a contractor to perform the pipe replacement. The engineer or his representative will be required to inspect and maintain quality control throughout the project. County representatives will periodically stop by the site to ensure a geo-technical person is on-site and proper installation procedures are being followed by the contractor.
6. Land disturbance exceeding 30,000 sq. ft. will require an engineered grading permit. If the land disturbance is less than 30,000 sq. ft., a Standard Erosion Sediment Control Plan permit Application will need to be submitted.  
  
Pond repairs are not impacted with processing or bond fees.  
  
You may obtain these permit applications from the county website at:  
  
<https://www.harfordcountymd.gov/397/Stormwater-Management-Permits>
7. Upon completion, the engineer will submit signed as-built plans, inspection reports, materials list, invoices, and other requested documentation for the as-built approval.

## Significant Failure Remediation Action Plan Status

BMP Name	BMP_ID	Responsible Party	Status	Target Completion Year (FY)	Actual Completion Date (MM/DD/YYYY)
Fairwind Farms Sec 5	SWM111348	County	Actively Performing Repairs	2026	
Ponderosa Estates		County	Actively Performing Repairs	2026	
Woodbridge Center Phase 2		County	Actively Performing Repairs	2026	
Box Hill North Section 7		Owners	Scheduled for Construction	2026	
Brentwood Park Pond	SWM110962	County	Scheduled for Construction	2026	
Brentwood Park WQ 3	SWM110962	Owners	Scheduled for Construction	2026	
Brentwood Park/Valewood SF	SWM110965	Owners	Scheduled for Construction	2026	
Campus Hills Commercial	SWM1125893	Owners	Scheduled for Construction	2026	
Leeswood Garth	SWM112094	County	Scheduled for Construction	2026	
Oak Avenue Rubble Fill Ponds 1	SWM1125185	County	Scheduled for Construction	2026	
Red Pump Fka Vale Rd Elementary School	SWM1124314	(HCPS) County	Scheduled for Construction	2026	
Riverside Business Park Regional Facility	SWM111220	County	Scheduled for Construction	2026	
Thomas Run Station	SWM1125756	Owners	Scheduled for Construction	2026	
Forest Glen Pond 1		Owners	Under Design Review	2026	
North Harford Elementary-Middle School		(HCPS) County	Under Design Review	2026	
Riverside Industrial Park Swm Retrofit	SWM112056	Owners	Under Design Review	2026	
Rt 1 Commercial - Fallston Commercial	SWM1125660	Owners	Under Design Review	2026	
Amyclae Estates Sec 1 Pond 1 (Econ Drive)		County	Pending Assesment	2027	
Amyclae Estates Sec 5 Phase 1		County	Pending Assesment	2027	
Bynum Woods Section 1		County	Pending Assesment	2027	
Constant Friendship 2	SWM1125824	County	Pending Assesment	2027	
Lohrs Orchard Pond 2	SWM112069	County	Pending Assesment	2027	
Lohrs Orchard Pond 4	SWM112071	County	Pending Assesment	2027	
Lohrs Orchard Section 1A Pond 1 (Red Haven)	SWM112067	County	Pending Assesment	2027	
Lohrs Orchard Section 1A Pond 2 Water Quality		County	Pending Assesment	2027	
Lohrs Orchard Section 1A Pond 3	SWM1125740	County	Pending Assesment	2027	
Sablewoods		Owners	Pending Assesment	2027	
Smiths Landing	SWM1125886	County	Pending Assesment	2027	
William Paca Industrial Park	SWM1124954	County	Pending Assesment	2027	
Abingdon Reserve Pond 1	SWM111202	County	Scheduled for Construction	2027	
Bright Oaks Apartments Section 2	SWM1124941	Owners	Scheduled for Construction	2027	
Crown Shell Service Center		Owners	Scheduled for Construction	2027	
Forest Lakes Section 9 Phase 2		County	Scheduled for Construction	2027	
Hidden Stream Section 1 Pond		County	Scheduled for Construction	2027	
Red Pump Elementary School Micropool		(HCPS) County	Scheduled for Construction	2027	
Village of Bynum Run Estates Sec 1 (Clarkson-Dana)	SWM1123524	Owners	Scheduled for Construction	2027	
Box Hill Corporate Center South Pond 2 Retrofit	SWM112087	Owners	Under Design Review	2027	
Coleman Plecker aka Golf America Pond		County	Under Design Review	2027	
Comfort Inn, Motel		Owners	Under Design Review	2027	
Durham Manor Section 1		County	Under Design Review	2027	
Flora Meadows Pond 2	SWM1125891	Owners	Under Design Review	2027	
Forest Glen Pond 2	SWM1126006	Owners	Under Design Review	2027	
Forest Lakes Elementary-Pond	SWM1125022	(HCPS) County	Under Design Review	2027	
Greenbrier Hills Section 8 Pond 3	SWM1125995	Owners	Under Design Review	2027	
International House Of Pancakes	SWM112101	Owners	Under Design Review	2027	
Laurel Valley Retrofit	SWM1125739	Owners	Under Design Review	2027	
Mar-Lin Investors		Owners	Under Design Review	2027	
Overview Manor Pond 1	SWM111206	Owners	Under Design Review	2027	
Ronkin Construction		Owners	Under Design Review	2027	
Southampton Banstead Court		Owners	Under Design Review	2027	
Tollgate Recreation		County	Under Design Review	2027	
Winter Run Industrial Park Retrofit	SWM1125961	County and Owners	Under Design Review	2027	

## Significant Failure Remediation Action Plan Status

BMP Name	BMP_ID	Responsible Party	Status	Target Completion Year (FY)	Actual Completion Date (MM/DD/YYYY)
Birchwood Manor		County	Repairs Complete		6/21/2024
The Church of Jesus Christ of Latter Day Saints		Owner	Repairs Complete		8/15/2024
Sleep Inn		Owner	Repairs Complete		11/22/2024
Victorious Faith Fellowship Church Pond 1		Owner	Repairs Complete		12/18/2024
Hunters Run Phase 5 Section 1 Pond 2		Owner	Repairs Complete		1/2/2025
Dixie Construction	SWM1125982	Owner	Repairs Complete		1/3/2025
Laura's Landing	SWM1126660	County	Repairs Complete		6/30/2025
Greenbrier Hills Section 7	SWM1125999	Owners	Repairs Complete		9/16/2025
Edgewood Recreation Center Proposed Addition Sand Filter	SWM1125621	County	Repairs Complete		10/9/2025
Seven Trails	SWM1125975	Owners	Repairs Complete		10/17/2025
Milton Avenue Commercial North Pervious Concrete Areas	SWM1124925	Owners	Repairs Complete		11/6/2025
Cranberry Woods	SWM1126683	County	Repairs Complete		11/7/2025

<p><b>Remediation Action Plan (RAP) by way of County assessment (Taxation) to Beneficial Users (BU).</b></p> <p>The County RAP is instituted once the HOA/ Owners/BU with or without SWM agreement, whom fail to perform maintenance repairs beyond 1 year of numerous 30 day notices; RAP sequence; County Engineer designs repair plans, County Contractor repairs facility per repair design and returns the facility back over to the HOA/ Owners/ BU in a triennial cycle.</p>
---

## Previous Significant Failures

BMP Name	BMP_ID	Responsible Party	Status	Target Completion Year (FY)	Actual Completion Date (MM/DD/YYYY)
Emmorton Business Park	SWM1126677	County	Actively Performing Repairs	2026	
Amyclae Estates Sec 5 Phase 1 (Agora Place) Infiltration Trench		County	Pending Assessment	2027	
Fairwind Farms Section 2	SWM111990	County	Pending Assessment	2027	
Village of Bynum Run Estates	SWM1125201	Owners	Scheduled for Construction	2027	
Mother's Choice Daycare		Owner	Under Design Review	2027	
Edgewood Walk in Medical Center		Owner	Repairs Complete		7/18/2025
Otter Creek Landing Sec 2 Phase 1 Pond ( Blueberry Ct.)		Owner	Repairs Complete		11/10/2025
Rooted Bible Fellowship Church		County	Repairs Complete		11/12/2025